
Sistemi za odkrivanje in javljanje požara ter alarmiranje - 30. del: Večsenzorski javljalniki požara - Točkovni javljalniki s senzorjema za zaznavanje ogljikovega monoksida in toplote

Fire detection and fire alarm systems - Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors

Brandmeldeanlagen - Teil 30: Mehrfachsensor-Brandmelder - Punktförmige Melder mit kombinierten CO- und Wärmesensoren

Système de détection et d'alarme incendie - Partie 30: Détecteurs d'incendie multicapteur - Détecteurs ponctuels utilisant une combinaison de capteurs de monoxyde de carbone et de température

Ta slovenski standard je istoveten z: EN 54-30:2015

ICS:

13.220.20	Požarna zaščita	Fire protection
13.320	Alarmni in opozorilni sistemi	Alarm and warning systems

SIST EN 54-30:2015**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 54-30:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

EUROPEAN STANDARD

EN 54-30

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2015

ICS 13.220.20

English Version

Fire detection and fire alarm systems - Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors

Système de détection et d'alarme incendie - Partie 30:
DéTECTEURS d'incendie multicapteur - DéTECTEURS ponctuels
utilisant une combinaison de capteurs de monoxyde de
carbone et de température

Brandmeldeanlagen - Teil 30: Mehrfachsensor-
Brandmelder - Punktförmige Melder mit kombinierten CO-
und Wärmesensoren

This European Standard was approved by CEN on 25 January 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	6
Introduction	8
1 Scope	9
2 Normative references	9
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions	10
3.2 Abbreviations	10
4 Requirements	10
4.1 General.....	10
4.2 Nominal activation conditions/sensitivity	10
4.2.1 Individual alarm indication	10
4.2.2 Rate sensitive CO response	11
4.2.3 Response to slowly developing fires.....	11
4.2.4 Repeatability of CO response.....	11
4.2.5 Directional dependence of CO response	11
4.2.6 Directional dependence of heat response	11
4.2.7 Lower limit of heat response	11
4.2.8 Reproducibility of CO response	11
4.2.9 Reproducibility of heat response.....	11
4.2.10 Air movement	11
4.3 Operational reliability	12
4.3.1 Connection of ancillary devices	12
4.3.2 Monitoring of detachable detectors	12
4.3.3 Manufacturer's adjustments	12
4.3.4 On-site adjustment of behaviour.....	12
4.3.5 Software-controlled detectors	12
4.3.6 Long-term stability.....	13
4.4 Tolerance to supply voltage — Variation in supply parameters.....	14
4.5 Performance parameters under fire conditions — Fire sensitivity	14
4.6 Durability of nominal activation/sensitivity	14
4.6.1 Temperature resistance	14
4.6.2 Humidity resistance.....	14
4.6.3 Corrosion resistance — SO ₂ corrosion (endurance)	14
4.6.4 Shock and vibration resistance.....	15
4.6.5 Electrical stability — EMC, immunity (operational).....	15
4.6.6 Resistance to chemical agents	15
5 Test and evaluation methods	15
5.1 General.....	15
5.1.1 Atmospheric conditions for tests	15
5.1.2 Operating conditions for tests	16
5.1.3 Mounting arrangements	16
5.1.4 Tolerances	16
5.1.5 Measurement of CO response value.....	16
5.1.6 Measurement of heat response value	17
5.1.7 Provision for tests	17
5.1.8 Test schedule	18
5.2 Nominal activation conditions/sensitivity	19

5.2.1	Individual alarm indication	19
5.2.2	Rate sensitive CO response	19
5.2.3	Response to slowly developing fire	19
5.2.4	Repeatability of CO response	20
5.2.5	Directional dependence of CO response	20
5.2.6	Directional dependence of heat response	21
5.2.7	Lower limit of heat response	21
5.2.8	Reproducibility of CO response	22
5.2.9	Reproducibility of heat response	22
5.2.10	Air movement	23
5.3	Operational reliability	23
5.3.1	Connection of ancillary devices	23
5.3.2	Monitoring of detachable detectors	23
5.3.3	Manufacturer's adjustments	23
5.3.4	On-site adjustment of behaviour	23
5.3.5	Software controlled devices	23
5.3.6	Long-term stability (operational)	24
5.4	Tolerance to supply voltage — Variations in supply parameters	24
5.4.1	Object	24
5.4.2	Test procedure	24
5.4.3	Requirements	24
5.5	Performance parameters under fire conditions — Fire sensitivity	25
5.5.1	Object	25
5.5.2	Principle	25
5.5.3	Test procedure	25
5.5.4	Requirements	27
5.6	Durability	27
5.6.1	Temperature resistance	27
5.6.2	Humidity resistance	30
5.6.3	Corrosion resistance — Sulphur dioxide SO ₂ corrosion (endurance)	34
5.6.4	Shock and vibration resistance	35
5.6.5	Electrical stability — EMC, immunity (operational)	39
5.6.6	Resistance to chemical agents	41
6	Assessment and verification of constancy of performance (AVCP)	43
6.1	General	43
6.2	Type testing	43
6.2.1	General	43
6.2.2	Test samples, testing and compliance criteria	44
6.2.3	Test reports	44
6.3	Factory production control (FPC)	44
6.3.1	General	44
6.3.2	Requirements	45
6.3.3	Product specific requirements	47
6.3.4	Initial inspection of factory and FPC	48
6.3.5	Continuous surveillance of FPC	48
6.3.6	Procedure for modifications	49
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities	49
7	Classification	50
8	Marking, labelling and packaging	50
Annex A	(normative) Gas test chamber for CO response value and cross-sensitivity to chemical agents	51
A.1	General	51
A.2	Gas test chamber specification	51

EN 54-30:2015 (E)

Annex B (normative) Fire test room	52
B.1 General	52
B.2 Fire test room specification	52
Annex C (normative) Measuring instruments for smoke and CO	55
C.1 General	55
C.2 CO measuring instrument	55
C.3 Obscuration meter	55
C.4 Measuring ionization chamber (MIC)	55
Annex D (informative) Establishing exposure levels of chemical agents	56
D.1 General	56
D.2 Establishing concentration of chemical agents for test gases 1 to 9 of 5.23	56
D.3 Verification of test chamber leakage	56
D.4 Establishing concentration of ozone	56
Annex E (normative) Heat tunnel for heat response value	58
E.1 General	58
E.2 Heat tunnel specification	58
Annex F (normative) Smouldering (pyrolysis) wood fire (TF2)	59
F.1 General	59
F.2 Fuel	59
F.3 Hotplate	59
F.4 Arrangement	59
F.5 Heating rate	59
F.6 End-of-test condition	59
F.7 Test validity criteria	60
Annex G (normative) Glowing smouldering cotton fire (TF3)	64
G.1 Introduction	64
G.2 Fuel	64
G.3 Arrangement	64
G.4 Ignition	65
G.5 End-of-test condition	66
G.6 Test validity criteria	66
Annex H (normative) Open plastics (polyurethane) fire (TF4)	70
H.1 Introduction	70
H.2 Fuel	70
H.3 Conditioning	70
H.4 Arrangement	70
H.5 Ignition	70
H.6 Method of ignition	70
H.7 End-of-test condition	70
H.8 Test validity criteria	71
Annex I (normative) Liquid (heptane) fire (TF5)	74
I.1 Introduction	74
I.2 Fuel	74
I.3 Arrangement	74
I.4 Ignition	74
I.5 End-of-test condition	74
I.6 Test validity criteria	74
Annex J (informative) Information concerning the construction of the gas test chamber	78
J.1 General	78
J.2 Construction of the gas test chamber	78
Annex K (informative) Construction of the heat tunnel	80
K.1 General	80

K.2	Construction of the heat tunnel	80
Annex L	(informative) Apparatus for impact test.....	84
L.1	General	84
L.2	Impact apparatus construction.....	84
Annex ZA	(informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation.....	87
Bibliography	97

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 54-30:2015](https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015)

<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

EN 54-30:2015 (E)**Foreword**

This document (EN 54-30:2015) has been prepared by Technical Committee CEN/TC 72 "Fire detection and fire alarm systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2015, and conflicting national standards shall be withdrawn at the latest by April 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of Regulation (EU) 305/2011.

For relationship with EU Regulations see informative Annex ZA, which is an integral part of this document.

EN 54, *Fire detection and fire alarm systems*, consists of the following parts:

- *Part 1: Introduction;*
- *Part 2: Control and indicating equipment;*
- *Part 3: Fire alarm devices — Sounders;*
- *Part 4: Power supply equipment;*
- *Part 5: Heat detectors — Point detectors;*
- *Part 7: Smoke detectors — Point detectors using scattered light, transmitted light or ionization;*
- *Part 10: Flame detectors — Point detectors;*
- *Part 11: Manual call points;*
- *Part 12: Smoke detectors — Line detectors using an optical light beam;*
- *Part 13: Compatibility assessment of system components;*
- *Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance [CEN Technical Specification];*
- *Part 16: Voice alarm control and indicating equipment;*
- *Part 17: Short circuit isolators;*
- *Part 18: Input/output devices;*
- *Part 20: Aspirating smoke detectors;*
- *Part 21: Alarm transmission and fault warning routing equipment;*
- *Part 22: Resettable line-type heat detectors [currently at acceptance stage];*
- *Part 23: Fire alarm devices — Visual alarms devices;*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

- *Part 24: Components of voice alarm systems — Loudspeakers;*
- *Part 25: Components using radio links;*
- *Part 26: Carbon monoxide detectors — Point detectors;*
- *Part 27: Duct smoke detectors;*
- *Part 28: Non-resettable line type heat detectors [currently at drafting stage];*
- *Part 29: Multi-sensor fire detectors — Point detectors using a combination of smoke and heat sensors;*
- *Part 30: Multi-sensor fire detectors — Point detectors using a combination of carbon monoxide and heat sensors [the present document];*
- *Part 31: Multi-sensor fire detectors — Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors;*
- *Part 32: Planning, design, installation, commissioning, use and maintenance of voice alarm systems [currently at acceptance stage].*

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to www.cen.eu.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

[SIST EN 54-30:2015](https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015)

<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

EN 54-30:2015 (E)**Introduction**

Carbon monoxide (CO) is a product of the incomplete combustion of carbon-based materials. CO fire detectors can react promptly to smouldering fires involving carbonaceous materials because CO does not depend solely on convection, but also moves by diffusion. CO fire detectors might be better suited to applications where other fire detection techniques are prone to false alarms, for example due to dust, steam and cooking vapours. Detectors based on the use of CO sensors alone, are covered by EN 54-26.

Some fires may not produce a sufficient amount of CO to trigger an alarm condition from a detector conforming to EN 54-26. These are typically free-burning, open, well-ventilated fires. The inclusion of heat sensing combined with CO sensing can increase the sensitivity of such a detector to these types of fires.

A number of different methods for sensing CO are suitable. However, most sensors will also be influenced by other gases and phenomena. Tests have therefore been included in the test schedule to assess cross-sensitivity to substances normally present in the service environment that may affect the performance of the detector.

Test Fires TF2, TF3, TF4 and TF5 from EN 54-7 have been included to verify the detection performance. TF4 and TF5 specifically demonstrate the influence of the heat sensor(s). For these Test Fires, the CO level and, where applicable, the temperature is used as test validity criteria.

Detectors may have modes of operation, in which only one fire phenomenon is evaluated. This standard does not include tests for additional alarm outputs corresponding to the sensing of only one fire phenomenon. Reference should be made to other parts of EN 54, which may cover such modes of operation or outputs.

iteh STANDARD PREVIEW
(standards.iteh.ai)
SIST EN 54-30:2015
<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

1 Scope

This European Standard specifies requirements, test methods and performance criteria for point-type multi-sensor fire detectors for use in fire detection systems installed in and around buildings (see EN 54-1:2011), incorporating in one mechanical enclosure at least one carbon monoxide sensor and at least one heat sensor and where the overall fire detection performance is determined utilizing the combination of the detected phenomena.

This European Standard provides for the assessment and verification of consistency of performance (AVCP) of multi-sensor fire detectors using a combination of carbon monoxide and heat sensors to this EN.

Multi-sensor fire detectors using carbon monoxide and heat sensors having special characteristics suitable for the detection of specific fire risks are not covered by this European Standard. The performance requirements for any additional functions are beyond the scope of this standard (e.g. additional features or enhanced functionality for which this European Standard does not define a test or assessment method).

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems — Part 1: Introduction*

EN 54-5:2000¹⁾, *Fire detection and fire alarm systems — Part 5: Heat detectors - Point detectors*

EN 54-7:2000²⁾, *Fire detection and fire alarm systems — Part 7: Smoke detectors — Point detectors using scattered light, transmitted light or ionization*

EN 50130-4:2011, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:2014, *Environmental testing — Part 1: General and guidance (IEC 60068-1:2013)*

EN 60068-2-1:2007, *Environmental testing — Part 2-1: Tests — Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-2:2007, *Environmental testing — Part 2-2: Tests — Test B: Dry heat (IEC 60068-2-2:2007)*

EN 60068-2-6:2008, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:2007)*

EN 60068-2-27:2009, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock (IEC 60068-2-27:2008)*

EN 60068-2-30:2005, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

1) This document is currently impacted by the stand-alone amendment EN 54-5:2000/A1:2002.

2) This document is currently impacted by the stand-alone amendments EN 54-7:2000/A1:2002 and EN 54-7:2000/A2:2006.

EN 54-30:2015 (E)

EN 60068-2-42:2003, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-78:2013, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state (IEC 60068-2-78:2012)*

ISO 209:2007, *Wrought aluminium and aluminium alloys — Chemical composition and forms of products — Part 1: Chemical composition*

3 Terms, definitions and abbreviations**3.1 Terms and definitions**

For the purposes of this document, the terms and definitions given in EN 54-1:2011 and the following apply.

3.1.1**CO response value**

CO concentration in the proximity of the specimen at the moment that it generates an alarm signal

Note 1 to entry: When tested as described in 5.1.5.

Note 2 to entry: The response value may depend on signal processing in the detector and in the control and indicating equipment.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.1.2**rate-sensitive**

behaviour of a detector that depends on the rate of change of CO concentration

[SIST EN 54-30:2015](https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015)

3.2 Abbreviations

<https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015>

EMC electromagnetic compatibility

4 Requirements**4.1 General**

In order to conform to this standard, the detector shall meet the requirements of this clause, which shall be verified by visual inspection or engineering assessment or shall be tested as described in Clause 5 and shall meet the requirements of the tests.

4.2 Nominal activation conditions/sensitivity**4.2.1 Individual alarm indication**

Each detector shall be provided with an integral red visual indicator, by which the individual detector that released the alarm can be identified, until the alarm condition is reset. Where other conditions of the detector can be visually indicated, they shall be clearly distinguishable from the alarm indication, except when the detector is switched into a service mode. For detachable detectors, the indicator may be integral with the base or the detector head. The visual indicator shall be visible from a distance of 6 m directly below the detector, in an ambient light intensity up to 500 lux when assessed as described in 5.2.1.

4.2.2 Rate sensitive CO response

The CO response value of the detector may depend on the rate of change of CO concentration in the vicinity of the detector. Such behaviour may be incorporated in the detector design to improve the discrimination between ambient CO levels and those generated by a fire. If such rate sensitive behaviour is included then it shall not lead to a significant reduction in the detector's sensitivity to fires, nor to a significant increase in the probability of a false alarm when assessed as specified in 5.2.2.

4.2.3 Response to slowly developing fires

Carbon monoxide detectors may incorporate provision for "drift compensation", for example to compensate for sensor drift due to the ageing of the CO sensor or the build-up of contaminants in the detector. If such drift compensation is included, then it shall not lead to a significant change in the detector's sensitivity to slowly developing fires when assessed as specified in 5.2.3.

4.2.4 Repeatability of CO response

The detector shall have stable behaviour with respect to its sensitivity to CO after a number of alarm conditions and shall meet the requirements specified in 5.2.4.

4.2.5 Directional dependence of CO response

The sensitivity of the detector to CO shall not be unduly dependent on the direction of airflow around it and shall meet the requirements specified in 5.2.5.

4.2.6 Directional dependence of heat response

The heat sensitivity of the detector shall not be unduly dependent on the direction of airflow around it and shall meet the requirements specified in 5.2.6.

4.2.7 Lower limit of heat response

The detector shall not be more sensitive to heat alone, without the presence of CO, than is permitted in EN 54-5 and shall meet the requirements specified in 5.2.7.

4.2.8 Reproducibility of CO response

The sensitivity of the detector to CO shall not vary unduly from specimen to specimen and shall meet the requirements specified in 5.2.8.

4.2.9 Reproducibility of heat response

The heat sensitivity of the detector shall not vary unduly from specimen to specimen and shall meet the requirements specified in 5.2.9.

4.2.10 Air movement

The sensitivity of the detector to CO shall not be unduly affected by the rate of the airflow and shall meet the requirements specified in 5.2.10.

EN 54-30:2015 (E)**4.3 Operational reliability****4.3.1 Connection of ancillary devices**

Where the detector provides for connections to ancillary devices (e.g. remote indicators, control relays), open- or short-circuit failures of these connections shall not prevent the correct operation of the detector.

4.3.2 Monitoring of detachable detectors

For detachable detectors, a means shall be provided for a remote monitoring system (e.g. the control and indicating equipment) to detect the removal of the head from the base, in order to give a fault signal.

4.3.3 Manufacturer's adjustments

It shall be possible to change the manufacturer's settings only by special means (e.g. the use of a special code or tool) or by breaking or removing a seal.

4.3.4 On-site adjustment of behaviour

If there is provision for on-site adjustment of the response behaviour of the detector then:

- for each setting at which the manufacturer claims compliance with this standard, the detector shall conform to the requirements of this standard, and access to the adjustment means shall only be possible by the use of a code or special tool or by removing the detector from its base or mounting;
- any setting(s) at which the manufacturer does not claim compliance with this standard, shall only be accessible by the use of a code or special tool, and it shall be clearly marked on the detector or in the associated data, that if these setting(s) are used, the detector does not conform to the standard.

These adjustments may be carried out on the detector or at the control and indicating equipment.

4.3.5 Software-controlled detectors**4.3.5.1 General**

For detectors which rely on software control in order to fulfil the requirements of this standard, the requirements of 4.3.5.2, 4.3.5.3 and 4.3.5.4 shall be met.

4.3.5.2 Software documentation**4.3.5.2.1 Design overview**

Documentation shall be submitted that gives an overview of the software design. This documentation shall be in sufficient detail for the design to be inspected for compliance with this standard and shall include at least the following:

- a) a functional description of the main program flow (e.g. as a flow diagram or structogram) including:
 - 1) a brief description of the modules and the functions that they perform;
 - 2) the way in which the modules interact;
 - 3) the overall hierarchy of the program;
 - 4) the way in which the software interacts with the hardware of the detector;

- 5) the way in which the modules are called, including any interrupt processing;
- b) a description of which areas of memory are used for the various purposes (e.g. the program, site specific data and running data);
- c) a designation, by which the software and its version can be uniquely identified.

4.3.5.2.2 Design detail

The manufacturer shall have available detailed design documentation, which only needs to be provided if required by the testing authority. It shall comprise at least the following:

- a) an overview of the whole system configuration, including all software and hardware components;
- b) a description of each module of the program, containing at least:
 - 1) the name of the module;
 - 2) a description of the tasks performed;
 - 3) a description of the interfaces, including the type of data transfer, the valid data range and the checking for valid data;
- c) full source code listings, as hard copy or in machine-readable form (e.g. ASCII-code), including all global and local variables, constants and labels used, and sufficient comment for the program flow to be recognized;
- d) details of any software tools used in the design and implementation phase (e.g. CASE-tools, compilers).

4.3.5.3 Software design

SIST EN 54-30:2015

[https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-](https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015)

[17d92ade3084/sist-en-54-30-2015](https://standards.iteh.ai/catalog/standards/sist/891ce8a0-1cc1-4260-ac8e-17d92ade3084/sist-en-54-30-2015)

In order to ensure the reliability of the detector, the following requirements for software design shall apply:

- a) the software shall have a modular structure;
- b) the design of the interfaces for manually and automatically generated data shall not permit invalid data to cause error in the program operation;
- c) the software shall be designed to avoid the occurrence of deadlock of the program flow.

4.3.5.4 The storage of programs and data

The program necessary to conform to this standard and any pre-set data, such as manufacturer's settings, shall be held in non-volatile memory. Writing to areas of memory containing this program and data shall only be possible by the use of some special tool or code and shall not be possible during normal operation of the detector.

Site-specific data shall be held in memory which will retain data for at least two weeks without external power to the detector, unless provision is made for the automatic renewal of such data, following loss of power, within 1 h of power being restored.

4.3.6 Long-term stability

The detectors shall be stable over long periods of time and shall meet the requirements specified in 5.3.6.3.