
**Reciprocating internal combustion
engine driven alternating current
generating sets —**

Part 3:

**Alternating current generators for
generating sets**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

*Groupes électrogènes à courant alternatif entraînés par moteurs
alternatifs à combustion interne —*

Partie 3: Alternateurs pour groupes électrogènes

<https://standards.iteh.ai/catalog/standards/sist/2e8faa4c-12a7-44b6-a5f6-5bb909e3df07/iso-8528-3-2005>



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 8528-3:2005

<https://standards.iteh.ai/catalog/standards/sist/2e8faa4c-f2a7-44b6-a5f6-5bb909e3df07/iso-8528-3-2005>

© ISO 2005

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
1 Scope	1
2 Normative references	1
3 Symbols, terms and definitions	2
4 Other requirements and additional regulations	6
5 Rating	6
5.1 General.....	6
5.2 Basic continuous rating (BR)	6
5.3 Peak continuous rating (PR).....	6
6 Limits of temperature and temperature rise	7
6.1 Basic continuous rating	7
6.2 Peak continuous rating	7
7 Rated power and speed characteristics	7
8 Voltage characteristics.....	7
9 Parallel operation.....	7
10 Special load conditions.....	8
10.1 General.....	8
10.2 Unbalanced load current.....	8
10.3 Sustained short-circuit current.....	8
10.4 Occasional excess current capability.....	8
10.5 Telephone Harmonic Factor (THF).....	8
10.6 Radio interference suppression (F)	9
11 Effect of electromechanical frequency of vibrations when sets operate in parallel	9
12 Asynchronous generators with excitation equipment.....	9
12.1 General.....	9
12.2 Sustained short-circuit current	9
12.3 Range of voltage setting	9
12.4 Parallel operation.....	9
13 Operating limit values	10
14 Rating plate	10
Annex A (normative) Transient voltage characteristic of an a.c. generator following a sudden change in load	11

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 8528-3 was prepared by Technical Committee ISO/TC 70, *Internal combustion engines*.

This second edition cancels and replaces the first edition (ISO 8528-3:1993), which has been technically revised.

ISO 8528 consists of the following parts, under the general title *Reciprocating internal combustion engine driven alternating current generating sets*:

- *Part 1: Application, ratings and performance*
- *Part 2: Engines*
- *Part 3: Alternating current generators for generating sets*
- *Part 4: Controlgear and switchgear*
- *Part 5: Generating sets*
- *Part 6: Test methods*
- *Part 7: Technical declarations for specification and design*
- *Part 8: Requirements and tests for low-power generating sets*
- *Part 9: Measurement and evaluation of mechanical vibrations*
- *Part 10: Measurement of airborne noise by the enveloping surface method*
- *Part 11¹⁾: Rotary uninterruptible power supply systems — Performance requirements and test methods*
- *Part 12: Emergency power supplies to safety services*

1) Part 11 will be published as ISO/IEC 88528-11.

Reciprocating internal combustion engine driven alternating current generating sets —

Part 3: Alternating current generators for generating sets

1 Scope

This part of ISO 8528 specifies the principal characteristics of Alternating Current (a.c.) generators under the control of their voltage regulators when used in generating set applications. It supplements the requirements of IEC 60034-1.

NOTE At present no International Standard is available for asynchronous generators. When such an International Standard is published, this part of ISO 8528 will be revised accordingly.

This part of ISO 8528 applies to a.c. generators used in a.c. generating sets driven by reciprocating internal combustion (RIC) engines for land and marine use, excluding generating sets used on aircraft or to propel land vehicles and locomotives.

For some specific applications (e.g. essential hospital supplies, high-rise buildings), supplementary requirements may be necessary. The provisions of this part of ISO 8528 should be regarded as the basis for establishing any supplementary requirements.

For a.c. generating sets driven by other reciprocating-type prime movers (e.g. steam engines) the provisions of this part of ISO 8528 should be used as a basis for establishing these requirements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 8528-1²⁾, *Reciprocating internal combustion engine driven alternating current generating sets — Part 1: Application, ratings and performance*

IEC 60034-1, *Rotating electrical machines — Part 1: Rating and performance*

CISPR 14-1, *Limits and methods of measurement of radio interference characteristics of household electrical appliances, portable tools and similar electrical apparatus*

CISPR 15, *Limits and methods of measurement of radio interference characteristics of fluorescent lamps and luminaires*

2) To be published.

3 Symbols, terms and definitions

For indications of technical data for electrical equipment, IEC uses the term “rated” and the subscript “N”. For indications of technical data for mechanical equipment, ISO uses the term “declared” and the sub-script “r”. Therefore, in this part of ISO 8528, the term “rated” is applied only to electrical items. Otherwise, the term “declared” is used throughout.

An explanation of the symbols and abbreviations used in this International Standard are shown in Table 1.

Table 1 — Symbols, terms and definitions

Symbol	Term	Unit	Definition
U_s	Set voltage	V	Line-to-line voltage for defined operation selected by adjustment.
$U_{st,max}$	Maximum steady-state voltage deviation	V	
$U_{st,min}$	Minimum steady-state voltage deviation	V	
U_r	Rated voltage	V	Line-to-line voltage at the terminals of the generator at the rated frequency and rated output. NOTE Rated voltage is the voltage assigned by the manufacturer for operating and performance characteristics.
U_{rec}	Recovery voltage	V	Maximum obtainable steady-state voltage for a specified load condition. NOTE Recovery voltage is normally expressed as a percentage of the rated voltage. It normally lies within the steady-state voltage tolerance band (ΔU). For loads in excess of the rated load, recovery voltage is limited by saturation and exciter-regulator field forcing capability (see Figure A.2.1).
$U_{s,do}$	Downward adjustable voltage	V	
$U_{s,up}$	Upward adjustable voltage	V	
U_0	No-load voltage	V	Line-to-line voltage at the terminals of the generator at rated frequency and no-load.
$U_{dyn,max}$	Maximum upward transient voltage on load decrease	V	
$U_{dyn,min}$	Minimum downward transient voltage on load increase	V	
ΔU	Steady-state voltage tolerance band	V	Agreed voltage band about the steady-state voltage that the voltage reaches within a given regulating period after a specified sudden increase or decrease of load given by: $\Delta U = 2\delta U_{st} \times \frac{U_r}{100}$

Table 1 (continued)

Symbol	Term	Unit	Definition
ΔU_s	Range of voltage setting	V	Range of maximum possible upward and downward adjustment of voltage at the generator terminals at rated frequency, for all loads between no-load and rated output and within the agreed range of power factor given by: $\Delta U_s = \Delta U_{s,up} + \Delta U_{s,do}$
$\Delta U_{s,do}$	Downward range of voltage setting	V	Range between the rated voltage and downward adjustment of voltage at the generator terminals at rated frequency, for all loads between no-load and rated output within the agreed range of power factor given by: $\Delta U_{s,do} = U_r - U_{s,do}$
$\Delta U_{s,up}$	Upward range of voltage setting	V	Range between the rated voltage and upward adjustment of voltage at the generator terminals at rated frequency, for all loads between no-load and rated output within the agreed range of power factor given by: $\Delta U_{s,up} = U_{s,up} - U_r$
δU_{dyn}	Transient voltage deviation	V	
δU_{dyn}^-	Transient voltage deviation on load increase ^a	%	Transient voltage deviation on load increase is the voltage drop when the generator, driven at rated speed and at rated voltage under normal excitation control, is switched onto rated load, expressed as a percentage of rated voltage given by: $\delta U_{dyn}^- = \frac{U_{dyn,min} - U_r}{U_r} \times 100$
δU_{dyn}^+	Transient voltage deviation on load decrease ^a	%	Transient voltage deviation on load decrease is the voltage rise when the generator, driven at rated speed and at rated voltage under normal excitation control, has a sudden rejection of rated load, expressed as a percentage of rated voltage given by: $\delta U_{dyn}^+ = \frac{U_{dyn,max} - U_r}{U_r} \times 100$ If the load change differs from the above-defined values, then the specified values and the associated power factors shall be stated.
δU_s	Related range of voltage setting	%	Range of voltage setting expressed as a percentage of the rated voltage given by: $\delta U_s = \frac{U_{s,up} + U_{s,do}}{U_r} \times 100$

Table 1 (continued)

Symbol	Term	Unit	Definition
$\delta U_{s,do}$	Related downward range of voltage setting	%	Downward range of voltage setting expressed as a percentage of the rated voltage given by: $\delta U_{s,do} = \frac{U_r - U_{s,do}}{U_r} \times 100$
$\delta U_{s,up}$	Related upward range of voltage setting	%	Upward range of voltage setting, expressed as a percentage of the rated voltage given by: $\delta U_{s,up} = \frac{U_{s,up} - U_r}{U_r} \times 100$
δU_{st}	Steady-state voltage deviation	%	Change in steady-state voltage for all load changes between no-load and rated output, taking into account the influence of temperature, but not considering the effect of quadrature-current compensation droop. NOTE The initial set voltage is usually the rated voltage, but may be anywhere within the specified range of ΔU_s . The steady-state voltage deviation is expressed as a percentage of the rated voltage given by: $\delta U_{st} = \pm \frac{U_{st,max} - U_{st,min}}{2U_r} \times 100$
$\hat{U}_{mod,max}$	Maximum peak of voltage modulation	%	Quasi-periodic maximum voltage variation (peak-to-peak) about a steady-state voltage
$\hat{U}_{mod,min}$	Minimum peak of voltage modulation	%	Quasi-periodic minimum voltage variation (peak-to-peak) about a steady-state voltage
\hat{U}_{mod}	Voltage modulation	%	Quasi-periodic voltage variation (peak-to-peak) about a steady-state voltage having typical frequencies below the fundamental generation frequency, expressed as a percentage of average peak voltage at rated frequency and constant speed given by: $\hat{U}_{mod} = 2 \frac{\hat{U}_{mod,max} - \hat{U}_{mod,min}}{\hat{U}_{mod,max} + \hat{U}_{mod,min}} \times 100$
$\delta U_{2,0}$	Voltage unbalance	%	Ratio of the negative sequence or the zero sequence voltage components to the positive sequence voltage component at no-load. Voltage unbalance is expressed as a percentage of the rated voltage.
	Voltage regulation characteristics		Curves of terminal voltage as a function of load current at a given power factor under steady-state conditions at rated speed without any manual adjustment of the voltage regulating system.
δ_{QCC}	Grade of quadrature-current compensation voltage droop		

Table 1 (continued)

Symbol	Term	Unit	Definition
$s_{r,G}$	Rated slip of an asynchronous generator		The difference between the synchronous speed and the rated speed of the rotor referred to the synchronous speed, where the generating set is giving its rated active power and is given by: $s_{r,G} = \frac{(f_r / p) - n_{r,G}}{f_r / p}$
f_r	Rated frequency	Hz	
p	Number of pole pairs		
$n_{r,G}$	Rated speed of generator rotation	min ⁻¹	Speed of rotation necessary for voltage generation at the rated frequency. NOTE For a synchronous generator, this rotational speed is given by: $n_{r,G} = \frac{f_r}{p}$ For an asynchronous generator, this speed is given by: $n_{r,G} = \frac{f_r}{p} (1 - s_{r,G})$
S_r	Rated output (rated apparent power)	V·A	Apparent electric power at the terminals or its decimal multiples together with the power factor.
P_r	Rated active power	W	Rated apparent power multiplied by the power factor or its decimal multiples given by: $P_r = S_r \cos \varphi_r$
$\cos \varphi_r$	Rated power factor		Ratio of the rated active power to the rated apparent power given by: $\cos \varphi_r = \frac{P_r}{S_r}$
Q_r	Rated reactive power	var	Geometrical difference between the rated apparent power and the rated active power or its decimal multiples given by: $Q_r = \sqrt{S_r^2 - P_r^2}$
$t_{U,in}$	Voltage recovery time after load increase ^b	s	Time interval from the point at which a load increase is initiated until the point when the voltage returns to and remains within the specified steady-state voltage tolerance band (see Figures A.2.1 and A.2.3). This time interval applies to constant speed and depends on the power factor. If the load change differs from the rated apparent power, the value of the power change and the power factor shall be stated.

Table 1 (continued)

Symbol	Term	Unit	Definition
$t_{U,de}$	Voltage recovery time after load decrease ^b	s	Time interval from the point at which a load decrease is initiated until the point when the voltage returns to and remains within the specified steady-state voltage tolerance band (see Figure A.2.2). This time interval applies to constant speed and depends on the power factor. If the load change differs from the rated apparent power, the value of the power change and the power factor shall be stated.
I_L	Real current drawn by the load	A	
T_L	Relative thermal life expectancy factor		
^a Further details are given in Annex A.			
^b See Figure 5 of ISO 8528-5.			

4 Other requirements and additional regulations

For a.c. generators for generating sets used on board ships and offshore installations which have to comply with rules of a classification society, the additional requirements of the classification society shall be observed. The classification society name shall be stated by the customer prior to placing the order.

For a.c. generators operating in non-classed equipment, such additional requirements are subject to agreement between the manufacturer and customer.

If special requirements from any other authority (e.g. inspecting and/or legislative authorities) have to be met, the authority name shall be stated by the customer prior to placing the order.

Any further additional requirements shall be subject to agreement between the manufacturer and customer.

5 Rating

5.1 General

The generator rating class shall be specified in accordance with the requirements of IEC 60034-1. In the case of generators for RIC engine driven generating sets, the continuous rating (duty type S1) or rating with discrete constant loads (duty type S10) shall be specified.

5.2 Basic continuous rating (BR)

For the purposes of this part of ISO 8528, the maximum continuous rating based on duty type S1 is called the basic continuous rating (BR).

5.3 Peak continuous rating (PR)

For duty type S10, there is a peak continuous rating (PR), where the permissible generator temperature rises are increased by a specific amount according to the thermal classification. In the case of duty type S10, operation at the PR thermally ages the generator insulation systems at an increased rate. Factor T_L for the relative thermal life expectancy of the insulation system is therefore an important and integral part of the rating class.

6 Limits of temperature and temperature rise

6.1 Basic continuous rating

The generator shall be capable of delivering its BR over the whole range of operating conditions (e.g. minimum to maximum coolant temperatures) with total temperatures not exceeding 40 °C plus the temperature rises specified in Table 1 (see Note below) of IEC 60034-1.

6.2 Peak continuous rating

At the generator PR, the total temperatures may be increased by the amounts shown in Table 2 (see Note below):

Table 2 — Peak continuous rating temperatures

Thermal classification	Rating < 5 MV·A	Rating ≥ 5 MV·A
A or E	15 °C	10 °C
B or F	20 °C	15 °C
H	25 °C	20 °C

For ambient temperatures below 10 °C, the total temperature increase allowed shall be reduced by 1 °C for each degree Celsius by which the ambient temperature is below 10 °C.

The RIC engine output may vary with changes of ambient air temperature. The generator total temperature in operation will depend upon its primary coolant temperature, which is not necessarily related to the RIC engine inlet air temperature.

ISO 8528-3:2005

<https://standards.iteh.ai/catalog/standards/sist/2e8faa4c-f2a7-44b6-a5f6-bbb9-553b71e52632/iso-8528-3-2005>

NOTE When the generator operates at these higher temperatures, the generator insulation systems will age thermally from two to six times faster (depending on the temperature increase and the specific insulation system used) than at the generator BR temperature values; i.e. operating 1 h at PR temperature rise values is approximately equal to operating 2 h to 6 h at BR temperature rise values.

The exact value for the factor T_L shall be stated by the manufacturer and marked on the rating plate of the machine (see Clause 14).

7 Rated power and speed characteristics

Terms, symbols and definitions applicable to rated power and speed are given in Table 1.

8 Voltage characteristics

Terms, symbols and definitions applicable to voltages are given in Table 1.

9 Parallel operation

When a generator is running in parallel with other generator sets or with another source of electrical supply, means shall be provided to ensure stable operation and correct sharing of reactive power.

Stable operation is most often affected by influencing the automatic voltage regulator through a sensing circuit with an additional reactive current component. This causes a voltage droop characteristic to be present for reactive loads.