

**SLOVENSKI STANDARD**  
**SIST EN 14511-3:2013****01-december-2013****Nadomešča:****SIST EN 14511-3:2012**

---

**Klimatske naprave, enote za tekočinsko hlajenje in toplotne črpalke z električnimi kompresorji za segrevanje in hlajenje prostora - 3. del: Preskusne metode**

Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling - Part 3: Test methods

Luftkonditionierer, Flüssigkeitskühlsätze und Wärmepumpen mit elektrisch angetriebenen Verdichtern für die Raumbeheizung und -kühlung - Teil 3: Prüfverfahren  
(standards.iteh.ai)Climatiseurs, groupes refroidisseurs de liquide et pompes à chaleur avec compresseur entraîné par moteur électrique pour le chauffage et la réfrigération des locaux - Partie 3: Méthodes d'essai  
d6b875c7ec79/sist-en-14511-3-2013**Ta slovenski standard je istoveten z: EN 14511-3:2013****ICS:**

23.120	Zračniki. Vetrniki. Klimatske naprave	Ventilators. Fans. Air-conditioners
27.080	Toplotne črpalke	Heat pumps
91.140.30	Prezračevalni in klimatski sistemi	Ventilation and air-conditioning

**SIST EN 14511-3:2013****en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 14511-3:2013](#)

<https://standards.iteh.ai/catalog/standards/sist/948f7a59-3d3a-4e11-9f77-d6b875c7ec79/sist-en-14511-3-2013>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 14511-3**

July 2013

ICS 27.080; 91.140.30

Supersedes EN 14511-3:2011

English Version

**Air conditioners, liquid chilling packages and heat pumps with  
electrically driven compressors for space heating and cooling -  
Part 3: Test methods**

Climatiseurs, groupes refroidisseurs de liquide et pompes à  
chaleur avec compresseur entraîné par moteur électrique  
pour le chauffage et la réfrigération des locaux - Partie 3:  
Méthodes d'essai

Luftkonditionierer, Flüssigkeitskühlsätze und  
Wärmepumpen mit elektrisch angetriebenen Verdichtern  
für die Raumbeheizung und -kühlung - Teil 3: Prüfverfahren

This European Standard was approved by CEN on 7 June 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Contents

	Page
Foreword.....	3
<b>1 Scope .....</b>	<b>4</b>
<b>2 Normative references .....</b>	<b>4</b>
<b>3 Terms and definitions .....</b>	<b>4</b>
<b>4 Rating capacity test.....</b>	<b>4</b>
4.1 Basic principles method of calculation for the determination of capacities.....	4
4.2 Test apparatus .....	8
4.3 Uncertainties of measurement .....	10
4.4 Test procedure .....	12
4.5 Test results .....	19
<b>5 Electrical consumptions for single duct and double duct units.....</b>	<b>22</b>
5.1 Determination of power consumption due to standby mode .....	22
5.2 Determination of power consumption in off-mode .....	23
5.3 Electricity consumption .....	23
<b>6 Air flow rate measurement of ducted units.....</b>	<b>23</b>
<b>7 Heat recovery test for air-cooled multisplit systems.....</b>	<b>23</b>
7.1 Test installation.....	23
7.2 Test procedure .....	24
7.3 Test results .....	24
<b>8 Test report .....</b>	<b>24</b>
8.1 General information.....	24
8.2 Additional information .....	25
8.3 Rating test results.....	25
<b>Annex A (normative) Calorimeter test method .....</b>	<b>26</b>
<b>Annex B (normative) Indoor air enthalpy test method .....</b>	<b>35</b>
<b>Annex C (informative) Heating capacity tests - Flow chart and examples of different test sequences .....</b>	<b>36</b>
<b>Annex D (informative) Conformance criteria.....</b>	<b>42</b>
<b>Annex E (informative) Symbols used in annexes .....</b>	<b>43</b>
<b>Annex F (informative) Test at system reduced capacity.....</b>	<b>45</b>
<b>Annex G (informative) Individual unit tests .....</b>	<b>46</b>
<b>Annex H (normative) Determination of the liquid pump efficiency.....</b>	<b>48</b>
<b>Annex I (informative) Rating of indoor and outdoor units of multisplit and modular heat recovery multisplit system.....</b>	<b>51</b>
<b>Annex J (normative) Air flow rate measurement .....</b>	<b>53</b>
<b>Annex ZA (informative) Relationship between this European Standard and the requirements of Commission regulation (EC) No 206/2012 .....</b>	<b>54</b>
<b>Bibliography .....</b>	<b>55</b>

## Foreword

This document (EN 14511-3:2013) has been prepared by Technical Committee CEN/TC 113 "Heat pumps and air conditioning units", the secretariat of which is held by AENOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2014 and conflicting national standards shall be withdrawn at the latest by January 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14511-3:2011.

The main changes with respect to the previous edition are listed below:

- a) the addition of requirements related to the electrical consumption and the air flow rate measurement of ducted units;
- b) the addition of a table template containing the test results of the ducted units;
- c) the addition of two normative annexes related to indoor and outdoor units of multisplit and modular heat recovery multisplit systems and air flow rate measurement;
- d) the addition of an Annex ZA relating to the Commission Regulation (EC) n°206/2012.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

Although this document has been prepared in the frame of the commission regulation (EU) No 206/2012 implementing Directive 2009/125/EC with regard to ecodesign requirements for air conditioners and comfort fans, it is also intended to support the essential requirements of the European Directive 2010/30/CE.

EN 14511 comprises the following parts under the general title *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling*:

- *Part 1: Terms, definitions and classification,*
- *Part 2: Test conditions,*
- *Part 3: Test methods,*
- *Part 4: Operating requirements, marking and instructions.*

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**EN 14511-3:2013 (E)****1 Scope**

1.1 The scope of EN 14511-1 is applicable.

1.2 This European Standard specifies the test methods for the rating and performance of air conditioners, liquid chilling packages and heat pumps using either air, water or brine as heat transfer media, with electrically driven compressors when used for space heating and cooling.

It also specifies the method of testing and reporting for heat recovery capacities, system reduced capacities and the capacity of individual indoor units of multisplit systems, where applicable.

This European Standard also makes possible to rate multisplit and modular heat recovery multisplit systems by rating separately the indoor and outdoor units.

**2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14511-1:2013, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 1: Terms, definitions and classification*

EN 14511-2:2013, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 2: Test conditions*

**3 Terms and definitions**

For the purposes of this document, the terms and definitions given in EN 14511-1:2013 apply.

**4 Rating capacity test****4.1 Basic principles method of calculation for the determination of capacities****4.1.1 Heating capacity**

The heating capacity of air conditioners and of air-to-air or water-to-air heat pumps shall be determined by measurements in a calorimeter room (see Annex A) or by the air enthalpy method (see Annex B).

However, the heating capacity of air conditioners and of air-to-air heat pumps having a cooling capacity below or equal to 12 kW shall be determined by measurements in a calorimeter room.

The heating capacity of air-to-water, water-to-water heat pumps and liquid chilling packages shall be determined in accordance with the direct method at the water or brine heat exchanger, by determination of the volume flow of the heat transfer medium, and the inlet and outlet temperatures, taking into consideration the specific heat capacity and density of the heat transfer medium.

For steady state operation, the heating capacity shall be determined using the following formula:

$$P_H = q \times \rho \times c_p \times \Delta t \quad (1)$$

where

- $P_H$  is the heat capacity, expressed in Watts;
- $q$  is the volume flow rate, expressed in cubic metres per second;
- $\rho$  is the density, expressed in kilograms per cubic metre;
- $c_p$  is the specific heat at constant pressure, expressed in joules per kilogram and Kelvin;
- $\Delta t$  is the difference between inlet and outlet temperatures, expressed in Kelvin.

NOTE 1 The mass flow rate can be determined directly instead of the term ( $q \times \rho$ ).

NOTE 2 The enthalpy change  $\Delta H$  can be directly measured instead of the term ( $c_p \times \Delta t$ ).

For the heating capacity calculation in transient operation, refer to 4.5.3.2.

The heating capacity shall be corrected for the heat from the fan or pump:

- if the fan or pump at the indoor heat exchanger is an integral part of the unit, the same power (calculated in 4.1.5.2 or 4.1.6.3) which is excluded from the total power input shall be also subtracted from the heating capacity;
- if the fan or pump at the indoor heat exchanger is not an integral part of the unit, the same power (calculated in 4.1.5.3 or 4.1.6.4) which is included in the effective power input shall be also added to the heating capacity.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

### 4.1.2 Cooling capacity

The cooling capacity of air conditioners and of air-to-air or water-to-air heat pumps shall be determined by measurements in a calorimeter room (see Annex A) or by the air enthalpy method (see Annex B).

However, the cooling capacity of air conditioners and of air-to-air heat pumps having a cooling capacity below or equal to 12 kW shall be determined by measurements in a calorimeter room.

The cooling capacity of air-to-water, water-to-water heat pumps and liquid chilling packages shall be determined in accordance with the direct method at the water or brine heat exchanger, by determination of the volume flow of the heat transfer medium, and the inlet and outlet temperatures, taking into consideration the specific heat capacity and density of the heat transfer medium.

The cooling capacity shall be determined using the following formula:

$$P_C = q \times \rho \times c_p \times \Delta t \quad (2)$$

where

- $P_C$  is the cooling capacity, expressed in watts;
- $q$  is the volume flow rate, expressed in cubic metres per second;
- $\rho$  is the density, expressed in kilograms per cubic metre;
- $c_p$  is the specific heat at constant pressure, expressed in joules per kilogram and Kelvin;
- $\Delta t$  is the difference between inlet and outlet temperatures, expressed in Kelvin.

NOTE 1 The mass flow rate can be determined directly instead of the term ( $q \times \rho$ ).

NOTE 2 The enthalpy change  $\Delta H$  can be directly measured instead of the term ( $c_p \times \Delta t$ ).

**EN 14511-3:2013 (E)**

The cooling capacity shall be corrected for the heat from the fan or pump:

- a) If the fan or pump at the evaporator is an integral part of the unit, the same power (calculated in 4.1.5.2 or 4.1.6.3) which is excluded from the total power input is also added to the cooling capacity.
- b) If the fan or pump at the evaporator is not an integral part of the unit, the same power (calculated in 4.1.5.3 or 4.1.6.4) which is included in the effective power input is also subtracted from the cooling capacity.

**4.1.3 Heat recovery capacity**

The heat recovery capacity of air-to-water and water-to-water heat pumps and liquid chilling packages shall be determined in accordance with the direct method at the water or brine heat exchanger, by determination of the volume flow of the heat transfer medium, and the inlet and outlet temperatures, taking into consideration the specific heat capacity and density of the heat transfer medium.

The heat recovery capacity shall be determined using the following formula:

$$P_{HR} = q \times \rho \times c_p \times \Delta t \quad (3)$$

where

$P_{HR}$  is the heat recovery capacity, expressed in Watts;

$q$  is the volume flow rate, expressed in cubic metres per second;

$\rho$  is the density, expressed in kilograms per cubic metre;

$c_p$  is the specific heat at constant pressure, expressed in joules per kilogram and Kelvin;

$\Delta t$  is the difference between inlet and outlet temperatures expressed in Kelvin;

NOTE The mass flow rate can be determined directly instead of the term ( $q \times \rho$ ). The enthalpy change  $\Delta H$  can be directly measured instead of the term ( $c_p \times \Delta t$ ).

The heat recovery capacity shall be corrected for the heat of the pump:

- a) if the pump at the heat recovery exchanger is an integral part of the unit, the power calculated according to 4.1.6.3 shall be subtracted from heat recovery capacity
- b) if the pump at the heat recovery exchanger is not an integral part of the unit, the power calculated according to 4.1.6.4 shall be added to the heat recovery capacity.

**4.1.4 Power input of fans for units without duct connection**

In the case of units which are not designed for duct connection, i.e. which do not permit any external pressure differences, and which are equipped with an integral fan, the power absorbed by the fan shall be included in the effective power absorbed by the unit.

**4.1.5 Power input of fans for units with duct connection**

**4.1.5.1** The following corrections of the power input of fans shall be made to both indoor and outdoor fans, where applicable.

**4.1.5.2** If a fan is an integral part of the unit, only a fraction of the input of the fan motor shall be included in the effective power absorbed by the unit. The fraction that is to be excluded from the total power absorbed by the unit shall be calculated using the following formula:



$$\frac{q \cdot (\Delta p_e - ESP_{\min})}{\eta} \quad (4)$$

where

$\eta$  is equal to  $\eta_{\text{target}}$ ; as declared by the fan manufacturer according to the ecodesign regulation n°327/2011 for fans driven by motors between 125 W and 500 kW.

$\eta$  is 0.3 by convention, for fans driven by motors below 125 W.

$\Delta p_e$  is the measured available external static pressure difference, expressed in Pascal, as defined in 2.52 of EN 14511-1:2013.

$ESP_{\min}$  is the minimum external static pressure difference specified in Table 2 or Table 3, as applicable for an indoor unit, or 30 Pa for an outdoor unit.

$q$  is the nominal air flow rate, expressed in cubic meters per second.

**4.1.5.3** If no fan is provided with the unit, the proportional power input which is to be included in the effective power absorbed by the unit, shall be calculated using the following formula:

(5)

$$\frac{-q \cdot (\Delta p_i) + ESP_{\min}}{\eta}$$

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

where

$\eta$  is 0,3 by convention.

$\Delta p_i$  is the measured internal static pressure difference, expressed in Pascal, as defined in 2.53 of EN 14511-1:2013.

$ESP_{\min}$  is the minimum external static pressure difference given in Table 2 or Table 3, as applicable for an indoor unit, or 30 Pa for an outdoor unit.

$q$  is the nominal air flow rate, expressed in cubic meters per second.

#### 4.1.6 Power input of liquid pumps

**4.1.6.1** The following corrections of the power input of liquid pumps shall be made to both indoor and outdoor (and heat recovery) liquid pumps, where applicable.

**4.1.6.2** When the liquid pump is integrated into the unit, it shall be connected for operation. When the liquid pump is delivered by the manufacturer apart from the unit, it shall be connected for operation according to the manufacturer's instructions and be then considered as an integral part of the unit.

**4.1.6.3** If a liquid pump is an integral part of the unit, only a fraction of the input to the pump motor shall be included in the effective power absorbed by the unit. The fraction which is to be excluded from the total power absorbed by the unit shall be calculated using the following formula:

$$\frac{q \times \Delta p_e}{\eta} \quad (6)$$

where

$\eta$  is the efficiency of the pump calculated according to Annex H;

**EN 14511-3:2013 (E)**

$\Delta p_e$  is the measured available external static pressure difference, expressed in Pascal, as defined in 2.52 of EN 14511-1:2013;

$q$  is the nominal liquid flow rate, expressed in cubic meters per second.

**4.1.6.4** If no liquid pump is provided with the unit, the proportional power input which is to be included in the effective power absorbed by the unit, shall be calculated using the following formula:

$$\frac{q \times (-\Delta p_i)}{\eta} \quad (7)$$

where

$\eta$  is the efficiency of the pump calculated according to Annex H.

$\Delta p_i$  is the measured internal static pressure difference, expressed in Pascal, as defined in 2.53 of EN 14511-1:2013.

$q$  is the nominal liquid flow rate, expressed in cubic meters per second.

**4.1.6.5** In the case of appliances designed especially to operate on a distributing network of pressurised water without water-pump, no correction is to be applied to the power input.

**4.1.7 Units for use with remote condenser**

The power from the auxiliary liquid pump of the remote condenser shall not be taken into account in the effective power input.

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

**4.2 Test apparatus**

[SIST EN 14511-3:2013](https://standards.iteh.ai/catalog/standards/sist/948f7a59-3d3a-4e11-9f77-6b875c7ec79/sist-en-14511-3-2013)

[https://standards.iteh.ai/catalog/standards/sist/948f7a59-3d3a-4e11-9f77-](https://standards.iteh.ai/catalog/standards/sist/948f7a59-3d3a-4e11-9f77-6b875c7ec79/sist-en-14511-3-2013)

**4.2.1 Arrangement of the test apparatus****4.2.1.1 General requirements**

The test apparatus shall be designed in such a way that all requirements on adjustment of set values, stability criteria and uncertainties of measurement according to this European Standard can be fulfilled.

**4.2.1.2 Test room for the air side**

The size of the test room shall be selected such that any resistance to air flow at the air inlet and air outlet orifices of the test object is avoided. The air flow through the room shall not be capable of initiating any short circuit between these two orifices, and therefore the velocity of the air flows through the room at these two locations shall not exceed 1,5 m/s when the test object is switched off. The air velocity in the room shall also not be greater than the mean velocity through the unit inlet. Unless otherwise stated by the manufacturer, the air inlet or air outlet orifices shall be not less than 1 m distant from the surfaces of the test room.

Any direct heat radiation by heating units in the test room onto the unit or onto the temperature measuring points shall be avoided.

**4.2.1.3 Appliances with duct connection**

The connections of a ducted air unit to the test facility shall be sufficiently air tight to ensure that the measured results are not significantly influenced by exchange of air with the surroundings.

#### 4.2.1.4 Appliances with integral pumps

For appliances with integral and adjustable water or brine pumps, the external static pressure shall be set at the same time as the temperature difference.

When the liquid pump has one or several fixed speeds, the speed of the pump shall be set in order to provide the minimum external static pressure.

In case of variable speed liquid pump, the manufacturer shall provide information to set the pump in order to reach a maximal external static pressure of 10 kPa.

#### 4.2.1.5 Liquid chilling package for use with remote condenser

Units for use with remote condenser are tested by using a water-cooled condenser, the characteristics of which shall enable the intended operating conditions to be achieved.

### 4.2.2 Installation and connection of the test object

#### 4.2.2.1 General

The test object shall be installed and connected for the test as recommended by the manufacturer in the installation and operation manual. The accessories provided by option are not included in the test. If a back-up heater is provided in option or not, it shall be switched off or disconnected to be excluded from the testing.

For single ducts, regardless of the manufacturer's instructions, the discharge duct shall be as short and straight as possible compatibly with minimum distance between the unit and the wall for correct air inlet but not less than 50 cm. No accessory shall be connected to the discharge end of the duct.

For double duct units, the same requirements apply to both suction and discharge ducts, unless the appliance is designed to be installed directly on the wall. For multisplit systems, the test shall be performed with the system operating at a capacity ratio of 1, or as close as possible.

When performing measures in heating mode, set the highest room temperature on the unit/system control device; when performing measures in cooling mode, set the lowest room temperature on the unit/system control device. If in the instructions, the manufacturer indicates a value for the temperature set on the control device for a given rating condition, then this value shall be used.

For unit with open-type compressor the electric motor shall be supplied or specified by the manufacturer. The compressor shall be operated at the rotational speed specified by the manufacturer.

For inverter type control units, the setting of the frequency shall be done for each rating condition. The manufacturer shall provide in the documentation information about how to obtain the necessary data to set the required frequencies.

If a skilled personnel with knowledge of control software is required for the start of the system, the manufacturer or the nominated agent should be in attendance when the system is being installed and prepared for tests.

#### 4.2.2.2 Installation of unit consisting of several parts

In the case of a unit consisting of several parts, the following installation conditions shall be complied for the test.

- a) The refrigerant lines shall be installed in accordance with the manufacturer's instructions. The length of the lines shall be 5 m except if the constraints of the test installation make 5 m not possible, in which case a greater length may be used, with a maximum of 7,5 m.

**EN 14511-3:2013 (E)**

- b) The lines shall be installed so that the difference in elevation does not exceed 2,5 m.
- c) The thermal insulation of the lines shall be applied in accordance with the manufacturer's instructions.
- d) Unless constrained by the design, at least half of the connecting lines shall be exposed to the outside conditions, with the rest of the lines exposed to the inside conditions.

**4.2.2.3 Indoor units of multisplit systems**

When testing a multisplit system in a calorimeter room, the air flow rate and the external static pressure shall be adjusted separately for each one of the ducted indoor units.

When testing a multisplit system using the air enthalpy method, the air flow rate and the external static pressure shall be adjusted separately for each indoor unit, ducted or not.

In case of equipment with non ducted indoor units tested using the air enthalpy method, the above requirement on ducted indoor units shall apply.

**4.2.2.4 Measuring points**

Temperature and pressure measuring points shall be arranged in order to obtain mean significant values.

For free air intake temperature measurements, it is required:

- either to have at least one sensor per square meter, with not less than four measuring points and by restricting to 20 the number of sensors equally distributed on the free air surface;
- or to use a sampling device. It shall be completed by four sensors for checking uniformity if the surface area is greater than 1 m<sup>2</sup>.

Air temperature sensors shall be placed at a maximum distance of 0,25 m from the free air surface.

For control cabinet air conditioners, the inlet temperature at the evaporator is measured instead of the temperature inside the control cabinet.

For units consisting of a heat pump and a storage tank as a factory made unit, water inlet and outlet temperature measurements shall be taken at the inlet and outlet of this unit.

For water and brine, the density in formulae (1), (2) and (3) shall be determined in the temperature conditions measured near the volume flow measuring device.

**4.3 Uncertainties of measurement**

The uncertainties of measurement shall not exceed the values specified in Table 1.

Table 1 — Uncertainties of measurement for indicated values

Measured quantity	Unit	Uncertainty of measurement
<b>Liquid</b>		
- temperature difference	K	$\pm 0,15$ K
- temperature inlet/outlet	K	$\pm 0,15$ K
- volume flow	m <sup>3</sup> /s	$\pm 1$ %
- static pressure difference	kPa	$\pm 1$ kPa ( $\Delta p \leq 20$ kPa) or $\pm 5$ % ( $\Delta p > 20$ kPa)
<b>Air</b>		
- dry bulb temperature	°C	$\pm 0,2$ K
- wet bulb temperature	°C	$\pm 0,4$ K
- volume flow	m <sup>3</sup> /s	$\pm 5$ %
- static pressure difference	Pa	$\pm 5$ Pa ( $\Delta p \leq 100$ Pa) or $\pm 5$ % ( $\Delta p > 100$ Pa)
<b>Refrigerant</b>		
- pressure at compressor outlet	kPa	$\pm 1$ %
- temperature	°C	$\pm 0,5$ K
<b>Concentration</b>		
- Heat transfer medium	%	$\pm 2$
<b>Electrical quantities</b>		
- electric power	W	$\pm 1$ %
- voltage	V	$\pm 0,5$ %
- current	A	$\pm 0,5$ %
- electrical energy	kWh	$\pm 1$ %
<b>Compressor rotational speed</b>	min <sup>-1</sup>	$\pm 0,5$ %

The heating or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.

The steady state heating or cooling capacities determined using the calorimeter method shall be determined with a maximum uncertainty of 5 %, independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids; this maximum uncertainty is extended to 10 % for single duct units due to the air exchange between the two compartments of the calorimeter room.

Heating capacity determined during transient operation (defrost cycles) using the calorimeter method shall be determined with a maximum uncertainty of 10 %, independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.

The heating and cooling capacities measured on the air side using the air enthalpy method shall be determined with a maximum uncertainty of 10 %, independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.

**EN 14511-3:2013 (E)****4.4 Test procedure****4.4.1 General****4.4.1.1 All units**

The test conditions are given in EN 14511-2.

If liquid heat transfer media other than water are used, the specific heat capacity and density of such heat transfer media shall be determined and taken into consideration in the evaluation.

Table 4 states permissible deviations of the measured values from the test conditions.

**4.4.1.2 Non ducted units**

For non-ducted units, the adjustable settings such as louvers and fan speed shall be set for maximum steady-state air flow.

For inverter type control units, if the manufacturer indicates a speed of the fan different from the maximum one to set on the control device for a given rating condition, then this speed shall be used.

**4.4.1.3 Units ducted on the indoor heat exchanger**

The volume flow and the external static pressure, as specified by the manufacturer for the cooling mode (or heating mode if no cooling mode of the unit), shall be related to standard air and with dry heat exchanger.

The volume flow and the pressure difference shall be related to standard air and with dry heat exchanger.

If the airflow rate is given by the manufacturer with no atmospheric pressure, temperature and humidity conditions, it shall be considered as given for standard air conditions.

The airflow rate given by the manufacturer shall be converted into standard air conditions.

$$q_{vi} = \frac{q_{vi \text{ measured}} \rho_{i \text{ measured}}}{1,204} \quad (8)$$

The setting of this airflow rate shall be made when the fan only is operating.

The rated air flow rate given by the manufacturer converted into standard air conditions if necessary shall be set and the resulting ESP measured. This ESP shall also be converted into standard air conditions as follows:

$$\Delta p_e = \frac{\Delta p_{e \text{ measured}} \rho_{i \text{ measured}}^2}{1,204^2} \quad (9)$$

If the ESP is lower than the minimum value given in Table 2 (or Table 3), the air flow rate is decreased to reach this minimum value.

If the ESP is greater than twice the minimum value given in Table 2 (or Table 3), the air low rate is increased to reach twice this minimum value.

If the ESP is greater than the minimum value given in Table 2 (or Table 3) but not greater than twice this minimum value, then keep this ESP.

The apparatus used for setting the ESP shall be maintained in the same position during all the tests.

**Table 2 — Pressure requirement for comfort air conditioners**

Standard capacity ratings kW	Minimum external static pressure (ESP <sub>min</sub> ) <sup>a b</sup> Pa
$0 < Q < 8$	25
$8 \leq Q < 12$	37
$12 \leq Q < 20$	50
$20 \leq Q < 30$	62
$30 \leq Q < 45$	75
$45 \leq Q < 82$	100
$82 \leq Q < 117$	125
$117 \leq Q < 147$	150
$Q \geq 147$	175

<sup>a</sup> For equipment tested without an air filter installed, the minimum external static pressure shall be increased by 10 Pa.

<sup>b</sup> If the manufacturer's installation instructions state that the maximum allowable discharge duct length is less than 1m, then the unit can be considered as a free delivery unit and be tested as a non ducted indoor unit with an ESP of 0 Pa.

(standards.iteh.ai)

**Table 3 — Pressure requirement for close control air conditioners**

Capacity kW	Minimum external static Pressure (ESP <sub>min</sub> ) Pa	
	For down-flow discharge into double floor	For up-flow discharge into duct all units
< 30	50	-
≥ 30	75	-
All	-	50

**4.4.1.4 Units ducted on the outdoor heat exchanger**

The volume flow and the pressure difference shall be related to standard air and with dry heat exchanger.

If the air flow rate is given by the manufacturer with no atmospheric pressure, temperature and humidity conditions, it shall be considered as given for standard air conditions.

The air flow rate given by the manufacturer shall be converted into standard air conditions. The air flow rate setting shall be made when the fan only is operating.

The rated air flow rate given by the manufacturer shall be set and the resulting external static pressure (ESP) measured.

If the ESP is lower than 30 Pa, the air flow rate is decrease to reach this minimum value.