



SLOVENSKI STANDARD SIST EN ISO 16890-4:2017

01-marec-2017

Nadomešča:
SIST EN 779:2012

Zračni filtri pri splošnem prezračevanju - 4. del: Metoda kondicioniranja za ugotavljanje minimalne frakcijske učinkovitosti (ISO 16890-4:2016)

Air filters for general ventilation - Part 4: Conditioning method to determine the minimum fractional test efficiency (ISO 16890-4:2016)

Luftfilter für die allgemeine Raumlufttechnik - Teil 4: Konditionierungsverfahren für die Ermittlung des Fraktionsabscheidegradminimums (ISO 16890-4:2016)

Filtres à air pour ventilation générale - Partie 4: Méthode de conditionnement pour déterminer le rendement fractionnaire minimal d'essai (ISO 16890-4:2016)

Ta slovenski standard je istoveten z: EN ISO 16890-4:2016

ICS:

91.140.30	Prezračevalni in klimatski sistemi	Ventilation and air-conditioning systems
-----------	------------------------------------	--

SIST EN ISO 16890-4:2017

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16890-4:2017](https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017)

<https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN ISO 16890-4

December 2016

ICS 91.140.30

Supersedes EN 779:2012

English Version

**Air filters for general ventilation - Part 4: Conditioning
method to determine the minimum fractional test
efficiency (ISO 16890-4:2016)**

Filtres à air de ventilation générale - Partie 4: Méthode
de conditionnement afin de déterminer l'efficacité
spectrale minimum d'essai (ISO 16890-4:2016)

Luftfilter für die allgemeine Raumlufttechnik - Teil 4:
Konditionierungsverfahren für die Ermittlung des
Fraktionsabscheidegradminimums (ISO 16890-4:2016)

This European Standard was approved by CEN on 19 September 2016.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

iTeh STANDARD PREVIEW

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	3

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16890-4:2017](https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017)
<https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>

European foreword

This document (EN ISO 16890-4:2016) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 "Air filters for general air cleaning" the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2017, and conflicting national standards shall be withdrawn at the latest by June 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 779:2012.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

SIST EN ISO 16890-4:2017

<https://standards.iteh.ai/catalog/standards/sist/86b028-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>

Endorsement notice

The text of ISO 16890-4:2016 has been approved by CEN as EN ISO 16890-4:2016 without any modification.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16890-4:2017

<https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>

INTERNATIONAL STANDARD

**ISO
16890-4**

First edition
2016-12-01

Air filters for general ventilation — Part 4: Conditioning method to determine the minimum fractional test efficiency

Filtres à air de ventilation générale —

*Partie 4: Méthode de conditionnement afin de déterminer l'efficacité
spectrale minimum d'essai*

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

SIST EN ISO 16890-4:2017

<https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>



Reference number
ISO 16890-4:2016(E)

© ISO 2016

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN ISO 16890-4:2017

<https://standards.iteh.ai/catalog/standards/sist/c86bc988-e76b-4f7f-94bf-c2b657e8420f/sist-en-iso-16890-4-2017>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	2
5 General conditioning test requirements	2
5.1 General.....	2
5.2 Test device requirements.....	2
5.3 Test device selection.....	2
5.4 Conditioning cabinet requirements.....	3
6 Conditioning materials	3
7 Conditioning cabinet	4
7.1 General.....	4
7.2 Conditioning cabinet dimensions and construction materials.....	4
7.3 Environment, temperature and relative humidity.....	5
8 Safety issues	6
9 Test method	6
9.1 General.....	6
9.2 Conditioning procedure.....	7
10 Qualification	7
11 Reporting results	8
Annex A (informative) Hints for health and safety aspects for the use of IPA	9
Bibliography	11

ISO 16890-4:2016(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 142, *Cleaning equipment for air and other gases*.

This first edition of ISO 16890-4, together with ISO 16890-1, ISO 16890-2 and ISO 16890-3, cancels and replaces ISO/TS 21220:2009, which has been technically revised.

ISO 16890 consists of the following parts, under the general title *Air filters for general ventilation*:

- *Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)*
- *Part 2: Measurement of fractional efficiency and air flow resistance*
- *Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured*
- *Part 4: Conditioning method to determine the minimum fractional test efficiency*

Introduction

The effects of particulate matter (PM) on human health have been extensively studied in the past decades. The results are that fine dust can be a serious health hazard, contributing to or even causing respiratory and cardiovascular diseases. Different classes of particulate matter can be defined according to the particle size range. The most important ones are PM₁₀, PM_{2,5} and PM₁. The U.S. Environmental Protection Agency (EPA), the World Health Organization (WHO) and the European Union define PM₁₀ as particulate matter which passes through a size-selective inlet with a 50 % efficiency cut-off at 10 µm aerodynamic diameter. PM_{2,5} and PM₁ are similarly defined. However, this definition is not precise if there is no further characterization of the sampling method and the sampling inlet with a clearly defined separation curve. In Europe, the reference method for the sampling and measurement of PM₁₀ is described in EN 12341. The measurement principle is based on the collection on a filter of the PM₁₀ fraction of ambient particulate matter and the gravimetric mass determination (see EU Council Directive 1999/30/EC of 22 April 1999).

As the precise definition of PM₁₀, PM_{2,5} and PM₁ is quite complex and not simple to measure, public authorities, like the U.S. EPA or the German Federal Environmental Agency (Umweltbundesamt), increasingly use in their publications the more simple denotation of PM₁₀ as being the particle size fraction less or equal to 10 µm. Since this deviation to the above mentioned complex “official” definition does not have a significant impact on a filter element’s particle removal efficiency, the ISO 16890 series refers to this simplified definition of PM₁₀, PM_{2,5} and PM₁.

Particulate matter in the context of the ISO 16890 series describes a size fraction of the natural aerosol (liquid and solid particles) suspended in ambient air. The symbol ePM_x describes the efficiency of an air cleaning device to particles with an optical diameter between 0,3 µm and x µm. The following particle size ranges are used in the ISO 16890 series for the listed efficiency values.

Table 1 — Optical particle diameter size ranges for the definition of the efficiencies, ePM_x

<https://standards.iteh.ai/standards/sist/c861773-47594bf-c2b65758420f/sist-en-iso-16890-4-2017>

Efficiency	Size range, µm
ePM_{10}	$0,3 \leq x \leq 10$
$ePM_{2,5}$	$0,3 \leq x \leq 2,5$
ePM_1	$0,3 \leq x \leq 1$

Air filters for general ventilation are widely used in heating, ventilation and air-conditioning applications of buildings. In this application, air filters significantly influence the indoor air quality and, hence, the health of people, by reducing the concentration of particulate matter. To enable design engineers and maintenance personnel to choose the correct filter types, there is an interest from international trade and manufacturing for a well-defined, common method of testing and classifying air filters according to their particle efficiencies, especially with respect to the removal of particulate matter. Current regional standards are applying totally different testing and classification methods, which do not allow any comparison with each other, and thus hinder global trade with common products. Additionally, the current industry standards have known limitations by generating results which often are far away from filter performance in service, i.e. overstating the particle removal efficiency of many products. With this new ISO 16890 series, a completely new approach for a classification system is adopted, which gives better and more meaningful results compared to the existing standards.

The ISO 16890 series describes the equipment, materials, technical specifications, requirements, qualifications and procedures to produce the laboratory performance data and efficiency classification based upon the measured fractional efficiency converted into a particulate matter efficiency (ePM) reporting system.

Air filter elements according to the ISO 16890 series are evaluated in the laboratory by their ability to remove aerosol particulate expressed as the efficiency values ePM_1 , $ePM_{2,5}$ and ePM_{10} . The air filter elements can then be classified according to the procedures defined in ISO 16890-1. The particulate removal efficiency of the filter element is measured as a function of the particle size in the range of 0,3 µm to 10 µm of the unloaded and unconditioned filter element as per the procedures defined in ISO 16890-2. After the initial particulate removal efficiency testing, the air filter element is conditioned