



SLOVENSKI STANDARD SIST-TS ISO/TS 20100:2020

01-junij-2020

Plinasti vodik - Polnilne postaje

Gaseous hydrogen - Fuelling stations

Carburant d'hydrogène gazeux - Stations-service

Ta slovenski standard je istoveten z: **ISO/TS 20100:2008**

[SIST-TS ISO/TS 20100:2020](https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020)

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

ICS:

27.075	Tehnologija vodika	Hydrogen technologies
71.100.20	Industrijski plini	Gases for industrial application

SIST-TS ISO/TS 20100:2020

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST-TS ISO/TS 20100:2020

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

TECHNICAL
SPECIFICATION

ISO/TS
20100

First edition
2008-12-01

Gaseous hydrogen — Fuelling stations

Carburant d'hydrogène gazeux — Stations-service

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TS ISO/TS 20100:2020
https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-
632d2f966614/sist-ts-iso-ts-20100-2020](https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020)



Reference number
ISO/TS 20100:2008(E)

© ISO 2008

ISO/TS 20100:2008(E)

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST-TS ISO/TS 20100:2020](https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020)

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	v
1 Scope	1
2 Normative references	2
3 Terms and definitions	3
4 General design requirements	7
5 Hydrogen delivery systems	8
5.1 General	8
5.2 Gaseous hydrogen supply by tube trailers and multi cylinder packs	8
5.3 Liquid hydrogen supply	9
5.4 Pipeline	13
6 On-site generation	13
6.1 Hydrogen generators using water electrolysis process	13
6.2 Hydrogen generators using fuel processing technologies	13
6.3 Shutdown control	13
7 Hydrogen compressors	14
7.1 General	14
7.2 Vibration and movement	14
7.3 Compressor enclosure ventilation	14
7.4 Attachment to other buildings	14
7.5 Enclosure access doors	14
7.6 Control and monitoring	14
8 Filters and separators	15
9 Hydrogen purifier	15
10 Gaseous hydrogen buffer storage tanks	16
11 Dispenser, fuelling assembly, and process control	16
11.1 Location and protection of dispensers	16
11.2 Fuelling position	16
11.3 Dispenser system design	17
11.4 Fuelling hose assembly	18
11.5 Hose breakaway device	20
11.6 Fuelling connector	21
11.7 Fuelling process control	22
11.8 Dispenser safety devices	22
11.9 Safety notices at fuelling point	24
12 Hydrogen fuel specifications	25
13 Layout	25
13.1 General	25
13.2 Safety distances	25
14 Fire and explosion hazard protection requirements	30
14.1 General requirements	30
14.2 Area classification	30
14.3 Protection requirements for equipment within classified areas	30
14.4 Prevention of the accumulation of ignitable mixtures indoors and in enclosures	30
14.5 Ventilation specification	31
14.6 Start-up purge	32

ISO/TS 20100:2008(E)

14.7	Areas adjacent to hazardous areas.....	32
14.8	Hydrogen detection systems.....	32
14.9	Safety of personnel.....	33
15	Hydrogen storage siting requirements.....	33
15.1	Ground storage.....	33
15.2	Below-ground vaults.....	33
15.3	Fuelling station canopy-top storage.....	34
15.4	Roof-top installation of gaseous hydrogen systems.....	35
16	General equipment requirements.....	36
16.1	Materials.....	36
16.2	Piping carrying gaseous hydrogen.....	37
16.3	Pressure relief devices for gaseous hydrogen systems.....	37
16.4	Protection from the accumulation of static charges.....	38
16.5	Equipment grounding and bonding.....	38
16.6	Valves for gaseous hydrogen.....	38
16.7	Instruments and cabinets.....	39
17	Gaseous hydrogen vent systems.....	39
18	Instrumentation control and safety systems.....	39
18.1	General.....	39
18.2	Master system.....	40
18.3	Alarms.....	40
18.4	Pneumatics.....	41
18.5	Safety systems.....	41
18.6	Instrumentation.....	41
18.7	Safety functions control.....	41
19	Electrical systems (electrical equipment and wiring).....	42
19.1	General requirements.....	42
19.2	Power supply.....	42
19.3	Electromagnetic compatibility and interference (EMC).....	42
20	Safety systems.....	42
20.1	Emergency principles and operations.....	42
20.2	Fire detection systems.....	43
20.3	Safety and emergency shut-off systems.....	43
20.4	Emergency release of gas from gaseous hydrogen buffer storage tanks.....	43
20.5	Fire-fighting systems.....	43
21	Protection from external effects.....	44
21.1	General principles.....	44
21.2	Lightning protection.....	44
21.3	Protection from environmental conditions.....	44
22	Tests.....	44
22.1	Pressure test.....	44
22.2	Leak test.....	45
22.3	Testing of electrotechnical control/safety/emergency systems and components.....	45
	Bibliography.....	46

iTech STANDARD PREVIEW
(standards.iteh.ai)

SIST-TS-ISO/TS-20100:2020
<https://standards.iteh.ai/catalog/standards/sist/632d2f966614/sist-ts-iso-ts-20100-2020>
 632d2f966614/sist-ts-iso-ts-20100-2020

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

In other circumstances, particularly when there is an urgent market requirement for such documents, a technical committee may decide to publish other types of document:

- an ISO Publicly Available Specification (ISO/PAS) represents an agreement between technical experts in an ISO working group and is accepted for publication if it is approved by more than 50 % of the members of the parent committee casting a vote.
- an ISO Technical Specification (ISO/TS) represents an agreement between the members of a technical committee and is accepted for publication if it is approved by 2/3 of the members of the committee casting a vote.

An ISO/PAS or ISO/TS is reviewed after three years in order to decide whether it will be confirmed for a further three years, revised to become an International Standard, or withdrawn. If the ISO/PAS or ISO/TS is confirmed, it is reviewed again after a further three years, at which time it must either be transformed into an International Standard or be withdrawn.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO/TS 20100 was prepared by Technical Committee ISO/TC 197, *Hydrogen technologies*.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST-TS ISO/TS 20100:2020

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

Gaseous hydrogen — Fuelling stations

1 Scope

This Technical Specification specifies the characteristics of outdoor public and non-public fuelling stations that dispense gaseous hydrogen used as fuel onboard land vehicles of all types.

Residential and home applications to fuel land vehicles are excluded from this Technical Specification.

The fuelling station may comprise, as applicable, the following as shown in Figure 1:

- Delivery of hydrogen by pipeline, trucked-in gaseous and/or liquid hydrogen;
- On-site hydrogen generators using water electrolysis process or hydrogen generators using fuel processing technologies;
- Liquid hydrogen storage, pumping and vaporizing systems;
- Gaseous hydrogen compression and purification systems;

NOTE When the fuelling station comprises an on-site hydrogen generator, the compressor/purifier system is commonly integrated into it.

- Gaseous hydrogen buffer storage;

- Gaseous hydrogen dispensers.




Figure 1 — Gaseous hydrogen — Fuelling station

ISO/TS 20100:2008(E)

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4126-1, *Safety devices for protection against excessive pressure — Part 1: Safety valves*

ISO 4126-2, *Safety devices for protection against excessive pressure — Part 2: Bursting disc safety devices*

ISO 4414, *Pneumatic fluid power — General rules relating to systems*

ISO 7751, *Rubber and plastics hoses and hose assemblies — Ratios of proof and burst pressure to design working pressure*

ISO 14113, *Gas welding equipment — Rubber and plastic hoses assembled for compressed or liquefied gases up to a maximum design pressure of 450 bar*

ISO 14687 (all parts), *Hydrogen fuel — Product specification*

ISO 15649, *Petroleum and natural gas industries — Piping*

ISO 16110-1, *Hydrogen generators using fuel processing technologies — Part 1: Safety*

ISO 16528-1, *Boilers and pressure vessels — Part 1: Performance requirements*

ISO 17268, *Compressed hydrogen surface vehicle refuelling connection devices*

ISO 21009-1, *Cryogenic vessels — Static vacuum-insulated vessels — Part 1: Design, fabrication, inspection and tests*

ISO 21011, *Cryogenic vessels — Valves for cryogenic service*

ISO 21012, *Cryogenic vessels — Hoses*

ISO 21013-1, *Cryogenic vessels — Pressure-relief accessories for cryogenic service — Part 1: Reclosable pressure-relief valves*

ISO 21013-2, *Cryogenic vessels — Pressure-relief accessories for cryogenic service — Part 2: Non-reclosable pressure-relief devices*

ISO 21013-3, *Cryogenic vessels — Pressure-relief accessories for cryogenic service — Part 3: Sizing and capacity determination*

ISO 22734-1, *Hydrogen generators using water electrolysis process — Part 1: Industrial and commercial applications*

IEC 60079-0, *Explosive atmospheres — Part 0: Equipment — General requirements*

IEC 60079-10, *Electrical apparatus for explosive gas atmospheres — Part 10: Classification of hazardous areas*

IEC 60079-14, *Explosive atmospheres — Part 14: Electrical installations design, selection and erection*

IEC 60079-29-1, *Explosive atmospheres — Part 29-1: Gas detectors — Performance requirements of detectors for flammable gases*

IEC 60079-29-2, *Explosive atmospheres — Part 29-2: Gas detectors — Selection, installation, use and maintenance of detectors for flammable gases and oxygen*

IEC 60079-30-1, *Explosive atmospheres — Part 30-1: Electrical resistance trace heating — General and testing requirements*

IEC 60204-1, *Safety of Machinery — Electrical equipment of machines — Part 1: General requirements*

IEC 60364-4-41, *Low-voltage electrical installations — Part 4-41: Protection for safety — Protection against electric shock*

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification — Identification of equipment terminals and conductor terminations*

IEC 60446, *Basic and safety principles for man-machine interface, marking and identification — Identification of conductors by colours or alphanumerics*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61000-6-1, *Electromagnetic compatibility (EMC) — Part 6-1: Generic standards — Immunity for residential, commercial and light-industrial environments*

IEC 61000-6-3, *Electromagnetic compatibility (EMC) — Part 6-3: Generic standards — Emission standard for residential, commercial and light-industrial environments*

IEC 61069-7, *Industrial-process measurement and control — Evaluation of system properties for the purpose of system assessment — Part 7: Assessment of system safety*

IEC 61508, *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61511-1, *Functional safety — Safety instrumented systems for the process industry sector — Part 1: Framework, definitions, system, hardware and software requirements*

IEC 62305-3, *Protection against lightning — Part 3: Physical damage to structures and life hazard*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

accessory

part capable of performing an independent function and contributing to the operations of the equipment that it serves

3.2

authority having jurisdiction

organization, office or individual responsible for approving a facility along with an equipment, an installation or a procedure

3.3

bleed venting

expiration or inspiration of air or gas from, or to, one side of a diaphragm of any accessory, component or equipment such as a valve, pressure regulator or switch

3.4

buffer storage tanks

pressurized tanks, which can be located between a hydrogen generator and a compressor for an even flow of gas to the compressor or between the compressor and dispenser for accumulation of pressurized gas supply for vehicle fuelling

ISO/TS 20100:2008(E)**3.5****control system**

system that is intended to automatically operate the fuelling station within its normal operating parameters

NOTE The control system includes the measuring, monitoring and reporting and recording functions, as applicable.

3.6**design pressure**

maximum pressure permissible in a storage vessel (at its top) or a piping system for a designated temperature

NOTE 1 The design pressure is the basis for the pressure setting of the pressure relief devices protecting the vessel or piping system.

NOTE 2 The design pressure may also be the maximum allowable operating pressure rating of pressure vessels manufactured in accordance with national pressure vessel codes.

3.7**dispenser**

parts of the pressurized-gas fuelling station via which the pressurized gas is dispensed to vehicles

NOTE As an example, the dispenser may include a dispenser cabinet, a gas flow meter, a fuelling hose and fuelling nozzle attachments.

3.8**dispenser cabinet**

protective housing that encloses the dispenser gas containing equipment

3.9**dispensing system**

system comprising all equipment necessary to carry out the vehicle fuelling operation, downstream of the hydrogen supply system

[SIST-TS ISO/TS 20100:2020](https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020)

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

3.10**enclosure**

structure that protects equipment from the environment, provides noise attenuation, or provides safety to the areas surrounding the equipment

3.11**fail-safe**

design feature that ensures that safe operating conditions are maintained in the event of a malfunction of control devices or an interruption of a supply source

3.12**fill pressure**

pressure attained at the end of filling

NOTE Fill pressure varies according to the gas temperature in the vehicle tank, which is dependent on the changing parameters and the ambient conditions.

3.13**forecourt**

hard surfaced area at the front of the vehicle fuelling position, including any area underneath a canopy

3.14**fuelling connector**

joined assembly of the fuelling nozzle and fuelling receptacle, which permits quick connect and disconnect of the fuel supply to the vehicle or storage system

3.15**fuelling hose**

flexible conduit used for dispensing gaseous hydrogen to vehicles through a fuelling nozzle

3.16**fuelling nozzle**

mating part of the fuelling connector at the fuelling station, including shut-off valves, that connects the fuelling hose to the vehicle fuelling receptacle for the transfer of hydrogen fuel

3.17**fuelling receptacle**

mating part of the fuelling connector mounted on a vehicle

3.18**fuelling position**

area adjacent to the hydrogen dispensers, where customers park their vehicles for fuelling

3.19**fuelling station**

facility for the dispensing of compressed hydrogen, which includes all stationary equipment that supplies, compresses, stores and dispenses gaseous hydrogen to fuel a land vehicle

3.20**guard**

part of a machine specially used to provide protection by means of a physical barrier

NOTE

Depending on its construction, a guard may be called casing, cover, screen, door, enclosed guard, etc.

3.21**harm**

physical injury or damage to the health of people, or damage to property or to the environment

3.22**hazard**

potential source of harm

3.23**hazardous event**

occurrence in which a hazardous situation results in harm

3.24**hazardous situation**

circumstance in which people, property or the environment are exposed to one or more hazards

3.25**hose breakaway device**

component installed downstream of the dispenser outlet connection to protect the dispenser assembly from damage by vehicles driving away while still connected to the dispenser nozzle

3.26**housing**

section of a system that encloses, and is intended to protect, operating parts, control mechanisms, or other components, which need not be accessible during normal operation

3.27**hydrogen purifier**

equipment to remove oxygen, moisture and other impurities from the hydrogen

ISO/TS 20100:2008(E)**3.28****manufacturer**

person or organization responsible for the design, fabrication and testing of equipment and components

3.29**maximum fill pressure**

maximum pressure to which a vehicle tank may be filled

3.30**mechanically actuating safety equipment**

mechanically actuating equipment that prevents fuelling station operation outside specified acceptable maximum or minimum operating pressures or that prevents a gas leakage in the event of an incident

3.31**nominal working pressure**

nominal working pressure is the vehicle tank pressure, as specified by the manufacturer, at a uniform gas temperature of 15 °C or as specified and at full gas content

3.32**non-public fuelling station**

fuelling station that does not sell or dispense gaseous hydrogen to the general public, e.g. private or municipal vehicle fleet operation

3.33**operator**

licensed person or organization responsible for the safe operation, maintenance and housekeeping of the fuelling station

3.34**outdoors**

location outside of any building or structure, or locations under a roof, weather shelter, or canopy provided this area is not enclosed on more than two sides

3.35**plinth**

raised area on the forecourt, supporting and protecting the dispensers and associated equipment

3.36**pressure relief device**

device designed to open to prevent a rise of internal pressure in excess of a specified value due to emergency or abnormal conditions

NOTE The pressure relief device can be of the re-closing or other type, such as one having a rupture disk and/or fusible plug that requires replacement after each use.

3.37**public fuelling station**

fuelling station that sells gaseous hydrogen to the general public

3.38**risk**

combination of the probability of occurrence of harm and the severity of that harm

3.39**safeguarding**

use of specific technical means to protect persons from the hazards which cannot reasonably be removed or sufficiently limited by design

3.40**safety**

freedom from unacceptable risk

3.41**safety device**

device other than a guard, which eliminates or reduces risk, alone or associated with the guard

3.42**safety distance**

minimum separation between a hazard source and an object (human, equipment or environment), which will mitigate the effect of a likely foreseeable incident and prevent a minor incident from escalating into a larger incident

3.43**safety function**

function to be implemented by a safety-instrumented system, other technology safety-related system or external risk reduction facilities, which is intended to achieve or maintain a safe state for the process with respect to a specific hazardous situation

3.44**safety-instrumented system**

instrumented system used to implement one or more safety-instrumented functions

NOTE A safety-instrument system is composed of any combination of sensors, logic solvers, and final elements.

3.45**safety measures**

combination of the measures incorporated at the design stage and those measures required to be implemented by the user

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TS ISO/TS 20100:2020](https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020)

<https://standards.iteh.ai/catalog/standards/sist/4cdda17b-2760-433e-86f7-632d2f966614/sist-ts-iso-ts-20100-2020>

3.46**vaporizer**

device other than a tank that receives hydrogen in a liquid form and adds sufficient heat to convert the liquid to a gaseous state

NOTE Hydrogen purifiers may comprise purification vessels, dryers, filters and separators.

4 General design requirements

The hydrogen fuelling station installation shall be sited to minimize risk to users, operating personnel, and neighbouring personnel, residents and property.

Consideration shall be given to any potential hazard or risk in relation to the location and operation of the facility.

More specifically, measures to reduce fire and explosion risks shall be applied in the following order of priority:

- prevention of the formation of a flammable or explosive mixture and reduction of the explosion strength potential of explosive atmospheres generated by potential leaks or releases;
- avoidance of ignition sources;
- mitigation of the effects of a fire or explosion.

Installation and equipment design shall minimize the number of connections and other possible points of leakage or release to atmosphere.

Configurations generating the possibility of a hazardous confined explosive atmosphere shall be avoided.