
**Evaluation of pore size distribution and
porosimetry of solid materials by
mercury porosimetry and gas
adsorption —**

Part 1:

Mercury porosimetry

iTeh STANDARD PREVIEW
(standards.iteh.ai)

*Distribution des dimensions des pores et porosimétrie des matériaux
solides par porosimétrie au mercure et par adsorption de gaz —*

Partie 1: Porosimétrie au mercure

<https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 15901-1:2005](https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005)

<https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>

© ISO 2005

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions.....	2
4 Symbols	4
5 Principles.....	4
6 Apparatus and material	5
7 Procedures for calibration and performance.....	5
8 Procedures	6
9 Evaluation.....	9
10 Reporting	10
Annex A (informative) Mercury porosimetry analysis results for alumina reference sample.....	12
Bibliography	18

iTeh STANDARD PREVIEW
 (standards.iteh.ai)
 ISO 15901-1:2005
<https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 15901-1 was prepared by Technical Committee ISO/TC 24, *Sieves, sieving and other sizing methods*, Subcommittee SC 4, *Sizing by methods other than sieving*.

ISO 15901 consists of the following parts, under the general title *Evaluation of pore size distribution and porosimetry of solid materials by mercury porosimetry and gas adsorption*:

- Part 1: Mercury porosimetry
- Part 2: Analysis of mesopores and macropores by gas adsorption
- Part 3: Analysis of micropores by gas adsorption

Introduction

In general, different pores (micro-, meso-, and macropores) can be pictured as either apertures, channels or cavities within a solid body or as space (i.e. interstices or voids) between solid particles in a bed, compact or aggregate. Porosity is a term which is often used to indicate the porous nature of solid material and is more precisely defined as the ratio of the volume of the accessible pores and voids to the total volume occupied by a given amount of the solid. In addition to the accessible pores, a solid can contain closed pores which are isolated from the external surface and into which fluids are not able to penetrate. The characterization of closed pores is not covered in this International Standard.

Porous materials can take the form of fine or coarse powders, compacts, extrudates, sheets or monoliths. Their characterization usually involves the determination of the pore size distribution as well as the total pore volume or porosity. For some purposes, it is also necessary to study the pore shape and interconnectivity and to determine the internal and external specific surface area.

Porous materials have great technological importance, for example in the context of the following:

- controlled drug release;
- catalysis;
- gas separation;
- filtration including sterilization;
- materials technology;
- environmental protection and pollution control;
- natural reservoir rocks;
- building materials properties;
- polymers and ceramic.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 15901-1:2005](https://standards.iteh.ai/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005)

<https://standards.iteh.ai/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>

It is well established that the performance of a porous solid (e.g. its strength, reactivity, permeability or adsorbent power) is dependent on its pore structure. Many different methods have been developed for the characterization of pore structure. In view of the complexity of most porous solids, it is not surprising that the results obtained are not always in agreement and that no single technique can be relied upon to provide a complete picture of the pore structure. The choice of the most appropriate method depends on the application of the porous solid, its chemical and physical nature and the range of pore size.

The most commonly used methods are as follows:

- a) mercury porosimetry, where the pores are filled with mercury under pressure; this method is suitable for many materials with pores in the appropriate diameter of 0,003 μm to 400 μm ;
- b) meso- and macropore analysis by gas adsorption, where the pores are characterized by adsorbing a gas, such as nitrogen, at liquid nitrogen temperature; the method is used for pores in the approximate diameter range of 0,002 μm to 0,1 μm (2,0 nm to 100 nm), and is an extension of the surface area estimation technique;
- c) micropore analysis by gas adsorption, where the pores are characterized by adsorbing a gas, such as nitrogen, at liquid nitrogen temperature; the method is used for pores in the approximate diameter range of 0,4 nm to 2,0 nm, and is an extension of the surface area estimation technique.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 15901-1:2005](https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005)

<https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>

Evaluation of pore size distribution and porosimetry of solid materials by mercury porosimetry and gas adsorption —

Part 1: Mercury porosimetry

WARNING — The use of this International Standard may involve hazardous materials, operations and equipment. This International Standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this International Standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

1 Scope

This International Standard describes a method for the evaluation of the pore size distribution and the specific surface in pores of solids by mercury porosimetry according to the method of Ritter and Drake ^{[1], [2]}. It is a comparative test, usually destructive due to mercury contamination, in which the volume of mercury penetrating a pore or void is determined as a function of an applied hydrostatic pressure, which can be related to a pore diameter.

Practical considerations presently limit the maximum applied absolute pressure to about 400 MPa (60 000 psia) corresponding to a minimum equivalent pore diameter of approximately 0,003 µm. The maximum diameter will be limited for samples having a significant depth due to the difference in hydrostatic head of mercury from the top to the bottom of the sample. For the most purposes, this limit can be regarded as 400 µm. The measurements cover interparticle and intraparticle porosity. In general, it cannot distinguish between these porosities where they co-exist.

The method is suitable for the study of most non-wettable, by mercury, porous materials. Samples that amalgamate with mercury, such as certain metals, e.g. gold, aluminium, reduced copper, reduced nickel and silver, can be unsuitable for this technique or can require a preliminary passivation. Under the applied pressure, some materials are deformed, compacted or destroyed, whereby open pores can be collapsed and closed pores opened. In some cases, it is possible to apply sample compressibility corrections and useful comparative data can still be obtained. For these reasons, the mercury porosimetry technique is considered to be comparative.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3165, *Sampling of chemical products for industrial use — Safety in sampling*

ISO 8213, *Chemical products for industrial use — Sampling techniques — Solid chemical products in the form of particles varying from powders to coarse lumps*

M 024 4/85, Quecksilber und seine Verbindungen. Merkblatt der Berufsgenossenschaft der chemischen Industrie, Postfach 101480, D-69004 Heidelberg, Germany

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

bulk density

powder density under defined conditions

3.2

blind pore

dead-end-pore

open pore having a single connection with an external surface

3.3

closed pore

cavity not connected to the external surface

NOTE Closed pores are not covered in this International standard.

3.4

contact angle

angle that a non-wetting liquid makes with a solid material

3.5

external surface area

area of external surface including roughness but outside pores

3.6

ink bottle pore

narrow necked open pore

3.7

interconnected pore

pore which communicates with one or more other pores

3.8

internal surface area

area of internal pore walls

3.9

intraparticle porosity

ratio of the volume of open pores internal to the particle to the total volume occupied by the solid

3.10

interparticle porosity

ratio of the volume of space between particles in a powder to the apparent volume of the particles or powder

3.11

macropore

pore of internal width greater than 50 nm

3.12

mesopore

pore of internal width between 2 nm and 50 nm

3.13

micropore

pore of internal width less than 2 nm which is accessible for a molecule to be adsorbed

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[ISO 15901-1:2005](https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005)

<https://standards.iteh.ai/catalog/standards/sist/693954b9-cf07-4a01-9225-93e760d2fe5c/iso-15901-1-2005>

3.14**open pore**

cavity or channel with access to an external surface

3.15**open porosity**

ratio of the volume of open pores and voids to the total volume occupied by the solid

3.16**pore size**

pore width (for example, the diameter of a cylindrical pore or the distance between the opposite walls of a slit) that is a representative value of various sizes of the vacant space inside a porous material

NOTE One of the methods to determine pore sizes is by mercury porosimetry.

3.17**pore volume**

volume of pores determined by stated method

3.18**porosimeter**

instrument for measuring porosity and pore size distribution

3.19**porosimetry**

methods for the estimation of porosity and pore size distribution

3.20**porosity**

ratio of total pore volume to apparent volume of particle or powder

3.21**porous solid**

solid with cavities or channels which are deeper than they are wide

3.22**skeletal density**

mass of a powder divided by the total volume of the sample, including closed pores but excluding open pores

3.23**apparent density**

mass of a powder divided by the total volume of the sample, including closed and inaccessible pores, as determined by the stated method

3.24**powder density**

mass of a powder divided by its apparent volume, which is taken to be the total volume of the solid material, open and closed pores and interstices

3.25**surface area**

extent of available surface area as determined by given method under stated conditions

3.26**surface tension**

force required to separate a film of liquid from either a solid material or a film of the same liquid

3.27

through pore

pore which passes all the way through the sample

3.28

total porosity

ratio of the volume of voids plus the volume of open and closed pores to the total volume occupied by the solid

3.29

true density

true particle density

mass of the particle divided by its volume, excluding open and closed pores

3.30

void

space between particles, i.e. an interparticle pore

4 Symbols

For the purposes of this document, the following symbols apply.

Symbol	Term	SI unit	Derived unit	Conversion factors for obsolete units
p	pressure	Pa	MPa, psia, Torr, mm Hg	1 psia = 1 lb·in ⁻² = 6 894 Pa 1 Torr = 1 mm Hg = 133,32 Pa
d_p	pore diameter	m	nm, μm, Å	1 nm = 10 ⁻⁹ m, 1 μm = 10 ⁻⁶ m, 1 Å = 10 ⁻¹⁰ m
t	time	s	h	1 h = 3 600 s
S	specific surface area	m ² kg ⁻¹	m ² g ⁻¹	—
V_{Hg}	intruded volume (of mercury)	m ³	cm ³ , 10 ³ mm ³	10 ³ mm ³ = 1 cm ³ = 10 ⁻⁶ m ³
$V_{Hg,0}$	initial intruded volume of mercury	m ³	cm ³ , 10 ³ mm ³	—
$V_{Hg,max}$	final intruded volume of mercury	m ³	cm ³ , 10 ³ mm ³	—
V_p	specific pore volume	m ³ ·kg ⁻¹	10 ³ mm ³ g ⁻¹	—
γ	surface tension of mercury	N·m ⁻¹	dyne·cm ⁻¹ , N·m ⁻¹	dyne·cm ⁻¹ = N·m ⁻¹
ρ	density of mercury = 13,534 at 25,0 °C	kg·m ⁻³	g·cm ⁻³ , 10 ³ kg·m ⁻³	10 ³ kg·m ⁻³ = 1 g·cm ⁻³
θ	contact angle of mercury at the sample, measured through the liquid phase	rad	°	1° = (π/180) rad

5 Principles

A non-wettable liquid can enter a porous system only when forced by pressure. The pore size distribution of a porous solid can be determined by forcing mercury into an evacuated sample under increasing pressure and measuring the volume of mercury intruded as a function of pressure. The determination may proceed either with the pressure being raised in a step-wise manner and the volume of mercury intruded measured after an interval of time when equilibrium has been achieved, or by raising the pressure in a continuous (progressive) manner.

6 Apparatus and material

WARNING — It is important that proper precautions for the protection of laboratory personnel are taken when mercury is used. Attention is drawn to the relevant regulations and guidance documents which appertain for the protection of personnel in each of the member countries.

6.1 Sample holder, having a uniform bore capillary tube through which the sample can be evacuated and through which mercury can enter.

The capillary tube is attached to a wider bore tube in which the test sample is located. If precise measurements are required the internal volume of the capillary tube should be between 20 % and 90 % of the expected pore and void volume of the sample. Since different materials exhibit a wide range of open porosities a number of sample holders with different diameter capillary tubes and sample volumes may be required. A special design of sample holder is often used with powdered samples to avoid loss of powder during evacuation.

6.2 Porosimeter, capable of carrying out the test as two sequential measurements, a low-pressure test up to at least 0,2 MPa (30 psia) and a high-pressure test up to the maximum operating pressure of the porosimeter [circa 400 MPa (60 000 psia)].

The porosimeter may have several ports for high- and low-pressure operations, or the low-pressure test may be carried out on a separate unit.

Prior to any porosimetry measurement it is necessary to evacuate the sample using a vacuum pump, equipped with mercury retainer, to a residual pressure of 7 Pa or less and then to fill the sample holder with mercury to a given low pressure. A means of generating pressure is necessary to cause intrusion of mercury.

A means of detecting the change in the volume of mercury intruded to a resolution of 1 mm³ or less is desirable. This is usually done by measuring the change in capacitance between the mercury column in the capillary tube and a metal sleeve around the outside of the sample holder.

6.3 Mercury, of analytical quality, with a purity of at least ratio of 99,4 mass %.

7 Procedures for calibration and performance

7.1 General

Sample preparation and the filling of the sample holder with mercury require vacuum, the level of which is usually recorded using a transducer. For the porosity evaluation, two signals are required to be measured in a porosimeter; the applied pressure and the corresponding volume change of mercury as it fills the pores in the sample. The volume of mercury displaced from a precision glass capillary tube is most commonly determined as a function of electrical capacity change.

7.2 Pressure signal calibration

Pressure is usually measured with electronic pressure transducers which will have been factory calibrated. The accuracy of the pressure measurement should be within $\pm 1\%$ of the full scale transducer reading or $\pm 2\%$ of the actual reading, whichever is the lower. It is recommended that verification of calibration, traceable to an accredited organisation, be regularly performed.

7.3 Volume signal calibration

The accuracy of the volume measurement should be within $\pm 1\%$ of the total volume to be measured. It is recommended that verification of calibration, traceable to an accredited organisation, be regularly performed.