



SLOVENSKI STANDARD

SIST ISO 8873-2:2015

01-marec-2015

Nadomešča:
SIST ISO 8873:1996

**Penjeni polimerni materiali - Brizgana poliuretanska pena za toplotno izolacijo - 2.
del: Uporaba**

Rigid cellular plastics - Spray-applied polyurethane foam for thermal insulation - Part 2:
Application

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Plastiques alvéolaires rigides - Mousse de polyuréthane projetée pour l'isolation
thermique - Partie 2: Application [SIST ISO 8873-2:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>

Ta slovenski standard je istoveten z: ISO 8873-2:2007

ICS:

83.100	Penjeni polimeri	Cellular materials
91.120.10	Toplotna izolacija stavb	Thermal insulation

SIST ISO 8873-2:2015

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ISO 8873-2:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>

INTERNATIONAL STANDARD

ISO
8873-2

First edition
2007-05-01

Rigid cellular plastics — Spray-applied polyurethane foam for thermal insulation —

Part 2: Application

iTeh STANDARD PREVIEW
*Plastiques alvéolaires rigides — Mousse de polyuréthane projetée
pour l'isolation thermique —
Partie 2: Application*
(standards.iteh.ai)

[SIST ISO 8873-2:2015](https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>



Reference number
ISO 8873-2:2007(E)

© ISO 2007

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 8873-2:2015](https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>

**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2007

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents	Page
Foreword.....	iv
Introduction	v
1 Scope.....	1
2 Normative references	1
3 Terms and definitions	2
4 Requirements	3
4.1 Manufacturer	3
4.2 Spray polyurethane foam contractor	3
4.3 Spray polyurethane foam installer	4
4.4 Apprentice installer.....	6
4.5 Material.....	6
4.6 Equipment.....	6
4.7 Installation	6
5 Applications.....	8
5.1 General.....	8
5.2 Air barrier system application	8
5.3 Vapour barrier application.....	8
5.4 Exterior foundation insulation application.....	8
5.5 Interior foundation insulation application.....	8
5.6 Cathedral ceilings, flat ceilings and decks over heated spaces.....	8
5.7 Attic application, exterior (cavity) and interior wall application	8
6 Sampling	8
7 Test methods	9
7.1 Determination of density	9
7.2 Cohesion and adhesion test	10
7.3 Verification of substrate (application surface) preparation.....	10
7.4 Reporting requirements	10
8 Manufacturer's marking.....	11
9 Manufacturer's documentation	12
10 Limitations	12
Annex A (normative) Substrate preparation.....	13
Annex B (normative) Selection of chemical components (system).....	16
Annex C (informative) Climatic factors	17
Annex D (normative) Job-site set up.....	18
Annex E (informative) Trouble shooting and repair.....	20
Annex F (normative) Handling and safety precautions.....	22
Annex G (normative) Disposal and detoxification of drums.....	25
Annex H (informative) Daily work record	27
Annex I (informative) Example of job site label	29
Annex J (informative) Outline of licensed installer training programme.....	30
Annex K (normative) Minimum equipment for site test kit	36
Bibliography	37

ISO 8873-2:2007(E)**Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 8873-2 was prepared by Technical Committee ISO/TC 61, *Plastics*, Subcommittee SC 10, *Cellular plastics*.

This first edition of ISO 8873-2, together with ISO 8873-1 and ISO 8873-3, cancels and replaces ISO 8873:1987, which has been technically revised.

ISO 8873 consists of the following parts, under the general title *Rigid cellular plastics — Spray-applied polyurethane foam for thermal insulation*: [SIST ISO 8873-2:2015](https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015)

— *Part 1: Material specifications*

— *Part 2: Application*

— *Part 3: Test methods*

Introduction

Spray polyurethane foam for thermal insulation is made by combining two liquid components on the project site to manufacture a product. As the manufactured product is what provides the physical and thermal properties desired by the user, it only becomes spray polyurethane foam when it is installed. As such, an International Standard for the application and installation is required.

This part of ISO 8873 outlines the obligations for the installer of the liquid components that produce the actual material.

ISO 8873-1 outlines obligations for the manufacturers of spray polyurethane foam liquid components.

ISO 8873-3 provides test methods which have not previously been specified in International Standards.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 8873-2:2015](https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ISO 8873-2:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/58abfeb1-c612-44b2-b2bf-1cd8666d06f6/sist-iso-8873-2-2015>

Rigid cellular plastics — Spray-applied polyurethane foam for thermal insulation —

Part 2: Application

WARNING — Persons using this document should be familiar with normal laboratory practice, if applicable. This document does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user to establish appropriate safety and health practices and to ensure compliance with any regulatory requirements.

1 Scope

This part of ISO 8873 outlines requirements for the application of rigid cellular plastic spray polyurethane foam for thermal insulation. The primary application of the material is for use as thermal insulation. Spray polyurethane foam can also be used as the air barrier material which forms part of an air barrier assembly in buildings. Under specific application conditions, the material can be used in vapour barrier applications in a building assembly (details of the conditions can be obtained from the manufacturer). The application requirements are for the installation of spray polyurethane foam whether applied on a building site or in a prefabrication (manufacturing) facility.

This part of ISO 8873 can be used for non-building applications when agreed to by the supplier and the purchaser.

The requirements include obligations for the manufacturer, the contractor and the installer. The requirements include the selection of chemical components, application requirements, quality control and documentation of the application, limitations for the application and requirements for safety and for disposal of associated waste material and packaging.

Installation of spray polyurethane foam for thermal insulation, according to this part of ISO 8873 requires the use of materials and/or equipment that could be hazardous (see Warning).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 8873-1, *Rigid cellular plastics — Spray-applied polyurethane foam for thermal insulation — Part 1: Material specifications*

ISO/IEC 17024, *Conformity assessment — General requirements for bodies operating certification of persons*

ISO 8873-2:2007(E)

3 Terms and definitions

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

- 3.1 authority having jurisdiction**
officer or officers having authority, under appropriate regulatory instruments, to exercise enforcement
- 3.2 apprentice installer**
individual who applies spray polyurethane foam on the job site, under the direct supervision of a spray polyurethane installer
- 3.3 certification organization**
impartial body possessing the necessary competence and reliability to operate a certification system in accordance with ISO/IEC 17024, in which the interests of all parties concerned with the functioning of the system are represented
- 3.4 equipment manufacturer**
manufacturer of equipment designed for spray-application of rigid polyurethane cellular plastic thermal insulation
- 3.5 *in-situ* thermal insulation**
thermal insulation product produced or taking its final form at the site of application and which achieves its properties after installation
- 3.6 site quality assurance programme**
quality assurance programme (QAP) based upon quality standards, which ties the chemical system components manufacturer (supplier), the contractor and the installer together for the installation of spray polyurethane foam
- NOTE 1 The QAP should outline the responsibilities and obligations of each of the three parties. The QAP should outline the training and certification requirements for each of the three parties and should include a site inspection of the installation of spray polyurethane foam.
- NOTE 2 ISO 9001 and ISO 12576-2 are examples of quality standards.
- 3.7 spray polyurethane foam**
rigid cellular plastic material with substantially closed cell structure based on polyurethanes, which is foamed *in situ* by the catalysed reaction of polyisocyanates and polyhydroxyl compounds, expanded with blowing agents
- 3.8 spray polyurethane foam contractor**
individual, organization or corporation who is responsible for all requirements and obligations for the installation of the product
- 3.9 spray polyurethane foam installer**
individual or worker who applies the chemical components by mixing and spraying them to form the rigid cellular plastic spray polyurethane foam product

NOTE The installer is responsible for the actual installation and site requirements identified by the manufacturer and/or this part of ISO 8873 for application of the product. The installer should be trained and qualified as having

demonstrated the required knowledge for proper application of the product by a certification organization (CO). The installer should follow the requirements for installation and the obligations for installers identified by the manufacturer and this part of ISO 8873.

3.10

spray polyurethane foam system manufacturer

manufacturer/supplier of the liquid chemical components, polyisocyanates and polyhydroxyl blends containing also flame retardants, blowing agent and catalysts (system), which are designed to be mixed and sprayed to form rigid polyurethane foam insulation material *in situ*

4 Requirements

4.1 Manufacturer

The manufacturer (supplier)

- a) shall produce material that meets the requirements of ISO 8873-1,
- b) shall mark and label the shipping containers to declare that the material meets the requirements of ISO 8873-1,
- c) shall declare the certification organization that is responsible for delivering the site quality assurance programme for their product, and
- d) shall ensure that the material is installed by a spray polyurethane foam contractor using a spray polyurethane foam installer in accordance with this part of ISO 8873 and the instructions given by the chemical manufacturer.

4.2 Spray polyurethane foam contractor

The spray polyurethane foam contractor

- a) shall produce material that meets the requirements of ISO 8873-1 and shall comply with all requirements of this part of ISO 8873;
- b) shall select the material that is appropriate for the installation;
- c) shall procure material which complies with ISO 8873-1 from a spray polyurethane foam system manufacturer;
- d) shall verify, through the use of drum labels or other documentation, that the material received complies with ISO 8873-1;
- e) shall have at least one trained and certification organization approved spray polyurethane foam installer on each job site during the application of the spray polyurethane foam thermal insulation;
- f) shall be responsible for all aspects of the installation of the material; all regulations shall be complied with during the installation of the material; the completed application shall comply with all appropriate regulations such as building codes;
- g) shall ensure that the spray polyurethane foam installer has successfully completed a training course approved by the manufacturer and the certification organization; the spray polyurethane foam installer shall successfully complete the training and have obtained certification as a spray polyurethane foam installer;
- h) shall provide the spray polyurethane foam installer with proper equipment to install spray polyurethane foam; equipment may include, but is not limited to, transfer pumps, a proportioner unit, hoses, hose heaters, spray guns, compressors and generators;

ISO 8873-2:2007(E)

- i) shall provide, or ensure that the spray polyurethane foam installer has, proper personnel protection, which shall include a positive fresh-air-supplied full-face respirator; other protection includes head protection, eye protection, ear protection, body protection, hand protection and foot protection;
- j) shall provide, on each job site, a test kit meeting the requirements outlined in Annex K for use by the spray polyurethane foam installer to conduct the testing required for thermal insulation in accordance with this part of ISO 8873;
- k) shall ensure that the spray polyurethane foam installer conducts the daily testing;
- l) shall ensure that the installer completes daily work records in accordance with the site quality assurance programme; this daily work record shall contain
- information on the job site, date and material used,
 - name of the installer and certification number,
 - application conditions and environmental conditions,
 - results of the testing completed on site,
 - whether the material complies with ISO 8873-1,
 - whether the project required isolation and ventilation, and
 - whether the material used has been evaluated by a third party,
- m) shall supply the installer with all the forms required; the daily work record shall be completed at the beginning of each day, each time a material batch is changed, and when the job site is changed within a given day;
- n) shall keep the daily work records for a period of seven years; these records shall be made available upon request, within a reasonable time, to the manufacturer or the certification organization; the minimum information required for a daily work record is shown in Annex H;
- o) shall provide a job site declaration form containing the minimum information outlined in Annex I to the customer within 30 days of completion of the project;
- p) shall ensure that the spray polyurethane foam installer follows the site quality assurance programme developed by the certification organization; a copy of the site quality assurance programme shall be made available upon request;
- q) shall maintain the installation equipment in proper working order;
- r) where a separate contractor is responsible for the thermal barrier installation and when the authority having jurisdiction requires a thermal barrier for that application, the spray polyurethane foam contractor shall notify the building owner or the owner's representative in writing of the requirement for a thermal barrier and the flammability hazard, which could exist until such time that the foam is covered.

4.3 Spray polyurethane foam installer

The installer

- a) shall produce material that meets the requirements of ISO 8873-1 in accordance with this part of ISO 8873, the instructions provided by the spray polyurethane foam system manufacturer and the spray polyurethane foam contractor;

- b) shall confirm, using drum labels or other documentation, that the liquid chemicals to be used on site have been declared by the manufacturer to comply with ISO 8873-1 before commencing installation;
- c) shall be responsible for the on-site installation of the material, safe handling and storage of the material, proper isolation of the spray area, warning signs when spraying is in progress, site housekeeping, and their own personal and the crew's health and safety; the spray polyurethane foam installer shall wear proper personnel protection, which includes head protection, eye protection, a positive fresh-air-supplied full-face respirator, ear protection, body protection, hand protection and foot protection in compliance with regulations;
- d) shall successfully complete a training course approved by the manufacturer and the designated certification organization; the installer shall obtain certification from the designated certification organization as a spray polyurethane foam installer; a recommended training outline is shown in Annex J;
- e) shall follow all operating instructions for the equipment provided by the equipment manufacturer; this equipment may include, but is not limited to, transfer pumps, a proportioner unit, hoses, hose heaters, guns, compressors and generators; the installer shall follow instructions from the equipment manufacturer for the operation, maintenance and cleaning of the equipment used for installation; the spray polyurethane foam installer shall follow all safety procedures required by the equipment manufacturer;
- f) shall verify, through a material label, that the material on site has been declared by the manufacturer to comply with ISO 8873-1;
- g) shall verify that the substrate has been properly prepared;
- h) shall verify that the environmental conditions are within the range approved by the spray polyurethane foam system manufacturer;
- i) shall set the equipment to the proper operating parameters;
- j) shall install the material in accordance with this part of ISO 8873 and the manufacturer's instructions;
- k) shall comply with all requirements of the site quality assurance programme provided by the certification organization;
- l) shall apply the spray polyurethane foam so that the surface is reasonably smooth and of consistent thickness;
- m) shall exercise an ongoing visual and physical quality control check throughout the spray application to ensure proper adhesion to the substrate and proper quality of the spray polyurethane foam;
- n) shall check with a depth gauge (see Figure 1) the thickness of the the applied foam on a continual basis and shall provide the minimum thickness specified by the owner;
- o) shall conduct density, adhesion, cohesion and substrate verification at the beginning of each day, each time a material batch is changed, and when the job site is changed within a given day;
- p) shall complete daily work records in accordance with the site quality assurance programme; this daily work record shall contain
- information on the job site (see Annex D), date and material used,
 - name of the installer and certification number,
 - application conditions and environmental conditions,
 - results of the testing completed on site,
 - whether the material complies with ISO 8873-1,