
**Toplotna črpalka s plinsko gnanim motorjem z notranjim zgorevanjem - 5. del:
Izračun sezonske zmogljivosti za ogrevanje in hlajenje**

Gas-fired endothermic engine driven heat pumps - Part 5: Calculation of seasonal performances in heating and cooling mode

Gasbefeuerte endothermische Motor-Wärmepumpen - Teil 5: Berechnung der saisonalen Effizienzkennzahlen im Heiz- und Kühlmodus

Pompes à chaleur à moteur endothermique alimenté au gaz -Partie 5 : Calcul des performances saisonnières en modes chauffage et refroidissement

[https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-](https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018)

[d8788c6d9700/sist-en-16905-5-2018](https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018)

Ta slovenski standard je istoveten z: EN 16905-5:2017

ICS:

27.080

Toplotne črpalke

Heat pumps

SIST EN 16905-5:2018**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 16905-5:2018](https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018)

<https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018>

EUROPEAN STANDARD

EN 16905-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2017

ICS 27.080

English Version

Gas-fired endothermic engine driven heat pumps - Part 5: Calculation of seasonal performances in heating and cooling mode

Pompes à chaleur à moteur endothermique alimenté
au gaz -Partie 5 : Calcul des performances saisonnières
en modes chauffage et refroidissement

Gasbefeuerte endothermische Motor-Wärmepumpen -
Teil 5: Berechnung der saisonalen Effizienzkennzahlen
im Heiz- und Kühlmodus

This European Standard was approved by CEN on 9 January 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

iTeh STANDARD PREVIEW

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
European foreword.....	4
1 Scope	5
1.1 Scope of EN 16905 series.....	5
1.2 Scope of EN 16905-5.....	5
2 Normative references	6
3 Terms and definitions	6
4 Part load conditions in cooling mode	6
4.1 General.....	6
4.2 Air-to-air units	6
4.3 Water-to-air and brine to air units	6
4.4 Air-to-water units	7
4.5 Water-to-water and brine-to-water units.....	8
5 Part load conditions in heating mode.....	9
5.1 General.....	9
5.2 Air-to-air units	10
5.3 Water-to-air units and brine to air units.....	12
5.4 Air-to-water units	13
5.4.1 General.....	13
5.4.2 Low temperature application.....	14
5.4.3 Medium temperature application.....	17
5.4.4 High temperature application.....	20
5.5 Water-to-water and brine-to-water units.....	23
5.5.1 General.....	23
5.5.2 Low temperature application.....	23
5.5.3 Medium temperature application.....	26
5.5.4 High temperature application.....	29
6 Calculation methods for reference SPER_c.....	31
6.1 General.....	31
6.2 General formula for calculation of GUE _c and AEF _c	32
6.3 General formula for calculation of EHREgas _c and EHREelec _c	32
6.4 General formula for calculation of reference SGUE _c	32
6.5 Calculation of reference SAEF _c	33
6.6 Calculation of reference annual cooling demand (Q _{ref,c}).....	33
6.7 Calculation of reference SAEF _{CON}	34
6.8 Calculation of reference SEHREgas _c	34
6.9 Calculation of reference SEHREelec _c	35
6.10 Procedures for the determination of GUE _{cPL} / AEF _{cPL} values	35
6.11 Procedures for the determination of EHREgas _{cPL} / EHREelec _{cPL} values	35
6.12 Calculation of reference SPER _c	36
7 Calculation methods for reference SPER_h	36
7.1 General.....	36
7.2 General formula for calculation of GUE _h and AEF _h	36
7.3 General formula for calculation of EHREgas _h	36
7.4 General formula for calculation of reference SGUE _h	37

7.5	Calculation of reference $SAEF_h$	39
7.6	Calculation of reference annual heating demand (Q_{refh})	39
7.7	Calculation of reference $SAEF_{hON}$	40
7.8	Calculation of reference $SEHRE_{gas_h}$	40
7.9	Calculation of reference $SEHRE_{elec_h}$	41
7.10	Procedures for the determination of GUE_{hPL} / AEF_{hPL} values.....	41
7.11	Procedures for the determination of $SEHRE_{gas_{hPL}}$ / $SEHRE_{elec_{hPL}}$ values.....	41
7.12	Calculation of reference $SPER_h$	42
Annex A (normative) Determination of reference annual cooling/heating demands and determination of hours for active mode, thermostat off, standby, off mode and crankcase heater mode for reference $SAEF_c$ and $SAEF_h$ calculation.....		
		43
Annex B (informative) Calculation example for reference $SGUE_c$, $SAEF_c$, $SEHRE_{gas_c}$, $SEHRE_{elec_c}$ and $SPER_c$		
		45
Annex C (informative) Calculation example for reference $SGUE_h$, $SAEF_h$, $SEHRE_{gas_h}$, $SEHRE_{elec_h}$ and $SPER_h$.....		
		48
Annex D (informative) Adaption of water temperature for fixed capacity		
		51
Annex E (informative) Compensation method for air to water and water to water units		
		52
Annex ZA (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 aimed to be covered		
		53
Annex ZB (informative) Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 aimed to be covered.....		
		55
Bibliography		
		57

SIST EN 16905-5:2018

<https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018>

EN 16905-5:2017 (E)**European foreword**

This document (EN 16905-5:2017) has been prepared by Technical Committee CEN/TC 299 “Gas-fired sorption appliances, indirect fired sorption appliances, gas-fired endothermic engine heat pumps and domestic gas-fired washing and drying appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2017, and conflicting national standards shall be withdrawn at the latest by September 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA and Annex ZB, which are integral parts of this document.

This standard comprises the following parts under the general title, *Gas-fired endothermic engine driven heat pumps*:

- iTeh STANDARD PREVIEW**
(standards.iteh.ai)
- *Part 1: Terms and definitions;*
 - *Part 2: Safety* (WI 00299025; currently in preparation);
 - *Part 3: Test conditions;* [SIST EN 16905-5:2018
https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018](https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018)
 - *Part 4: Test methods;*
 - *Part 5: Calculation of seasonal performances in heating and cooling mode.*

EN 16905-1, prEN 16905-2, EN 16905-3, EN 16905-4 and EN 16905-5 have been prepared to address the essential requirements of the European Directive 2009/142/EC relating to appliances burning gaseous fuels (see prEN 16905-2:201X, Annex ZA for safety aspects and EN 16905-5:2017, Annex ZA for rational use of energy aspects).

These documents are linked to the Energy Related Products Directive (2009/125/EC) in terms of tests conditions, tests methods and seasonal performances calculation methods under Mandate M/535; (see EN 16905-3:2017, Annex ZA, EN 16905-4:2017, Annex ZA, EN 16905-5:2017, Annex ZA and prEN 16905-2:201X, Annex ZB).

These documents will be reviewed whenever new mandates could apply.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

1.1 Scope of EN 16905 series

This European Standard specifies the requirements, test methods and test conditions for the rating and performance calculation of air conditioners and heat pumps using either air, water or brine as heat transfer media, with gas-fired endothermic engine driven compressors when used for space heating, cooling and refrigeration, hereafter referred to as “GEHP appliance”.

This European Standard only applies to appliances with a maximum heat input (based on net calorific value) not exceeding 70 kW at standard rating conditions.

This European Standard only applies to appliances under categories I_{2H}, I_{2E}, I_{2Er}, I_{2R}, I_{2E(S)B}, I_{2L}, I_{2LL}, I_{2ELL}, I_{2E(R)B}, I_{2ESi}, I_{2E(R)}, I_{3P}, I_{3B}, I_{3B/P}, II_{2H3+}, II_{2Er3+}, II_{2H3B/P}, II_{2L3B/P}, II_{2E3B/P}, II_{2ELL3B/P}, II_{2L3P}, II_{2H3P}, II_{2E3P} and II_{2Er3P} according to EN 437.

This European Standard only applies to appliances having:

- a) gas fired endothermic engines under the control of fully automatic control systems;
- b) closed system refrigerant circuits in which the refrigerant does not come into direct contact with the fluid to be cooled or heated;
- c) where the temperature of the heat transfer fluid of the heating system (heating water circuit) does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the:
 - 1) heating water circuit (if installed) does not exceed 6 bar,
 - 2) domestic hot water circuit (if installed) does not exceed 10 bar.

This European Standard applies to appliances only when used for space heating or space cooling or for refrigeration, with or without heat recovery.

The appliances having their condenser cooled by air and by the evaporation of external additional water are not covered by this European Standard.

Packaged units, single split and multisplit systems are covered by this European Standard. Single duct and double duct units are covered by this European Standard.

The above appliances can have one or more primary or secondary functions.

This European Standard is applicable to appliances that are intended to be type tested. Requirements for appliances that are not type tested would need to be subject to further consideration.

In the case of packaged units (consisting of several parts), this European Standard applies only to those designed and supplied as a complete package.

NOTE All the symbols given in this text are used regardless of the language used.

1.2 Scope of EN 16905-5

This part of the EN 16905 series specifies the calculation of seasonal performance factor for gas-fired endothermic engine driven heat pumps for heating and/or cooling mode including the engine heat recovery.

EN 16905-5:2017 (E)

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 16905-1, *Gas-fired endothermic engine driven heat pumps — Part 1: Terms and definitions*

EN 16905-4:2017, *Gas-fired endothermic engine driven heat pumps — Part 4: Test methods*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 16905-1 apply.

4 Part load conditions in cooling mode

4.1 General

For the purpose of calculation of application $SGUE_c$, $SAEF_c$, $SEHREgas_c$, $SEHREelec_c$ and reference $SGUE_c$, $SAEF_c$, $SEHREgas_c$, $SEHREelec_c$ as explained in Clauses 6 and 7, the part load ratios mentioned below shall be based on the part load ratio Formulae (1)st column of Tables 1 to 2) and not on the rounded figures as mentioned in the 2nd column of these tables. The calculation of $SGUE_c$, $SAEF_c$, $SEHREgas_c$, $SEHREelec_c$ and reference $SGUE_c$, $SAEF_c$, $SEHREgas_c$, $SEHREelec_c$ is determined via linear interpolation of the respective part load values at the reference part load conditions mentioned below (A, B, C, D).

4.2 Air-to-air units

The part load conditions for determining the reference $SGUE_c$ (Formula (2)), $SAEF_c$ (Formula (4)), $SEHREgas_c$ (Formula (7)), $SEHREelec_c$ (Formula (8)) are given in the following table:

<https://standards.iteh.ai/catalog/standards/sist/ad268ef9-620d-40e6-96df-d8788c6d9700/sist-en-16905-5-2018>

Table 1 — Part load conditions of air to air units and air-cooled multisplit systems in cooling mode

	Part load ratio	Part load ratio %	Outdoor air dry bulb temperature °C	Indoor air dry bulb (wet bulb) temperatures °C
A	$(35-16)/(T_{designc}-16)$	100	35	27(19)
B	$(30-16)/(T_{designc}-16)$	74	30	27(19)
C	$(25-16)/(T_{designc}-16)$	47	25	27(19)
D	$(20-16)/(T_{designc}-16)$	21	20	27(19)

4.3 Water-to-air and brine to air units

The part load conditions for determining the reference $SGUE_c$ (Formula (2)), $SAEF_c$ (Formula (4)), $SEHREgas_c$ (Formula (7)), $SEHREelec_c$ (Formula (8)) are given in the following table:

Table 2 — Part load conditions of water-to-air and brine-to-air units in cooling mode

	Part load ratio	Part load ratio %	Outdoor heat exchanger			Indoor heat exchanger
			Cooling tower ^b or water loop application Inlet/outlet water temperatures °C	Ground coupled application (water or brine) Inlet/outlet water temperatures °C	Dry cooler application Inlet/outlet water temperatures °C	Air dry bulb (wet bulb) temperatures °C
A	$(35-16)/(T_{designc}-16)$	100	30/35	10/15	50/45	27(19)
B	$(30-16)/(T_{designc}-16)$	74	26/ ^a	10/ ^a	45/ ^a	27(19)
C	$(25-16)/(T_{designc}-16)$	47	22/ ^a	10/ ^a	40/ ^a	27(19)
D	$(20-16)/(T_{designc}-16)$	21	18/ ^a	10/ ^a	35/ ^a	27(19)
^a With the water flow rate as determined during the "A" test. ^b If a cooling tower and a water-to-air unit are sold as a matched assembly, they shall be tested as an air-to-air unit.						

SIST EN 16905-5:2018

4.4 Air-to-water units

For each application, units either allowing or not allowing a variation of the outlet water temperature with the outdoor temperature are considered. The variable outlet temperature shall only be applied when the control provides a regulation of outlet water temperature that considers the outdoor temperature.

The part load conditions for determining the reference SGUE_c (Formula (2)), SAEF_c (Formula (4)), SEHREgas_c (Formula (7)), SEHREelec_c (Formula (8)) are given in the following table:

Table 3 — Part load conditions of air-to-water units in cooling mode

	Part load ratio	Part load ratio %	Outdoor heat exchanger	Indoor heat exchanger		
			Air dry bulb temperature °C	Fan coil application Inlet/outlet water temperatures		Cooling floor application Inlet/outlet water temperatures °C
				Fixed outlet °C	Variable outlet °C	
A	$(35-16)/(T_{designc}-16)$	100	35	12/7	12/7	23/18
B	$(30-16)/(T_{designc}-16)$	74	30	a/7	a/8,5	a/18
C	$(25-16)/(T_{designc}-16)$	47	25	a/7	a/10	a/18
D	$(20-16)/(T_{designc}-16)$	21	20	a/7	a/11,5	a/18

^a With the water flow rate as determined during “A” test for units with a fixed water flow rate or with a fixed delta T of 5 K for units with a variable water flow rate.

4.5 Water-to-water and brine-to-water units

For each application, units either allowing or not allowing a variation of the outlet water temperature with the outdoor temperature are considered. The variable outlet temperature shall only be applied when the control provides a regulation of outlet water temperature that considers the outdoor temperature.

The part load conditions for determining the reference $SGUE_c$ (Formula (2)), $SAEF_c$ (Formula (4)), $SEHRE_{gas_c}$ (Formula (7)), $SEHRE_{elec_c}$ (Formula (8)) are given in the following table:

Table 4 — Part load conditions of water to-water units and brine to-water units in cooling mode

Part load ratio	Part load ratio %	Outdoor heat exchanger			Indoor heat exchanger			
		Cooling tower ^b application Inlet/outlet water temperatures °C	Ground coupled application (water or brine) Inlet/outlet water temperatures °C	Dry cooler application Inlet/outlet water temperatures °C	Fan coil application Inlet/outlet water temperatures		Cooling floor application Inlet/outlet water temperatures °C	
					Fixed outlet °C	Variable outlet °C		
A	(35-16) / (T _{designc-16})	100	30/35	10/15	50/45	12/7	12/7	23/18
B	(30-16) / (T _{designc-16})	74	26/ ^a	10/ ^a	45/ ^a	^a /7	^a /8,5	^a /18
C	(25-16) / (T _{designc-16})	47	22/ ^a	10/ ^a	40/ ^a	^a /7	^a /10	^a /18
D	(20-16) / (T _{designc-16})	21	18/ ^a	10/ ^a	35/ ^a	^a /7	^a /11,5	^a /18

^a With the water flow rate as determined during "A" test for units with a fixed water flow rate or with a fixed delta T of 5 K for units with a variable water flow rate.

^b If a cooling tower and water-to-air unit are sold as a matched assembly, they shall be tested as an air-to-air unit.

5 Part load conditions in heating mode

5.1 General

For the purpose of calculation of application $SGUE_h$, $SAEF_h$, $SEHRE_{gas,h}$, $SEHRE_{elec,h}$ and reference $SGUE_h$, $SAEF_h$, $SEHRE_{gas,h}$, $SEHRE_{elec,h}$ the part load ratios mentioned below should be based on the part load ratio Formulae (1st column of Tables 4 to 22) and not on the rounded figures as mentioned in the 2nd column of these tables. The calculation of $SGUE_h$, $SAEF_h$, $SEHRE_{gas,h}$, $SEHRE_{elec,h}$ and reference $SGUE_h$, $SAEF_h$, $SEHRE_{gas,h}$, $SEHRE_{elec,h}$ is determined via linear interpolation of the respective part load values at the reference part load conditions mentioned below (A, B, C, D). For the purpose of reference $SGUE_h$, $SAEF_h$, $SEHRE_{gas,h}$, $SEHRE_{elec,h}$ there are three reference conditions: average(A), warmer (W) and colder (C).

The relevant T_{design_h} values are defined as follows:

- T_{design} "average" dry bulb temperature conditions at -10 °C (-11 °C wet bulb) outdoor temperature and 20 °C indoor temperature;
- T_{design} "colder" dry bulb temperature conditions at -22 °C (-23 °C wet bulb) outdoor temperature and 20 °C indoor temperature
- T_{design} "warmer" dry bulb temperature conditions at +2 °C (1 °C wet bulb) outdoor temperature and 20 °C indoor temperature

EN 16905-5:2017 (E)

and the relevant $T_{bivalent}$ is defined as follows:

- for the average heating season, the dry bulb bivalent temperature is + 2 °C or lower;
- for the colder heating season, the dry bulb bivalent temperature is – 7 °C or lower;
- for the warmer heating season, the dry bulb bivalent temperature is + 7 °C or lower.

NOTE If the declared TOL is lower than the $T_{designh}$ of the considered climate, then it is assumed that TOL is equal to $T_{designh}$. For $T_{bivalent}$ and TOL higher or equal to – 7 °C the wet bulb temperature equals the dry bulb temperature minus 1 °C. For $T_{bivalent}$ and TOL below – 7 °C, the wet bulb temperature is not defined. At any other part load conditions, the declared capacity of the appliance is larger than the building load.

5.2 Air-to-air units

The part load conditions for determining the reference $SGUE_h$ (Formula (11)), $SAEF_h$ (Formula (13)), $SEHRE_{gas_h}$ (Formula (16)), $SEHRE_{elec_h}$ (Formula (17)) are given in the following tables:

Table 5 — Part load conditions of air-to-air units and air-cooled multisplit systems in heating mode for the reference heating season “A” = average

	A		Outdoor air dry bulb (wet bulb) temperatures °C	Indoor air dry bulb temperature °C
	Part load ratio	Part load ratio %		
A	$(-7-16)/(T_{designh}-16)$	88	-7(-8)	20
B	$(+2-16)/(T_{designh}-16)$	54	2(1)	20
C	$(+7-16)/(T_{designh}-16)$	35	7(6)	20
D	$(+12-16)/(T_{designh}-16)$	15	12(11)	20
E	$(TOL-16)/(T_{designh}-16)$		TOL	20
F	$(T_{bivalent}-16)/(T_{designh}-16)$		$T_{bivalent}$	20

Table 6 — Part load conditions of air-to-air units and air-cooled multisplit systems in heating mode for the reference heating season “W” = warmer

	W		Outdoor air dry bulb (wet bulb) temperatures °C	Indoor air dry bulb temperature °C
	Part load ratio	Part load ratio %		
A	(not applicable)			
B	$(+2-16)/(T_{\text{designh}}-16)$	100	2(1)	20
C	$(+7-16)/(T_{\text{designh}}-16)$	64	7(6)	20
D	$(+12-16)/(T_{\text{designh}}-16)$	29	12(11)	20
E	$(TOL-16)/(T_{\text{designh}}-16)$		TOL	20
F	$(T_{\text{bivalent}}-16)/(T_{\text{designh}}-16)$		Tbivalent	20

Table 7 — Part load conditions of air-to-air units and air-cooled multisplit systems in heating mode for the reference heating season “C” = colder

	C		Outdoor air dry bulb (wet bulb) temperatures °C	Indoor air dry bulb temperature °C
	Part load ratio	Part load ratio %		
A	$(-7-16)/(T_{\text{designh}}-16)$	61	-7(-8)	20
B	$(+2-16)/(T_{\text{designh}}-16)$	37	2(1)	20
C	$(+7-16)/(T_{\text{designh}}-16)$	24	7(6)	20
D	$(+12-16)/(T_{\text{designh}}-16)$	11	12(11)	20
E	$(TOL-16)/(T_{\text{designh}}-16)$		TOL	20
F	$(T_{\text{bivalent}}-16)/(T_{\text{designh}}-16)$		Tbivalent	20
G ^a	$(-15-16)/(T_{\text{designh}}-16)$	82	-15	20

^a Condition G is performed in case TOL is below -20 °C.

5.3 Water-to-air units and brine to air units

The part load conditions for determining the reference $SGUE_h$ (Formula (11)), $SAEF_h$ (Formula (13)), $SEHRE_{gas}_h$ (Formula (16)), $SEHRE_{elec}_h$ (Formula (17)) are given in the following tables:

Table 8 — Part load conditions of water-to-air and brine-to-air units in heating mode for the reference heating season “A” = average

A		Outdoor heat exchanger		Indoor heat exchanger	
Part load ratio	Part load ratio %	Ground water	Brine	Indoor air	
		Inlet/outlet temperatures °C	Inlet/outlet temperatures °C	Inlet dry bulb temperature °C	
A	$(-7-16)/(T_{designh}-16)$	88	10/a	0/a	20
B	$(+2-16)/(T_{designh}-16)$	54	10/a	0/a	20
C	$(+7-16)/(T_{designh}-16)$	35	10/a	0/a	20
D	$(+12-16)/(T_{designh}-16)$	15	10/a	0/a	20
F	$(T_{bivalent}-16)/(T_{designh}-16)$		10/a	0/a	20

^a The water flow rate as determined at the standard rating conditions.

SIST EN 16905-5:2018

Table 9 — Part load conditions of water-to-air and brine-to-air units in heating mode for the reference heating season “W” = warmer

W		Outdoor heat exchanger		Indoor heat exchanger	
Part load ratio	Part load ratio %	Ground water	Brine	Indoor air	
		Inlet/outlet temperatures °C	Inlet/outlet temperatures °C	Indoor temperatures dry bulb °C	
A	Not applicable				
B	$(+2-16)/(T_{designh}-16)$	100	10/a	0/a	20
C	$(+7-16)/(T_{designh}-16)$	64	10/a	0/a	20
D	$(+12-16)/(T_{designh}-16)$	29	10/a	0/a	20
F	$(T_{bivalent}-16)/(T_{designh}-16)$		10/a	0/a	20

^a The water flow rate as determined at the standard rating conditions of fixed capacity heat pumps.

Table 10 — Part load conditions of water-to-air and brine-to-air units in heating mode or the reference heating season “C” = colder

C		Outdoor heat exchanger		Indoor heat exchanger	
Part load ratio	Part load ratio %	Ground water	Brine	Indoor air	
		Inlet/outlet temperatures °C	Inlet/outlet temperatures °C	Indoor temperatures dry bulb °C	
A	$(-7-16)/(T_{designh}-16)$	61	10/a	0/a	20
B	$(+2-16)/(T_{designh}-16)$	37	10/a	0/a	20
C	$(+7-16)/(T_{designh}-16)$	24	10/a	0/a	20
D	$(+12-16)/(T_{designh}-16)$	11	10/a	0/a	20
F	$(T_{bivalent}-16)/(T_{designh}-16)$		10/a	0/a	20

^a The water flow rate as determined at the standard rating conditions of fixed capacity heat pumps.

5.4 Air-to-water units

(standards.iteh.ai)

5.4.1 General

SIST EN 16905-5:2018

For each application, units either allowing or not allowing a variation of the outlet water temperature with the outdoor temperature are considered. The variable outlet temperature shall only be applied when the control provides a regulation of outlet water temperature that considers the outdoor temperature.

The part load conditions for determining the reference $SGUE_h$ (Formula (11)), $SAEF_h$ (Formula (13)), $SEHRE_{gas_h}$ (Formula (16)), $SEHRE_{elec_h}$ (Formula (17)) are given in the following tables.