INTERNATIONAL STANDARD

ISO 6182-5

Second edition 2006-03-01

Fire protection — Automatic sprinkler systems —

Part 5:

Requirements and test methods for deluge valves

iTeh STANDARD PREVIEW

Protection contre l'incendie — Systèmes d'extinction automatiques de
(stype sprinkler — iteh.ai)

Partie 5: Exigences et méthodes d'essai des postes déluges

ISO 6182-5:2006

https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-7fccd786b6ac/iso-6182-5-2006



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO 6182-5:2006 https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-7fccd786b6ac/iso-6182-5-2006

© ISO 2006

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Cont	tents	Page
	ord	
Introdu	uction	v
1	Scope	1
2		
3	Terms and definitions	1
4	Requirements	4
5	Production testing and quality control	
6	Tests	
7	Marking	18
8	Instruction chart and trim	19

iTeh STANDARD PREVIEW (standards.iteh.ai)

 $\frac{ISO~6182\text{-}5\text{:}2006}{\text{https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-}} \\ \text{18cd-18cd-18c-6182-5-2006}$

ii

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6182-5 was prepared by Technical Committee ISO/TC 21, Equipment for fire protection and fire fighting, Subcommittee SC 5, Fixed firefighting systems using water.

This second edition cancels and replaces the first edition (ISO 6182-5:1995), which has been technically revised.

(standards.iteh.ai)

ISO 6182 consists of the following parts, under the general title *Fire protection — Automatic sprinkler systems*:

- Part 1: Requirements and test methods for sprinklers 7fccd786b6ac/iso-6182-5-2006
- Part 2: Requirements and test methods for wet alarm valves, retard chambers and water motor alarms
- Part 3: Requirements and test methods for dry pipe valves
- Part 4: Requirements and test methods for quick-opening devices
- Part 5: Requirements and test methods for deluge valves
- Part 6: Requirements and test methods for check valves
- Part 7: Requirements and test methods for early suppression fast response (ESFR) sprinklers
- Part 8: Requirements and test methods for pre-action dry alarm valves
- Part 9: Requirements and test methods for water mist nozzles
- Part 10: Requirements and test methods for domestic sprinklers
- Part 11: Requirements and test methods for pipe hangers
- Part 12: Requirements and test methods for grooved end pipe couplings
- Part 13: Requirements and test methods for extended coverage sprinklers

Introduction

This part of ISO 6182 is one of a number of ISO International Standards prepared by ISO/TC 21 covering components for automatic sprinkler systems, including the following:

- a) carbon dioxide systems (ISO 6183),
- b) explosion suppression systems (ISO 6184),

An International Standard covering foam systems is planned.

iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO 6182-5:2006 https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-7fccd786b6ac/iso-6182-5-2006

iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO 6182-5:2006

https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-7fccd786b6ac/iso-6182-5-2006

Fire protection — Automatic sprinkler systems —

Part 5:

Requirements and test methods for deluge valves

1 Scope

This part of ISO 6182 specifies performance requirements, methods of test and marking requirements for deluge valves and manufacturers' specified relevant trim used in deluge and pre-action automatic fire protection systems. Deluge valves covered by these requirements can be operated by hydraulic, pneumatic, electric, mechanical, manual, or thermal means or combinations thereof.

Performance and test requirements for other auxiliary components or attachments to deluge valves are not covered by this part of ISO 6182.

This part of ISO 6182 does not cover thermally operated valves released by heat acting directly on the valve. This type of valve utilizes a thermal device, such as the link-and-lever arrangement or glass bulb of a sprinkler, to hold the valve closed. Operation of the thermal device allows the valve to open.

2 Normative references ISO 6182-5:2006 https://standards.itch.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7-1, Pipe threads where pressure-tight joints are made on the threads — Part 1: Designation, dimensions and tolerances

ISO 37, Rubber, vulcanized or thermoplastic — Determination of tensile stress-strain properties

ISO 188, Rubber, vulcanized or thermoplastic — Accelerated aging and heat resistance tests

ISO 898–1, Mechanical properties of fasteners made of carbon steel and alloy steel — Part 1: Bolts, screws and studs

ISO 898–2, Mechanical properties of fasteners — Part 2: Nuts with specified proof load values — Coarse thread

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

alarm device

mechanical or electrical device to sound an alarm upon operation of the valve

3.2

anti-reseat latch

mechanism that prevents the sealing assembly from returning to its closed position after operation

3.3

automatic drain valve

normally open device that automatically drains water from and vents the intermediate chamber of a valve to the atmosphere when the valve is in the ready position, and limits water flow from the chamber after the valve has tripped

3.4

auxiliary pressure

pressure acting against an auxiliary diaphragm or piston, taken from either the service pressure or an external source

3.5

clapper

type of sealing element

NOTE See 3.19.

3.6

corrosion-resistant material

metallic material of bronze, brass, Monel¹⁾ metal, austenitic stainless steel, or equivalent, or plastic material conforming with the requirements of this document

iTeh STANDARD PREVIEW

3.7

deluge system

(standards.iteh.ai)

automatic fire protection system using a deluge valve which is operated by an auxiliary means to admit water into a system of non-automatic (open) sprinklers or nozzles

3.8

https://standards.iteh.ai/catalog/standards/sist/c8b9318e-d9c5-415c-87bf-

7fccd786b6ac/iso-6182-5-2006

deluge valve

automatic water-supply control valve intended to be operated by an auxiliary means to admit water into a system of open piping for a deluge system, or system of closed piping for a pre-action system

NOTE The auxiliary means of operating a deluge valve can be mechanical, electrical, hydraulic, pneumatic, thermal, manual or a combination of these.

3.8.1

hydraulically operated deluge valve

deluge valve that is maintained in the set position by service hydraulic pressure acting against a diaphragm or piston that holds the sealing assembly closed

NOTE A change in pressure against the diaphragm or piston allows the valve to open. The pressure is changed by operation of a manual control, an electrical device such as solenoid valve, or hydraulically, thermally, or pneumatically operated device.

3.8.1.1

pressure-loss operated deluge valve

type of hydraulically operated deluge valve in which the valve is released from the set position by reducing the pressure acting against an auxiliary diaphragm or piston

¹⁾ Monel is an example of a suitable product available commercially. This information is given for the convenience of users of this part of ISO 6182 and does not constitute an endorsement by ISO of this product.

3.8.1.2

supply-pressure operated deluge valve

type of hydraulically-operated deluge valve that is maintained in the set position by a spring or other means and is hydraulically operated by the application of service pressure to an auxiliary diaphragm or piston

3.8.2

mechanically operated deluge valve

deluge valve that is maintained in the set position by a mechanical means

NOTE It is released mechanically, for example, by the action of a release weight.

3.9

dry pilot actuator

differential-type valve that, upon loss of pneumatic pressure from a dry pilot line, permits the operation of a hydraulically operated deluge valve

3.10

dry pilot line

pneumatic detection and actuation piping system fitted with heat responsive devices, usually sprinklers, which, when subjected to an abnormal source of heat, operates to release pressure from the piping system and dry pilot actuator, causing the automatic operation of a deluge valve

3.11

flow velocity

speed of water flow through a valve, expressed as the equivalent water velocity through a pipe of the same nominal size as the valve reh STANDARD PREVIEW

3.12 (standards.iteh.ai)

intermediate chamber

that part of a valve which separates the air and/or water sealing assembly seating surfaces and is at atmospheric pressure when the valve is in the ready condition

7fccd786b6ac/iso-6182-5-2006

3.13 leak point

system air pressure for a specific service pressure at which water begins to flow from the intermediate chamber, automatic drain valve or alarm connection

3.14

pre-action system

automatic fire protection system using a valve that is operated by an auxiliary means to admit water into a system of automatic sprinklers or nozzles

3.15

priming water

water used to seal a sealing assembly and prevent cementation of working parts

3.16

rated working pressure

maximum service pressure at which a valve or retard chamber is intended to operate

3.17

ready condition

set condition

state of a valve with the sealing assembly in the closed and set position with service and system pressure applied

3.18

reinforced elastomeric element

element of clapper, clapper assembly or seat seals in a composite of an elastomeric compound with one or more other components

3.19

sealing assembly

main movable sealing element (such as a clapper) of the valve, which prevents the reverse flow of water and which maintains air pressure in the system piping

3.20

sealing assembly seat ring

main fixed sealing element of a valve that prevents the reverse flow of water and which maintains air pressure in the system piping

3.21

service pressure

static water pressure at the inlet to a valve when the valve is in the ready condition

3.22

trim

external equipment and pipework, excluding the main installation pipework, fitted to valve installation assembly

3.23

trip point

point at which a valve operates, admitting water into the system, measured in terms of the system air pressure at a given service pressure

3.24

water-motor alarm

Teh STANDARD PREVIEW hydraulically actuated device which provides a local audible alarm as a result of a flow through a valve

3.25

water-motor transmitter

hydraulically actuated device which generates an electrical current for a remote alarm as a result of operation of the valve 7fccd786b6ac/iso-6182-5-2006

(standards.iteh.ai)

3.26

wet pilot line

hydraulic detection and actuation piping system fitted with heat responsive devices, usually automatic sprinklers, which, when subjected to heat from a fire, operate to release pressure from the piping system causing the automatic operation of a deluge valve

Requirements

Nominal sizes 4.1

The nominal size of a valve shall be the nominal diameter of the inlet and outlet connections, i.e. the pipe size for which the connections are intended. The sizes shall be 40 mm, 50 mm, 65 mm, 80 mm, 100 mm, 125 mm, 150 mm, 200 mm, 250 mm or 300 mm. The diameter of the waterway through the sealing assembly seat ring may be less than the nominal size.

4.2 Connections

- 4.2.1 All connections shall be designed for use at the rated working pressure of the valve.
- The dimensions of all connections shall conform with the applicable requirements of International Standards. If International Standards are not applicable, national standards shall be permitted to be used.
- 4.2.3 An opening not smaller than 15 mm nominal diameter shall be provided for an alarm line connection.

- **4.2.4** If priming water is required to seal the downstream side of the sealing assembly, an external means shall be provided to introduce the priming water.
- **4.2.5** Means shall be provided to prevent water columning and to check the level of priming water (if required).
- **4.2.6** Suitable means shall be provided to facilitate testing of alarms without tripping the valve.
- **4.2.7** Valves shall be provided with a means of sounding an alarm if water enters the downstream piping to an elevation exceeding 0,5 m above the sealing assembly unless the valve is provided with an automatic means for drainage.

4.3 Rated working pressure

- **4.3.1** The rated working pressure shall be not less than 1,2 MPa (12 bar).
- **4.3.2** Inlet and outlet connections may be machined for lower working pressures to match installation equipment provided the valve is marked with the lower working pressure. See 7.3 f).

4.4 Body and cover

- **4.4.1** The body and cover shall be made of a material having corrosion resistance at least equivalent to cast iron.
- **4.4.2** Cover fasteners shall be made of steel, stainless steel, titanium, or other materials with equivalent physical and mechanical properties.

 (Standards iteh. a)
- **4.4.3** If non-metallic materials other than gaskets and seals or metals with a melting point less than 800 °C form part of the body or cover, the valve assembly shall be subjected to a fire exposure test as specified in 6.9. Following the fire exposure test, the sealing assembly shall open freely and fully and the valve shall withstand a hydrostatic pressure test as specified in 6.7.1 without permanent deformation or failure.
- **4.4.4** It shall not be possible to assemble the valve with the cover plate in a position which either improperly indicates flow direction or prevents proper operation of the valve.

4.5 Strength

- **4.5.1** An assembled valve, with the sealing assembly blocked open, shall withstand, without rupture, an internal hydrostatic pressure of four times the rated working pressure for a period of 5 min when tested as specified in 6.8.
- **4.5.2** If the test in accordance with 6.9 is not done with standard production fasteners, the supplier shall provide documentation showing that the calculated design load of any fastener, neglecting the force required to compress the gasket, shall not exceed the minimum tensile strength specified in ISO 898-1 and ISO 898-2, when the valve is pressurized to four times the rated working pressure. The area of the application of pressure shall be calculated as follows.
- a) If a full-face gasket is used, the area of application of pressure is that extending out to a line defined by the inner edge of the bolts.
- b) If an "O"-ring seal or ring gasket is used, the area of application of force is that extending out to the centreline of the "O"-ring or gasket.

4.6 Access for maintenance

Means shall be provided to permit access to working parts and removal of the sealing assembly. Any method adopted shall permit ready maintenance by one person with a minimum of down time.

© ISO 2006 – All rights reserved