

## SLOVENSKI STANDARD SIST EN 12671:2016

01-julij-2016

Nadomešča:

**SIST EN 12671:2009** 

# Kemikalije, ki se uporabljajo za pripravo pitne vode - Klorov dioksid, proizveden na kraju samem

Chemicals used for treatment of water intended for human consumption - Chlorine dioxide generated in situ

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Vor Ort erzeugtes Chlordioxid (standards.iteh.ai)

Produits chimiques utilisés pour le traitement de l'eau destinée à la consommation humaine - Dioxyde de chlore généréain situadards/sist/8c3e4253-2b19-4818-8629-0e825da8cee5/sist-en-12671-2016

Ta slovenski standard je istoveten z: EN 12671:2016

ICS:

13.060.20 Pitna voda Drinking water

71.100.80 Kemikalije za čiščenje vode Chemicals for purification of

water

SIST EN 12671:2016 en,fr,de

**SIST EN 12671:2016** 

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 12671:2016

https://standards.iteh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8629-0e825da8cee5/sist-en-12671-2016

**EUROPEAN STANDARD** 

EN 12671

NORME EUROPÉENNE

**EUROPÄISCHE NORM** 

May 2016

ICS 71.100.80

Supersedes EN 12671:2009

#### **English Version**

# Chemicals used for treatment of water intended for human consumption - Chlorine dioxide generated in situ

Produits chimiques utilisés pour le traitement de l'eau destinée à la consommation humaine - Dioxyde de chlore généré in situ Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Vor Ort erzeugtes Chlordioxid

This European Standard was approved by CEN on 18 March 2016.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovania, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

0e825da8cee5/sist-en-12671-2016



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

#### EN 12671:2016 (E)

Conte	ents	Page
Europ	ean foreword	4
Introd	uction	5
1	Scope	6
2	Normative references	6
2	Description	6
3.1	Identification	
3.1.1	Chemical name	_
3.1.2	Synonym or common name	
3.1.3	Relative molecular mass	
3.1.4	Empirical formula	
3.1.5	Chemical formula	
3.1.6	CAS Registry Number	6
3.1.7	EINECS reference	6
3.2	Presentation form	7
3.3	Physical properties	7
3.3.1	Appearance	7
3.3.2	AppearanceDensity	7
3.3.3	Solubility in water (standards.itch.ai) Vapour pressure	7
3.3.4	Vapour pressure	7
3.3.5	Boiling point at 101,3 kPaSISTEN 126/12016	8
3.3.6	Crystallization point.	8
3.3.7	Specific heat	8
3.3.8	Viscosity (dynamic)	8
3.3.9	Critical temperature	8
3.3.10	Critical pressure	8
	Physical hardness	
3.3.12	Dissolution heat	8
3.4	Chemical properties	8
4	Purity criteria	Q
<del>1</del> 4.1	General	
4.2	Composition of <i>in situ</i> generated product	
4.3	Impurities and main by-products	
4.4	Chemical parameters	
5	Test methods	10
5.1	Sampling	
5.2	Determination of chlorine dioxide and chlorite concentrations	
5.2.1	General	
5.2.2	Principle	
5.2.3	Reagents	
5.2.4	Apparatus	
5.2.5	Procedure	
5.2.6	Expression of results	
6	Labelling, distribution and storage	13
6.1	Labelling according to the EU legislation	

6.2	Means of distribution	_
6.3	Storage, stability	15
Annex	A (informative) General information on chlorine dioxide	16
<b>A.1</b>	Origin	16
A.1.1	Raw materials	16
A.1.2	Manufacturing process	16
<b>A.2</b>	Use	17
A.2.1	Function	17
A.2.2	Form in which it is used	17
A.2.3	Treatment dose	17
A.2.4	Means of application	17
A.2.5	Secondary effects	17
A.2.6	Removal of excess product	
A.3	Spectrometric method for specific determination of CIO <sub>2</sub>	17
A.3.1	Principle	17
A.3.2	Reagents	18
A.3.3	Apparatus	18
A.3.4	Procedure	19
A.3.5	Precision	20
A.3.6	Specificity	20
<b>A.4</b>	Determination of chlorite and chlorate ions contents in aqueous chlorine dioxide as	
	produced by the reactors	20
A.4.1	General Tob STANDARD DREVIEW	
A.4.2	Sample collection and preparation	20
A.4.3	Sample collection and preparation	20
A.4.4	Reagents	
A.4.5	ApparatusSIST EN 126712016	
A.4.6	Procedure https://standards.itelh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8629-	
A.4.7	Expression of results 0e825da8cee5/sist-en-12671-2016	22
<b>A.4.8</b>	Detection limit	22
Annay	B (normative) General rules relating to safety	23
B.1	Rules for safe handling and use	
B.2	Emergency procedures	
B.2.1	First aid	
B.2.2	Spillage	
B.2.3	Fire	
Biblio	graphy	24

#### **European foreword**

This document (EN 12671:2016) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2016, and conflicting national standards shall be withdrawn at the latest by November 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12671:2009.

Significant technical differences between this edition and EN 12671:2009 are as follows:

- a) deletion of reference to EU Directive 67/548/EEC of June 27, 1967 in order to take into account the latest Regulation in force (see [3]);
- b) Subclause 6.2 updating of risk and safety labelling according to EU Regulation [3] and its latest Adaptations to Technical Progress TANDARD PREVIEW

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Iteland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Sloyakia, Sloyenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

#### Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this document:

- 1) this document provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- 2) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

NOTE 1 Conformity with this standard does not confer or imply acceptance or approval of the product in any of the Member States of the EU or EFTA. The use of the product covered by this document is subject to regulation or control by National Authorities.

NOTE 2 This product is a biocide and needs to comply with the relevant legislation in force. In the European Union, at the time of publication, this legislation is REGULATION (EU) No 528/2012 [2]).

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 12671:2016 https://standards.iteh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8629-0e825da8cee5/sist-en-12671-2016

#### EN 12671:2016 (E)

#### 1 Scope

This European Standard is applicable to chlorine dioxide generated on site for treatment of water intended for human consumption. It describes the characteristics for chlorine dioxide and specifies the composition and the corresponding test methods for chlorine dioxide. It gives information on its use in water treatment. It also determines the rules relating to safe handling and use of chlorine dioxide generated on site (see Annex B).

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 3696, Water for analytical laboratory use — Specification and test methods (ISO 3696)

ISO 3165, Sampling of chemical products for industrial use — Safety in sampling

ISO 6206, Chemical products for industrial use — Sampling — Vocabulary

#### 3 Description

3.1 Identification

#### 3.1.1 Chemical name

iTeh STANDARD PREVIEW (standards.iteh.ai)

Chlorine dioxide.

3.1.2 Synonym or common name

SIST EN 12671:2016

https://standards.iteh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8629-0e825da8cee5/sist-en-12671-2016

3.1.3 Relative molecular mass

67,46.

None.

3.1.4 Empirical formula

 $ClO_2$ .

3.1.5 Chemical formula

0- Cl - 0 (resonance structure).

3.1.6 CAS Registry Number 1)

10049-04-4.

3.1.7 EINECS reference 2)

233-162-8.

6

<sup>1)</sup> Chemical Abstracts Service Registry Number.

<sup>2)</sup> European Inventory of Existing Commercial Chemical Substances.

#### 3.2 Presentation form

For water treatment, chlorine dioxide is generated *in situ* as an aqueous solution on or near the site of use and transferred to the site of use.

#### 3.3 Physical properties

#### 3.3.1 Appearance

The pure product is an orange gas or liquid, which forms a yellow solution in water.

NOTE If the solution becomes red-brown, it is a sign of decomposition.

#### 3.3.2 Density

Gas:  $3{,}09 \text{ g/l}$ ,  $(2{,}4 \text{ g/l relative}, \text{air} = 1)$  at 273 K and 101,3 kPa  $^{3)}$ .

Liquid: 1,64 g/ml at 20 °C.

#### 3.3.3 Solubility in water

In Table 1 the solubility values (S) for chlorine dioxide are given in grams per cubic meter  $(g/m^3)$  water at a pressure of 101,3 kPa for different temperatures:

Temperature of water 0 2016  $70 \pm 0.7$ **SIST EN 1267** https://standards.iteh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8660,3) 0e825da8cee5/sist-en-12671-2016 10 (53,7)15 45 20 (42,7)25 (33)30 (30,1)35  $26,5 \pm 0,8$ NOTE 1 S is a ratio, not an absolute value of concentration. NOTE 2 The S values are directly measured values except those in brackets which are extrapolated data.

Table 1 — Solubility values

#### 3.3.4 Vapour pressure

The vapour pressure of pure chlorine dioxide as a function of temperature is given in Table 2.

<sup>3) 100</sup> kPa = 1 bar.

#### EN 12671:2016 (E)

Table 2 — Vapour pressure of pure chlorine dioxide

<b>Temperature</b> [C°]	<b>Vapour pressure</b> [kPa]
0	82,3
5	90,4
10	98,8
11	100,5
20	116,5 (extrapolated)
25	125,8 (extrapolated)
30	135,3 (extrapolated)
35	145,1 (extrapolated)
40	155,0 (extrapolated)

#### 3.3.5 Boiling point at 101,3 kPa 4)

11 °C (for pure chlorine dioxide).

#### 3.3.6 Crystallization point

- 59 °C (for pure chlorine dioxide).

#### 3.3.7 Specific heat

### iTeh STANDARD PREVIEW

The specific heat of solutions of chlorine dioxide is very similar to that of pure water.

#### 3.3.8 Viscosity (dynamic)

SIST EN 12671:2016

https://standards.iteh.ai/catalog/standards/sist/8c3e4253-2b19-4818-8629-The dynamic viscosity of solutions of chloring-dioxide is very similar to that of pure water.

#### 3.3.9 Critical temperature

153 °C (for pure chlorine dioxide).

#### 3.3.10 Critical pressure

Not applicable.

#### 3.3.11 Physical hardness

Not applicable.

#### 3.3.12 Dissolution heat

The heat of the dissolution in water is – 26,8 kJ/mol (exothermic).

#### 3.4 Chemical properties

Chlorine dioxide is a molecule containing an unpaired electron and has the characteristics of a "molecule-free-radical". Relevant Redox potentials of chlorine dioxide and related molecules are ( $E_0$  values at 25 °C in volts):

8

<sup>4) 100</sup> kPa = 1 bar.

$HCIO_2 + 3H^+ + 4e^-$	$\Rightarrow$ CI <sup>-</sup> + 2H <sub>2</sub> O	$E_0 = 1,57 \text{ V}$
CIO <sub>2</sub> (dissolved gas) + 1e <sup>-</sup>	$\Rightarrow$ CIO <sub>2</sub> -	$E_0 = 1,15 \text{ V}$
$CIO_3^- + 1e^- + 2H^+$	$\Rightarrow$ ClO <sub>2</sub> + H <sub>2</sub> O	$E_0 = 1,15 \text{ V}$
ClO <sub>2</sub> (dissolved liquid) + 1e <sup>-</sup>	$\Rightarrow$ CIO <sub>2</sub> -	$E_0 = 0.95 \text{ V}$
CIO <sub>2</sub> - + 4e-+ 4 H+	$\Rightarrow$ CI <sup>-</sup> + 2H <sub>2</sub> O	$E_0 = 0.78 \text{ V}$

#### 4 Purity criteria

#### 4.1 General

This European Standard specifies the minimum purity requirements for chlorine dioxide generated *in situ* used for the treatment of water intended for human consumption. Limits are given for impurities commonly present in the product. Depending on the raw material and the manufacturing process, other impurities may be present and, if so, this shall be notified to the user and when necessary to relevant authorities.

Users of this product should check the national regulations in order to clarify whether it is of appropriate purity for treatment of water intended for human consumption, taking into account raw water quality, required dosage, contents of other impurities and additives used in the product not stated in this product standard.

Limits have been given for impurities and chemical parameters where these are likely to be present in significant quantities from the current production process and raw materials. If the production process or raw materials lead to significant quantities of impurities, by-products or additives being present, this shall be notified to the user.

SIST EN 12671:2016

## **4.2 Composition** of in situ generated products/8c3e4253-2b19-4818-8629-

Chlorine dioxide ( $ClO_2$ ) is produced as aqueous solution on or near the site of use. For safety reasons the aqueous  $ClO_2$  solution without intermediate storage in a storage tank (i.e. without headspace) shall not exceed a concentration of 20 g/l.

The concentration of the aqueous  $ClO_2$  solution with intermediate storage in a storage tank (i.e. with headspace) should not exceed a concentration of 3 g/l, to ensure an adequate distance to the explosion limit (see B.1).

#### 4.3 Impurities and main by-products

Impurities and main by-products of the starting products used for the generation (indicated in A.1.1) can be found in the *in situ* generated product in respective proportional concentrations.

Inadequate design, operation and maintenance of reactors can give rise to the formation of chlorine and traces of chlorate ion and, eventually, the presence of unreacted chlorite, chlorate and/or chlorine (see [6]); for analysis see 5.2 and A.4.

#### 4.4 Chemical parameters

NOTE For the purpose of this standard, "chemical parameters" are those defined in the EU Directive 98/83/EC of 3 November 1998 (see [1]).

Limits of chemical parameters being potentially present in chlorine dioxide solution have been specified in the corresponding EN standards of the starting products (indicated in A.1.1).