



SLOVENSKI STANDARD

kSIST FprEN 12876:2014

01-september-2014

Kemikalije, ki se uporabljajo za pripravo pitne vode - Kisik

Chemicals used for treatment of water intended for human consumption - Oxygen

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Sauerstoff

Produits chimiques utilisés pour le traitement d'eau destinée à la consommation humaine
- Oxygène

Ta slovenski standard je istoveten z: FprEN 12876

ICS:

13.060.20	Pitna voda	Drinking water
71.100.80	Kemikalije za čiščenje vode	Chemicals for purification of water

kSIST FprEN 12876:2014

en,fr,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

FINAL DRAFT
FprEN 12876

June 2014

ICS 71.100.80

Will supersede EN 12876:2009

English Version

Chemicals used for treatment of water intended for human consumption - Oxygen

Produits chimiques utilisés pour le traitement d'eau destinée à la consommation humaine - Oxygène

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Sauerstoff

This draft European Standard is submitted to CEN members for unique acceptance procedure. It has been drawn up by the Technical Committee CEN/TC 164.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
Foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Description	6
3.1 Identification.....	6
3.1.1 Chemical name.....	6
3.1.2 Synonym or common name.....	6
3.1.3 Relative molecular mass.....	6
3.1.4 Empirical formula.....	6
3.1.5 Chemical formula.....	6
3.1.6 CAS Registry Number	6
3.1.7 EINECS reference	6
3.2 Commercial forms	6
3.3 Physical properties.....	7
3.3.1 Appearance, odour and taste	7
3.3.2 Density	7
3.3.3 Solubility of pure oxygen (in water).....	7
3.3.4 Vapour pressure	7
3.3.5 Boiling point at 100 kPa	7
3.3.6 Melting point.....	7
3.3.7 Specific heat.....	7
3.3.8 Viscosity (dynamic)	7
3.3.9 Critical temperature	7
3.3.10 Critical pressure.....	7
3.3.11 Physical hardness	8
3.4 Chemical properties	8
4 Purity criteria.....	8
4.1 General.....	8
4.2 Composition of commercial product.....	8
4.3 Impurities and main by-products	8
4.4 Chemical parameters	8
5 Test methods.....	9
5.1 Sampling.....	9
5.2 Analyses	9
5.2.1 Main product	9
5.2.2 Impurities.....	11
6 Labelling - Transportation - Storage.....	11
6.1 Means of delivery.....	11
6.2 Labelling according to the EU legislation	11
6.3 Transportation regulations and labelling	12
6.4 Marking	13
6.5 Storage.....	13
6.5.1 Containers	13
6.5.2 Long term stability.....	13
6.5.3 Storage incompatibilities	13
Annex A (informative) General information on oxygen.....	14
A.1 Origin	14
A.1.1 Raw materials.....	14
A.1.2 Manufacturing process	14

A.2	Use	14
A.2.1	Function.....	14
A.2.2	Form in which it is used.....	14
A.2.3	Treatment dose.....	14
A.2.4	Means of application	14
A.2.5	Secondary effects.....	14
A.2.6	Removal of excess product.....	14
A.3	Monitoring of oxygen	14
A.3.1	Chromatographic method.....	14
A.3.2	Oxymeters based on electrochemical cells.....	15
A.3.3	Other methods	15
Annex B (normative)	General rules relating to safety	16
B.1	Rules for safe handling and use	16
B.2	Emergency procedures.....	16
B.2.1	First aid.....	16
B.2.2	Leaks.....	16
B.2.3	Fire	16
Annex C (normative)	Determination of hydrocarbons content (Methane Index).....	17
C.1	General	17
C.2	Principle.....	17
C.3	Apparatus	17
C.4	Calibration	17
C.5	Procedure.....	17
C.6	Accuracy.....	17
Bibliography	18

(standards.iteh.ai)

SIST EN 12876:2015

<https://standards.iteh.ai/catalog/standards/sist/92bff477-3d25-4e61-b6c3-444269a10ef1/sist-en-12876-2015>

FprEN 12876:2014 (E)**Foreword**

This document (FprEN 12876:2014) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This document is currently submitted to the Unique Acceptance Procedure.

This document will supersede EN 12876:2009.

Significant technical difference between this edition and EN 12876:2009 is as follows:

- a) deletion of reference to EU Directive 67/548/EEC of June 27, 1967 in order to take into account the latest Regulation in force (see [3]).
- b) clause 6.2 – updating of risk and safety labelling according to EU Regulation [3] and its latest Adaptations to Technical Progress):

Annex A is informative.

Annexes B and C are normative.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12876:2015

<https://standards.iteh.ai/catalog/standards/sist/92bff477-3d25-4e61-b6c3-444269a10ef1/sist-en-12876-2015>

Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this European Standard:

- a) This European Standard provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- b) It should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

NOTE Conformity with the standard does not confer or imply acceptance or approval of the product in any of the Member States of the EU or EFTA. The use of the product covered by this European Standard is subject to regulation or control by National Authorities.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12876:2015

<https://standards.iteh.ai/catalog/standards/sist/92bff477-3d25-4e61-b6c3-444269a10ef1/sist-en-12876-2015>

FprEN 12876:2014 (E)**1 Scope**

This European Standard is applicable to oxygen used for treatment of water intended for human consumption. It describes the characteristics of oxygen and specifies the requirements and the corresponding test methods for oxygen. It gives information on its use in water treatment.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1089-3, *Transportable gas cylinders - Gas cylinder identification (excluding LPG) - Part 3: Colour coding.*

3 Description**3.1 Identification****3.1.1 Chemical name**

Oxygen.

3.1.2 Synonym or common name

None.

3.1.3 Relative molecular mass

32,00

3.1.4 Empirical formula

O₂

3.1.5 Chemical formula

O = O

3.1.6 CAS Registry Number¹⁾

7782-44-7

3.1.7 EINECS reference²⁾

231-956-9

3.2 Commercial forms

Gas or cryogenic liquid.

¹⁾ Chemical Abstract Service Registry Number.

²⁾ European Inventory of Existing Commercial Chemical Substances.

3.3 Physical properties

3.3.1 Appearance, odour and taste

The product is a colourless, odourless, tasteless gas or a bluish liquid.

3.3.2 Density

- Liquid: 1,141 g/ml at -183 °C.
- Gas: 1,337 g/dm³ at 15 °C and 101,3 kPa ³⁾.

3.3.3 Solubility of pure oxygen (in water)

The solubility of oxygen at a pressure of 101,3 kPa ³⁾ in pure water, depending on the temperature, is:

- a) 61 mg/l at 5 °C;
- b) 45 mg/l at 15 °C;
- c) 36 mg/l at 25 °C.

3.3.4 Vapour pressure

Oxygen is a gas at 273,15 K and 101,3 kPa.

3.3.5 Boiling point at 100 kPa ³⁾

- 182,97 °C.

3.3.6 Melting point

Not applicable.

3.3.7 Specific heat

At a constant pressure 100 kPa:

- 919 J/(kgxK) at 15 °C;
- 920 J/(kgxK) at 25 °C.

3.3.8 Viscosity (dynamic)

2,0720 x 10⁻² mPaxs at 100 kPa and 27 °C.

3.3.9 Critical temperature

118,6 °C.

3.3.10 Critical pressure

5 043 kPa

³⁾ 100 kPa = 1 bar.

FprEN 12876:2014 (E)

3.3.11 Physical hardness

Not applicable.

3.4 Chemical properties

Oxygen is an oxidizing agent and a supporter of combustion. Dangerous reactions are possible with organic compounds and other combustible substances.

NOTE Oxygen-rich atmospheres (a volume fraction higher than 25 % of oxygen) increase the rate of combustion which can lead to explosive reactions.

4 Purity criteria

4.1 General

This European Standard specifies the minimum purity requirements for oxygen used for the treatment of water intended for human consumption. Limits are given for impurities commonly present in the product. Depending on the raw material and the manufacturing process other impurities may be present and, if so, this shall be notified to the user and when necessary to relevant authorities.

Users of this product should check the national regulations in order to clarify whether it is of appropriate purity for treatment of water intended for human consumption, taking into account raw water quality, required dosage, contents of other impurities and additives used in the product not stated in the product standard.

Limits have been given for impurities and chemicals parameters where these are likely to be present in significant quantities from the current production process and raw materials. If the production process or raw materials lead(s) to significant quantities of impurities, by-products or additives being present, this shall be notified to the user.

4.2 Composition of commercial product

Two grades of oxygen exist varying from the manufacturing process:

Grade A for cryogenically derived oxygen, the minimum concentration of oxygen shall be a volume fraction of 99,5 %.

Grade B for oxygen manufactured with non cryogenic methods, the minimum concentration of oxygen shall be a volume fraction of 90 %.

4.3 Impurities and main by-products

The hydrocarbons content (as Methane Index) shall not exceed a volume fraction of 50 ppm.

NOTE Depending on the production route, the product can contain quantities of water, nitrogen, argon, carbon dioxide and other rare gases which do not affect its use in water treatment.

4.4 Chemical parameters

NOTE For the purpose of this standard, "chemical parameters" are those defined in the EU Directive 98/83/EC of 03 November 1998 (see [2]).

Commercial oxygen does not contain significant levels of chemical parameters.

5 Test methods

5.1 Sampling

All or part of the gas flow is sent through the analyzer. Sample in a volumetric pipette of a few litres with a positive pressure from 150 kPa to 200 kPa or with an automatic sampler.

When sampling gaseous oxygen the following shall apply:

- sample lines and ancillary equipment shall be compatible with use with oxygen, be clean, leak tight and have the appropriate pressure rating to deliver the sample safely and without contamination to the analyzer;
- the sample taken shall be representative and apparatus shall be operated in accordance with the manufacturer's recommended operating procedures.

NOTE Flow rates to the analyzer can require precise control, following pressure regulation, if automatic flow control devices are not an integral part of the measurement system.

5.2 Analyses

5.2.1 Main product

5.2.1.1 General

The most commonly used method of oxygen content measurement is the paramagnetic method. This method has an accuracy of $\pm 0,01$ % volume fraction.

5.2.1.2 Principle

Magneto-dynamic oxygen analyzers are based on Faraday's principle of determining the magnetic susceptibility of a gas by measuring the force developed by a strong non-uniform magnetic field on a diamagnetic test body suspended in the sample gas. The test body of all measuring cells in paramagnetic oxygen analyzers consists of two nitrogen-filled quartz spheres arranged in the form of a dumb-bell, as shown in Figure 1. A single turn of fine platinum wire (the feedback coil) is secured in place around the dumb-bell. A rugged, taut band platinum ribbon suspension attached to the mid-point of the dumb-bell positions the dumb-bell in the strong non-uniform magnetic field existing between the specially shaped pole pieces of the permanent magnetic structure (see Figure 2).

5.2.1.3 Apparatus

A variety of analytical equipment suppliers provides simple, ready to run portable units for this purpose, which may be powered either by battery or mains electricity.

Figure 3 illustrates the configuration of a typical analyser designed for this purpose.