

SLOVENSKI STANDARD

SIST EN 12831-1:2018

01-maj-2018

Nadomešča:
SIST EN 12831:2004

Energijske lastnosti stavb - Metoda za izračun projektnih toplotnih obremenitev - 1. del: Toplotne obremenitve prostora - Modul M3-3

Energy performance of buildings - Method for calculation of the design heat load - Part 1:
Space heating load, Module M3-3

Energetische Bewertung von Gebäuden - Verfahren zur Berechnung der Norm-Heizlast -
Teil 1: Raumheizlast, Modul M3-3

Performance énergétique des bâtiments - Méthode de calcul de la charge thermique
nominale - Partie 1 : Charge de chauffage des locaux, module M3-3

Ta slovenski standard je istoveten z: EN 12831-1:2017

ICS:

91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings
91.140.10	Sistemi centralnega ogrevanja	Central heating systems

SIST EN 12831-1:2018 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12831-1:2018

<https://standards.iteh.ai/catalog/standards/sist/c45be024-9a24-451b-9950-1148c9f3589d/sist-en-12831-1-2018>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 12831-1

July 2017

ICS 91.140.10

Supersedes EN 12831:2003

English Version

Energy performance of buildings - Method for calculation of the design heat load - Part 1: Space heating load, Module M3-3

Performance énergétique des bâtiments - Méthode de
calcul de la charge thermique nominale - Partie 1 :
Charge de chauffage des locaux, module M3-3

Energetische Bewertung von Gebäuden - Verfahren zur
Berechnung der Norm-Heizlast - Teil 1: Raumheizlast,
Modul M3-3

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

iTeh STANDARD PREVIEW

(standards.itih.eu)
This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	5
Introduction	6
1 Scope.....	8
2 Normative references.....	12
3 Terms and definitions	12
4 Symbols and abbreviations	15
4.1 Symbols.....	15
4.2 Subscripts.....	16
5 Description of the methods	19
6 Standard method – Heat load of rooms, building entities and buildings.....	20
6.1 Output data.....	20
6.2 Input data.....	21
6.3 Calculation procedure	27
6.3.1 Design heat load	27
6.3.2 Design transmission heat losses of a heated space (i).....	29
6.3.3 Design ventilation heat loss	33
6.3.4 Additional heating-up power in intermittently heated spaces	41
6.3.5 Time constant.....	42
6.3.6 Heat transfer coefficients without temperature adjustment.....	43
6.3.7 External design temperature (climatic data).....	44
6.3.8 Influence of the heat emission system in high rooms (ceiling height ≥ 4 m)	46
7 Simplified method for the calculation of the design heat load of a heated space (single rooms).....	48
7.1 Output data.....	48
7.2 Input data.....	48
7.3 Calculation procedure	49
7.3.1 Design heat load of a heated space	49
7.3.2 Design transmission heat loss of a heated space.....	50
7.3.3 Design ventilation heat loss of a heated space	50
8 Simplified method for the calculation of the building design heat load	51
8.1 Output data.....	51
8.2 Input data.....	51
8.3 Calculation procedure	52
8.3.1 Building design heat load.....	52
8.3.2 Building design transmission heat loss.....	53
8.3.3 Design ventilation heat loss of a building	53
9 Compliance check.....	54
9.1 General.....	54
9.2 Dimensioning of heat emission systems.....	54
9.3 Dimensioning of heat generators.....	54
Annex A (normative) Input data, structure for default values	55
A.1 General.....	55
A.2 Input data for the standard method (6).....	55

A.2.1	Consideration of thermal bridges	55
A.2.2	Correction of U-values for the influence of building element properties and meteorological conditions	55
A.2.3	Heat loss through the ground	55
A.2.4	Temperature adjustment for heat loss to unheated spaces	56
A.2.5	Internal temperatures of adjacent building entities.....	56
A.2.6	Influence of the heat emission system in high rooms.....	56
A.2.7	Specific thermal storage capacity C_{eff}	57
A.2.8	Specific properties of air	57
A.2.9	Volume flow ratio between room (i) and zone (z)	58
A.2.10	Air tightness	58
A.2.11	Minimum air change rate	58
A.2.12	Coefficient for the volume flow ratio $f_{qv,z}$	59
A.2.13	Estimation of design data of external ATDs.....	59
A.2.14	Pressure exponent for leakages	59
A.2.15	Adjustment factor for the orientation of the zone (orientation factor)	59
A.2.16	Adjustment factor for the number of exposed facades	60
A.2.17	Air volume flow through large openings	60
A.2.18	Additional heating-up power in intermittently heated spaces ϕ_{hu}	60
A.2.19	Heat gains Φ_{gain}	60
A.3	Input data for the simplified methods (7, 8)	60
A.3.1	Ratio between external and internal surface areas	60
A.3.2	Thermal bridges	61
A.3.3	Temperature correction factor f_x	61
A.3.4	Air change rate	61
A.4	Input data for the standard method and the simplified methods	61
A.4.1	Climatic data	61
A.4.2	Internal design temperature	64
A.4.3	Simplified determination of U-Values	64
Annex B	(informative) Input data, default values	65
B.1	General.....	65
B.2	Input data for the standard method (6).....	65
B.2.1	Consideration of thermal bridges	65
B.2.2	Correction of U-values for the influence of building element properties and meteorological conditions	65
B.2.3	Heat loss through the ground	65
B.2.4	Temperature adjustment for heat loss to unheated spaces	66
B.2.5	Internal temperatures of adjacent building entities.....	66
B.2.6	Influence of the heat emission system in high rooms.....	66
B.2.7	Specific thermal storage capacity C_{eff}	67
B.2.8	Specific properties of air	68
B.2.9	Volume flow ratio between room (i) and zone (z)	68
B.2.10	Air tightness	68
B.2.11	Coefficient for the volume flow ratio $f_{qv,z}$	69
B.2.12	Estimation of design data of external ATDs.....	70
B.2.13	Pressure exponent for leakages	71
B.2.14	Adjustment factor for the orientation of the zone (orientation factor)	71
B.2.15	Adjustment factor for the number of exposed facades	71
B.2.16	Air volume flow through large openings	71
B.2.17	Additional heating-up power in intermittently heated spaces ϕ_{hu}	71
B.2.18	Heat gains Φ_{gain}	71
B.3	Input data for the simplified methods (7, 8)	71

EN 12831-1:2017 (E)

B.3.1	Ratio between external and internal surface areas	71
B.3.2	Thermal bridges	72
B.3.3	Temperature correction factor f_x	72
B.3.4	Air change rate	72
B.4	Input data for the standard method and the simplified methods	72
B.4.1	Climatic data	72
B.4.2	Internal design temperature	73
B.4.3	Simplified determination of U-Values	74
Annex C (informative)	Detailed consideration of thermal bridges.....	77
Annex D (informative)	Internal temperatures θ_{ui} of adjacent building entities or adjacent unheated spaces within the same building.....	78
Annex E (informative)	Equivalent thermal transmittance of building elements against ground..	81
Annex F (informative)	Estimation of heating-up power in intermittently heated spaces (6.3.4)..	84
F.1	General.....	84
F.2	Determination of the specific heating-up power $\varphi_{hu,i}$ based on the time of disuse.....	86
F.3	Determination of the specific heating-up power $\varphi_{hu,i}$ based on the internal temperature drop during setback.....	87
Annex G (informative)	External air volume flow through large openings	89
Bibliography		94

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12831-1:2018

<https://standards.iteh.ai/catalog/standards/sist/c45be024-9a24-451b-9950-1148c9f3589d/sist-en-12831-1-2018>

European foreword

This document (EN 12831-1:2017) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems in buildings”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2018, and conflicting national standards shall be withdrawn at the latest by January 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12831:2003.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

EN 12831, *Energy performance of buildings — Method for the calculation of the design heat load*, is composed with the following parts:

- Part 1: *Space heating load, Module M3-3*;
- Part 2: *Explanation and justification of EN 12831-1, Module M3-3* [CEN/TR];
- Part 3: *Domestic hot water systems heat load and characterisation of needs, Module M8-2, M8-3*;
- Part 4: *Explanation and justification of EN 12831-3, Module M8-2, M8-3* [CEN/TR].

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 12831-1:2017 (E)

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this standard a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

The EPB set of standards deals with energy performance calculation and other related aspects (like system sizing) to provide the building services considered in the EPBD.

The subjects covered by CEN/TC 228 are the following:

- design of heating systems (water based, electrical, etc.);
- installation of heating systems;
- commissioning of heating systems;
- instructions for operation, maintenance and use of heating systems;
- methods for calculation of the design heat loss and heat loads;
- methods for calculation of the energy performance of heating systems.

Heating systems also include the effect of attached systems such as hot water production systems.

All these standards are systems standards, i.e. they are based on requirements addressed to the system as a whole and not dealing with requirements to the products within the system.

Where possible, reference is made to other European or International Standards, a. o. product standards. However, use of products complying with relevant product standards is no guarantee of compliance with the system requirements.

The requirements are mainly expressed as functional requirements, i.e. requirements dealing with the function of the system and not specifying shape, material, dimensions or the like.

The guidelines describe ways to meet the requirements, but other ways to fulfil the functional requirements might be used if fulfilment can be proved.

Heating systems differ among the member countries due to climate, traditions and national regulations. In some cases requirements are given as classes so national or individual needs may be accommodated.

In cases where the standards contradict with national regulations, the latter should be followed.

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE So in this case:

- the regulators will **specify** the choices;

- the individual user will apply the standard to assess the energy performance of a building, and thereby **use** the choices made by the regulators.

Topics addressed in this standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B of this standard. Public regulation on the same topics can even, for certain applications, override the use of this standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

- national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case the national annex (e.g. NA) refers to this text;
- or, by default, the national standards body will consider the possibility to add or include a national annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 12831-2).

iteh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12831-1:2018

<https://standards.iteh.ai/catalog/standards/sist/c45be024-9a24-451b-9950-1148c9f3589d/sist-en-12831-1-2018>

EN 12831-1:2017 (E)**1 Scope**

This European Standard covers methods for the calculation of the design heat load for single rooms, building entities and buildings, where the design heat load is defined as the heat supply (power) needed to maintain the required internal design temperature under design external conditions.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 12831-1:2018

<https://standards.iteh.ai/catalog/standards/sist/c45be024-9a24-451b-9950-1148c9f3589d/sist-en-12831-1-2018>

Table 1 — Position of this standard, within the modular structure of the set of EPB standards

Sub module	Overarching		Building (as such)		Technical Building Systems									
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot water	Lighting	Building automation and control	Electricity production
sub1		M1		M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General		General		General	15316-1					15316-1			
2	Common terms and definitions; symbols, units and subscripts		Building Energy Needs		Needs						12831-3			
3	Applications		(Free) Indoor Conditions without Systems		Maximum Load and Power	12831-1					12831-3			
4	Ways to Express Energy Performance		Ways to Express Energy Performance		Ways to Express Energy Performance	15316-1					15316-1			
5	Building categories and Building Boundaries		Heat Transfer by Transmission		Emission and control	15316-2	15316-2							
6	Building Occupancy and Operating Conditions		Heat Transfer by Infiltration and Ventilation		Distribution and control	15316-3	15316-3				15316-3			

EN 12831-1:2017 (E)

Sub module	Overarching		Building (as such)		Technical Building Systems									
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot water	Lighting	Building automation and control	Electricity production
sub1		M1		M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
7	Aggregation of Energy Services and Energy Carriers		Internal Heat Gains		Storage and control	15316-5					15316-5 15316-4-3			
8	Building zoning		Solar Heat Gains		Generation									
8-1					Combustion boilers	15316-4-1					15316-4-1			
8-2					Heat pumps	15316-4-2	15316-4-2				15316-4-2			
8-3					Thermal solar Photovoltaics	15316-4-3					15316-4-3			15316-4-3
8-4					On-site cogeneration	15316-4-4					15316-4-4			15316-4-4
8-5					District heating and cooling	15316-4-5	15316-4-5							15316-4-5
8-6					Direct electrical heater	15316-4-8					15316-4-8			
8-7					Wind turbines									15316-4-10
8-8					Radiant heating, stoves	15316-4-8								

Sub module	Overarching		Building (as such)		Technical Building Systems									
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot water	Lighting	Building automation and control	Electricity production
sub1		M1		M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
9	Calculated Energy Performance		Building Dynamics (thermal mass)		Load dispatching and operating conditions									
10	Measured Energy Performance		Measured Energy Performance		Measured Energy Performance	15378-3					15378-3			
11	Inspection		Inspection		Inspection	15378-1					15378-1			
12	Ways to Express Indoor Comfort			-	BMS									
13	External Environment Conditions													
14	Economic Calculation	15459-1												

NOTE The shaded modules are not applicable.

EN 12831-1:2017 (E)**2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 6946, *Building components and building elements — Thermal resistance and thermal transmittance — Calculation method (ISO 6946)*

EN ISO 7345, *Thermal insulation — Physical quantities and definitions (ISO 7345)*

EN ISO 9972, *Thermal performance of buildings — Determination of air permeability of buildings — Fan pressurization method (ISO 9972)*

EN ISO 10077-1, *Thermal performance of windows, doors and shutters — Calculation of thermal transmittance — Part 1: General (ISO 10077-1)*

EN ISO 13370, *Thermal performance of buildings — Heat transfer via the ground — Calculation methods (ISO 13370)*

EN ISO 13789, *Thermal performance of buildings — Transmission and ventilation heat transfer coefficients — Calculation method (ISO 13789)*

EN ISO 52000-1, *Energy performance of buildings — Overarching EPB assessment — Part 1: General framework and procedures (ISO 52000-1)*

STANDARD PREVIEW
(standards.iteh.ai)

3 Terms and definitions

SIST EN 12831-1:2018

For the purposes of this document, the terms and definitions given in EN ISO 7345 and EN ISO 52000-1, and the following apply.

3.1**ATD, air terminal device**

air out-/inlets allowing air transfer between external and internal air (*external ATD*) or between separate rooms (*internal ATD*)

Note 1 to entry: In the field, the term *ATD* is used for a broad variety of air out- and inlets. Within this standard, the term refers only to passive devices allowing air flow through a building element (walls, etc.) in a defined manner. It does not include air out-/inlets of fan-assisted ventilation system.

Note 2 to entry: Within this standard, it is assumed that external ATDs are only applied in unbalanced ventilation.

3.2**annual mean external temperature**

mean value of the external temperature during the year

3.3**balanced ventilation**

fan-assisted ventilation where the sum of all supply air volume flows equals the sum of all exhausted air volume flows in quantity and over the course of time

3.4**building element**

internal or external component of the building structure and/or thermal envelope or a portion thereof with uniform thermal conditions on each side of the element

EXAMPLE Wall between two rooms of the same or different temperatures.

3.5**building entity**

certain portion of a building (one or more rooms) used as one unit by one party/occupant, such as:

- one apartment / flat;
- one office unit...

where the heat supply to that unit can be controlled individually by the occupant (usually by means of room temperature control devices)

Note 1 to entry: For the definition of *building entities* within application of this standard, it is not relevant if the heat supplied to *building entities* is generated centralized per building or separately in each *building entity*.

3.6**design heat load**

heat flow (power) required to achieve the specified internal design temperature under external design conditions

Note 1 to entry: The *design heat load* covers transmission and ventilation heat losses and, if any, an additional heating-up power.

SIST EN 12831-1:2018

<https://standards.iteh.ai/catalog/standards/sist/c45be024-9a24-451b-9950-1148c9f3589d/sist-en-12831-1-2018>

3.7**design heat loss**

heat loss (power) leaving the building to the external environment under specified design conditions

3.8**design transmission heat loss**

heat loss to the exterior and between heated and other heated or unheated spaces inside a building as a result of thermal conduction through the surrounding surfaces

Note 1 to entry: The design transmission heat loss is a portion of the design heat loss.

3.9**design ventilation heat loss**

heat loss to the exterior by ventilation and infiltration through the building envelope and the heat transferred by ventilation from one heated space to another heated or unheated space

Note 1 to entry: The design ventilation heat loss is a portion of the design heat loss.

3.10**external design temperature**

(minimal) external air temperature which is used for the calculation of the design heat losses