

SLOVENSKI STANDARD
kSIST-TP FprCEN/TR 15316-6-4:2016
01-december-2016

[Not translated]

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-4: Explanation and justification of EN 15316-4-1, Module M3-8-1, M8-8-1

Heizungsanlagen und Wasserbasierte Kühlanlagen in Gebäuden - Verfahren zur Berechnung der Energieanforderungen und Nutzungsgrade der Anlagen - Teil 6-4: Begleitender TR zur EN 15316-4-1 (Wärmeerzeugung für die Raumheizung und Trinkwarmwasser, Verbrennungssysteme (Heizungskessel, Biomasse))

<https://standards.iteh.ai/catalog/standards/sist/7699b7b4-55b8-4197-af50-312072091a2a/sist-tp-cen-tr-15316-6-4-2018>

Ta slovenski standard je istoveten z: FprCEN/TR 15316-6-4

ICS:

91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings
91.140.10	Sistemi centralnega ogrevanja	Central heating systems

kSIST-TP FprCEN/TR 15316-6-4:2016 en,fr,de

TECHNICAL REPORT
RAPPORT TECHNIQUE
TECHNISCHER BERICHT

FINAL DRAFT
FprCEN/TR 15316-6-4

November 2016

ICS 91.120.10; 91.140.10; 91.140.65

English Version

Energy performance of buildings - Method for calculation
of system energy requirements and system efficiencies -
Part 6-4: Explanation and justification of EN 15316-4-1,
Module M3-8-1, M8-8-1

Performance énergétique des bâtiments - Méthode de
calcul des besoins énergétiques et des rendements des
systèmes - Partie 6-4 : Explication et justification de
l'EN 15316-4-1, Module M3-8-1, M8-8-1

Heizungsanlagen und Wasserbasierte Kühlanlagen in
Gebäuden - Verfahren zur Berechnung der
Energieanforderungen und Nutzungsgrade der
Anlagen - Teil 6-4: Begleitender TR zur EN 15316-4-1
(Wärmeerzeugung für die Raumheizung und
Trinkwarmwasser, Verbrennungssysteme
(Heizungskessel, Biomasse))

This draft Technical Report is submitted to CEN members for Vote. It has been drawn up by the Technical Committee CEN/TC 228.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a Technical Report. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a Technical Report.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	5
Introduction	6
1 Scope	8
2 Normative references	8
3 Terms and definitions	8
3.1 Terms.....	8
3.2 Symbols.....	8
3.3 Abbreviations and indices	8
4 Description of the method	8
4.1 Output of the method.....	8
4.1.1 Description	8
4.1.2 Example	9
4.2 General description of the method	10
4.3 Input data.....	10
4.3.1 Description	10
4.3.2 Example	14
4.4 Boundaries between distribution and generation sub-system.....	14
4.5 Default values.....	16
4.5.1 Default values for generator efficiency at full load and intermediate load as a function of the generator power output.....	16
4.5.2 Default value for the stand-by heat losses $f_{\text{gen;ls;P0}}$ as a function of the generator power output	17
4.5.3 Auxiliary energy	18
4.6 Product values.....	19
4.7 Measured values.....	19
4.7.1 Boiler efficiencies from measured values.....	19
4.7.2 Measured total thermal losses, power input and calculated gains.....	19
4.7.3 Additional default data and calculation for condensing boilers.....	20
4.7.4 Thermal losses through the chimney with the burner on at full load $f_{\text{ch,on}}$	21
4.7.5 Thermal losses through the generator envelope $f_{\text{gen;env}}$	22
4.7.6 Thermal losses through the chimney with the burner off $f_{\text{ch,off}}$	22
4.8 Boiler rated output.....	22
5 Generation sub-system basic energy balance.....	23
5.1 Heat balance.....	23
5.2 Expenditure factor	24
5.3 Fuel heat input	25
5.3.1 Description	25
5.3.2 Example	25
5.4 Generator auxiliary energy	25
5.4.1 Description	25
5.4.2 Example	26
5.5 Generator losses.....	26
5.5.1 Generator loss	26
5.5.2 Generator thermal loss at specific load ratio $\beta_{\text{H;gen}}$ and power output PPx	26

5.5.3	Generator thermal loss calculation at full load	27
5.5.4	Generator thermal loss calculation at intermediate load.....	29
5.5.5	Generator thermal loss calculation at 0 % load	30
5.5.6	Correction factor by additional tests.....	31
5.6	Recoverable thermal losses.....	31
5.6.1	general.....	31
5.6.2	Generator thermal losses through the jacket (generator envelope)	32
5.6.3	Recoverable thermal losses out of auxiliary energy.....	32
5.7	Recovered auxiliary energy	33
5.7.1	Description.....	33
5.7.2	Example.....	33
5.8	Auxiliary energy.....	34
5.8.1	Description.....	34
5.8.2	Example.....	34
5.9	Generator thermal output.....	34
5.10	Heating time and load factor	35
5.11	Direct heated DHW heaters	36
5.11.1	Instantaneous electrical water heater	36
5.11.2	Instantaneous gas water heater	36
5.11.3	Gas-fired domestic storage water heaters.....	36
5.12	Method for domestic hot water appliance, tested with 24 hours tapping cycles.....	38
Annex A	(informative) Additional formulas and default values for parametering the boiler efficiency method	40
A.1	Information on the method.....	40
A.2	Conversion of the energy content of energy carriers	46
A.3	Deviation from default values.....	46
A.4	Fuel constants for flue gas measurement depending on Siegert constants	46
A.5	Default values for calculation of thermal losses through the chimney with the burner off.....	48
A.6	Additional default data and calculation for condensing boilers	49
A.7	Additional default data for generator output and losses.....	50
A.8	Additional default data and calculation for water heaters.....	50
Annex B	(informative) Additional formulas and default values for parametering the boiler efficiency method	51
B.1	Information on the method.....	51
B.2	Conversion of the energy content of energy carriers	58
B.3	Deviation from default values	58
B.4	Fuel constants for flue gas measurement depending on Siegert constants	58
B.5	Default values for calculation of thermal losses through the chimney with the burner off.....	60
B.6	Additional default data and calculation for condensing boilers	60
B.7	Additional default data for generator output and losses.....	62
B.8	Additional default data and calculation for water heaters.....	63

FprCEN/TR 15316-6-4:2016 (E)

Annex C (informative) General part default values and information - Boundary condition for DHW	64
Bibliography.....	65

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST-TP CEN/TR 15316-6-4:2018

<https://standards.iteh.ai/catalog/standards/sist/7699b7b4-55b8-4197-af50-312072091a2a/sist-tp-cen-tr-15316-6-4-2018>

European foreword

This document (FprCEN/TR 15316-6-4:2016) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems in buildings”, the secretariat of which is held by DIN.

This document is currently submitted to the Vote on TR.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST-TP CEN/TR 15316-6-4:2018

<https://standards.iteh.ai/catalog/standards/sist/7699b7b4-55b8-4197-af50-312072091a2a/sist-tp-cen-tr-15316-6-4-2018>

Introduction

This document informs about FprEN 15316-4-1 as a part of a series of standards aimed at European harmonization of the methodology for the calculation of the energy performance of buildings.

A huge amount of informative contents needs indeed to be recorded and made available for users to properly understand, apply and nationally adapt the EPB standards

The set of EPB standards, technical reports and supporting tools

In order to facilitate the necessary overall consistency and coherence, in terminology, approach, input/output relations and formats, for the whole set of EPB-standards, the following documents and tools are available:

- a) a document with basic principles to be followed in drafting EPB-standards: CEN/TS 16628:2014, Energy Performance of Buildings - Basic Principles for the set of EPB standards [1];
- b) a document with detailed technical rules to be followed in drafting EPB-standards; CEN/TS 16629:2014, Energy Performance of Buildings - Detailed Technical Rules for the set of EPB-standards [2];
- c) the detailed technical rules are the basis for the following tools:
 - 1) a common template for each EPB-standard, including specific drafting instructions for the relevant clauses;
 - 2) a common template for each technical report that accompanies an EPB standard or a cluster of EPB standards, including specific drafting instructions for the relevant clauses;
 - 3) a common template for the spreadsheet that accompanies each EPB standard, to demonstrate the correctness of the EPB calculation procedures.

Each EPB-standards follows the basic principles and the detailed technical rules and relates to the overarching EPB-standard, prEN ISO 52000-1 [3].

One of the main purposes of the revision of the EPB-standards is to enable that laws and regulations directly refer to the EPB-standards and make compliance with them compulsory. This requires that the set of EPB-standards consists of a systematic, clear, comprehensive and unambiguous set of energy performance procedures. The number of options provided is kept as low as possible, taking into account national and regional differences in climate, culture and building tradition, policy and legal frameworks (subsidiarity principle). For each option, an informative default option is provided (Annex B).

Rationale behind the EPB technical reports

There is a risk that the purpose and limitations of the EPB standards will be misunderstood, unless the background and context to their contents – and the thinking behind them – is explained in some detail to readers of the standards. Consequently, various types of informative contents are recorded and made available for users to properly understand, apply and nationally or regionally implement the EPB standards.

If this explanation would have been attempted in the standards themselves, the result is likely to be confusing and cumbersome, especially if the standards are implemented or referenced in national or regional building codes.

Therefore, each EPB standard is accompanied by an informative technical report, like this one, where all informative content is collected, to ensure a clear separation between normative and informative contents (see CEN/TS 16629 [2]):

- to avoid flooding and confusing the actual normative part with informative content;
- to reduce the page count of the actual standard; and
- to facilitate understanding of the set of EPB standards.

This was also one of the main recommendations from the European CENSE project [5] that laid the foundation for the preparation of the set of EPB standards.

FprEN 15316-4-1 is intended to replace EN 15316-4-1:2008 and includes Domestic hot water systems, generation (former EN 15316-3-3) and biomass boilers (former EN 15316-4-7:2008) in this standard published in 2007-2008 under the mandate M/343 on the EPBD. This revision was required as a result of the EPBD recast (2010/31/EU). The set of standards developed under mandate M/343 will be revised to become consistent with the overarching standard under mandate M/480.

The typology method has been removed, the boiler cycling method has been added for existing boilers to get the input parameters for the case specific boiler efficiency method.

Other generation systems are covered in other sub modules of part M3-8 (see Figure 1).

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST-TP CEN/TR 15316-6-4:2018

<https://standards.iteh.ai/catalog/standards/sist/7699b7b4-55b8-4197-af50-312072091a2a/sist-tp-cen-tr-15316-6-4-2018>

1 Scope

This Technical Report refers to FprEN 15316-4-1.

It contains information to support the correct understanding, use and national adaption of standard FprEN 15316-4-1.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 89, *Gas-fired storage water heaters for the production of domestic hot water*

EN 13203-2, *Gas-fired domestic appliances producing hot water - Part 2: Assessment of energy consumption*

FprEN 15316-4-1:2016, *Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-1: Space heating and DHW generation systems, combustion systems (boilers, biomass), Module M3-8-1, M8-8-1*

EN ISO 13790, *Energy performance of buildings - Calculation of energy use for space heating and cooling (ISO 13790)*

prEN ISO 52000-1:2015, *Energy performance of buildings - Overarching EPB assessment - Part 1: General framework and procedures (ISO/DIS 52000-1:2015)*

3 Terms and definitions

3.1 Terms

For the purposes of this document, the terms and definitions given in prEN ISO 52000-1:2015 and FprEN 15316-4-1:2016 apply.

3.2 Symbols

For the purposes of this document, the symbols and indices given in prEN ISO 52000-1:2015 and the symbols and units given in FprEN 15316-4-1:2016 apply.

3.3 Abbreviations and indices

For the purposes of this document, the abbreviations and indices given in prEN ISO 52000-1:2015 and the indices given in FprEN 15316-4-1:2016 applies.

4 Description of the method

4.1 Output of the method

4.1.1 Description

The calculation of the values takes place basically for the zones defined in EN ISO 13790.

If a number of parts of systems are contained in the various process domains then the values are to be added together for further analysis.

Here it is to be taken into account that the heating data are to be related to the gross calorific value.

In the following sections the thermal and auxiliary energy components of the different process domains are determined for further analysis in ISO/CD 11368.

For output quantities see Table 1.

Table 1 — Output quantities

Description	Symbol	Unit	Calculation Clause of FprEN 15316-6-4:2016	Validity interval	Destination module	Varying
Fuel heat input	$E_{\text{gen;in}}$	kWh	see 6.3	0...∞	M 3-1	YES
Recoverable generation heat losses for heating system (in the calculation interval)	$Q_{\text{gen;ls;rbt}}$	kWh	see 6.6	0...∞	M 3-1	YES
generation heat losses (in the calculation interval)	$Q_{\text{gen;ls;}}$	kWh	see 6.5	0...∞	M 3-1	YES
Expenditure factor of the generator for the whole service	ϵ_{gen}	-	see 6.2	1 - 10	M 3-1	YES
Expenditure factor of the generator for heating	$\epsilon_{\text{H;gen}}$	-	see 6.2	2 - 10	M 3-1	YES
Expenditure factor of the generator for cooling	$\epsilon_{\text{C;gen}}$	-	see 6.2	3 - 10	M 3-1	YES
Expenditure factor of the generator for ventilation	$\epsilon_{\text{V;gen}}$	-	see 6.2	4 - 10	M 3-1	YES
Expenditure factor of the generator for DHW	$\epsilon_{\text{W;gen}}$	-	see 6.2	5 - 10	M 3-1	YES
heat generation auxiliary energy for the heating system (in the calculation interval)	$W_{\text{gen;}}$	kWh	see 6.4	0...∞	M 3-1	YES
Fuel type		List		not relevant	M 3-1	NO

4.1.2 Example

Table 2 — Example for output quantities

Description	Symbol	Value
Fuel heat requirement	$E_{\text{gen;in}}$	99 443 kWh = 357,995 GJ
Recoverable heat loss	$Q_{\text{gen;ls;rbt}}$	408 kWh = 1,468 GJ
Total generation heat loss	$Q_{\text{gen;ls;}}$	1 574 kWh = 5,667 GJ
Auxiliary consumption	$W_{\text{gen;}}$	524,34 kWh = 1,888 GJ
expenditure factor of the generator		
for the whole service	ϵ_{gen}	0,99
for heating	$\epsilon_{\text{H;gen}}$	0,99
for cooling	$\epsilon_{\text{C;gen}}$	0,00
for ventilation	$\epsilon_{\text{V;gen}}$	0,00
for DHW	$\epsilon_{\text{W;gen}}$	0,00

4.2 General description of the method

The calculation method of the generation sub-system takes into account heat losses and/or recovery due to the following physical factors:

- heat losses to the chimney (or flue gas exhaust) and the generator(s) during total time of generator operation (running and stand-by);
- auxiliary energy.

The calculation is independent from the time steps.

There are a basic calculation for

- boilers at all (FprEN 15316-6-4:2016, Clause 6.);
- direct heated domestic hot water heaters (FprEN 15316-6-4:2016, 6.11) and
- domestic hot water appliance tested with 24 h tapping cycles (FprEN 15316-6-4:2016, 6.12).

There are three possible inputs for the generation efficiency calculation:

- default values (FprEN 15316-6-4:2016, 5.5);
- product values (FprEN 15316-6-4:2016, 5.6);
- measured values (FprEN 15316-6-4:2016, 5.7).

Default values are given in Annex B.

Product values by the manufactures should be tested according to the appropriated EN standard (see bibliography).

Measured values are for existing boilers, condensing boilers and on-site inspection (see 5.6).

Here it is to be taken into account that the heating data are to be related to the gross calorific value.

4.3 Input data

4.3.1 Description

Input quantities from other parts of the heating system standards, see Table 3.

Table 3 — Input quantities

Description	Symbol	Unit	Validity interval	Destination module	Varying
Fuel type	GEN_FUEL	List	not relevant	M 3-4, M 8-4	NO
Generator Type	GEN_TYP	List	not relevant	M 3-4, M 8-4	NO
Burner type	GEN_BURN	List	not relevant	M 3-4, M 8-4	NO
Boiler location	TH_ZONE	List	not relevant	M 3-4, M 8-4	NO
Type of control	HEAT_GEN_CTRL	List	not relevant	M 3-4, M 8-4	NO
Generation circuit typology	GEN_CIRC_TYPOL	List	not relevant	M 3-4, M 8-4	NO
number of dwellings within a building	N_{flat}	-	0...∞	M 3-1	YES
number of peak tappings per day	n_{sp}	-	0...∞	M 3-1	YES
Heat load	Φ_h	kW	0...∞	M 3-3	YES
Rated output for cooling system	$P_{n,C}$	kW	0...∞	M 4-3	YES
Rated output for ventilation system	$P_{n,V}$	kW	0...∞	M 5-3	YES
Rated output for DHW system	$P_{n,W}$	kW	0...∞	M 8-3	YES
Heat input to the heating distribution system (in the respective time)	$Q_{H,\text{dis};\text{in}}$	kWh	0...∞	M 3-6,	Yes
Heat input to the cooling distribution system (in the respective time)	$Q_{C,\text{dis};\text{in}}$	kWh	0...∞	M 4-6	YES
Heat input to the ventilation distribution system (in the respective time)	$Q_{V,\text{dis};\text{in}}$	kWh	0...∞	M 5-6,	YES
daily energy need for domestic hot water,	$Q_{W,b,d}$	kWh	0...∞	M 8-6	YES
Heat input to the domestic hot water distribution system (in the respective time)	$Q_{W,\text{dis};\text{in}}$	kWh	0...∞	M 8-6	YES
Usage period for heating (in the calculation interval),	$t_{H;\text{use}}$	h or d	0...8760	M 3-4, M 8-4	YES
Usage period for cooling (in the calculation interval)	$t_{C;\text{use}}$	h or d	0...8760	M 4-4	YES
Usage period for ventilation (in the calculation interval)	$t_{V;\text{use}}$	h or d	0...8760	M 5-4	YES
Usage period for domestic hot water (in the calculation interval)	$t_{W;\text{use}}$	h or d	0...8760	M 8-4	YES
Running time for heating (in the calculation interval)	t_H	s/h or h/mth	0...3600	M 3-4, M 8-4, EN ISO 13790	YES
running time for cooling system –	t_C	s/h or	0...3600	M 3-4, M 8-4	YES

FprCEN/TR 15316-6-4:2016 (E)

Description	Symbol	Unit	Validity interval	Destination module	Varying
when connected		h/mth			
running time for ventilation system – when connected	t_v	s/h or h/mth	0...3600	M 3-4, M 8-4	YES
running time for DHW system – when connected	t_w	s/h or h/mth	0...3600	M 3-4, M 8-4	YES
external air temperature	ϑ_e	°C	-30 .. +30	see external climat data, M 3-4, M 8-4	YES
daily average design temperature	$\vartheta_{e,min}$	°C	-30 .. +31	see external climat data, M 3-4, M 8-5	YES
generator average water temperature (or return temperature to the generator for condensing boilers) as a function of the specific operating conditions	$\vartheta_{Hc,mn}$	°C	0 .. 110	M 3-4, M 8-4	YES
average return temperature to the generator for condensing boilers as a function of the specific operating conditions	$\vartheta_{Hc,RT}$	°C	0 .. 110	M 3-4, M 8-4	YES
generator average water temperature as a function of the specific operating conditions for cooling systems - when connected	$\vartheta_{Cc,mn}$	°C	0 .. 110	M 3-4, M 8-4	YES
generator average water temperature as a function of the specific operating conditions for ventilation systems - when connected	$\vartheta_{Vc,mn}$	°C	0 .. 110	M 3-4, M 8-4	YES
generator average water temperature as a function of the specific operating conditions for DHW systems - when connected	$\vartheta_{Wc,mn}$	°C	0 .. 110	M 3-4, M 8-4	YES
average return temperature to the generator for condensing boilers as a function of the specific operating conditions for cooling systems - when connected	$\vartheta_{Cc,RT}$	°C	0 .. 110	M 3-4, M 8-4	YES
average return temperature to the generator for condensing boilers as a function of the specific operating conditions for ventilation systems - when connected	$\vartheta_{Vc,RT}$	°C	0 .. 110	M 3-4, M 8-4	YES

Description	Symbol	Unit	Validity interval	Destination module	Varying
average return temperature to the generator for condensing boilers as a function of the specific operating conditions for DHW systems - when connected	$\vartheta_{wc;RT}$	°C	0 .. 110	M 3-4, M 8-4	YES
average return temperature to the generator for condensing boilers	$\vartheta_{gen;RT}$	°C	-30 .. +30	measured	YES
ambient temperature	ϑ_{brm}	°C	-30 .. +31	M 3-4, M 8-4	YES
cold water temperature	ϑ_k	°C	0 .. 95	M 3-4	YES
Delivered energy input of the generation sub-system (measured fuel input) (in the calculation interval)	$E_{gen;del;in}$	kg, m ³	0...∞	M 3-1	YES
generator output at full load	P_n	kW	0...∞	M 3-2	YES
generator output at intermediate load	P_{int}	kW	0...∞	M 3-3	YES
temperature difference between boiler return water temperature and flue gas temperature at part load	$\Delta\vartheta_{wfg}$	°C	-30 .. +30	measured	YES
external air temperature	ϑ_e	°C	-30 .. +30	see external climat data, M 3-4, M 8-4	YES
ambient temperature	ϑ_{brm}	°C	-30 .. +31	see external climat data, M 3-4, M 8-5	YES
out of additional tests					
full load efficiency with mean water temperature $\vartheta_{gen;test;P_n;add}$	$\eta_{P_n;add}$	-	0 .. 1	measured	YES
mean water temperature at full load	$\vartheta_{gen;test;P_n;add}$	°C	-30 .. +30	measured	YES
part load efficiency with mean water temperature $\vartheta_{gen;test;P_{int};add}$	$\eta_{P_{int};add}$	-	0 .. 1	measured	YES
mean water temperature at part load	$\vartheta_{gen;test;P_{int};add}$	°C	-30 .. +31	measured	YES

The daily operation is taken into account by the heating time (operating hours/period of duration) $t_{H,op}$. The assumption is made that there is always only one user. Where there are a number of different loads a differentiation shall be made between the individual requirements for each case.

Only if the useful heat demand $Q_{H;dis;in} > 1$ kWh (in the calculation interval) is heating necessary.

If the generator provides heat for heating, cooling, ventilation and domestic hot water, the index H shall be replaced by C, V or W. In the following only H is used for simplicity.