

# SLOVENSKI STANDARD

## SIST EN 15232-1:2018

01-maj-2018

Nadomešča:  
SIST EN 15232:2012

---

**Energijske lastnosti stavb - 1. del: Vpliv avtomatizacije, regulacije in upravljanja stavb - Moduli M10-4, 5, 6, 7, 8, 9, 10**

Energy performance of Buildings - Part 1: Impact of Building Automation, Controls and Building Management - Modules M10-4,5,6,7,8,9,10

Energieeffizienz von Gebäuden - Teil 1: Einfluss von Gebäudeautomation und Gebäudemanagement - Module M10-4, 5, 6, 7, 8, 9, 10

Performance énergétique des bâtiments - Partie 1: Impact de l'automatisation, de la régulation et de la gestion technique - Modules M10-4, 5, 6, 7, 8, 9, 10

**Ta slovenski standard je istoveten z: EN 15232-1:2017**

---

**ICS:**

91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings
97.120	Avtomatske krmilne naprave za dom	Automatic controls for household use

**SIST EN 15232-1:2018**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 15232-1:2018

<https://standards.iteh.ai/catalog/standards/sist/1d98a1f5-2879-4e1c-b09f-1351eacb5152/sist-en-15232-1-2018>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 15232-1**

May 2017

ICS 91.120.10; 97.120

Supersedes EN 15232:2012

English Version

## Energy Performance of Buildings - Energy performance of buildings - Part 1: Impact of Building Automation, Controls and Building Management - Modules M10-4,5,6,7,8,9,10

Performance énergétique des bâtiments - Partie 1: Impact de l'automatisation, de la régulation et de la gestion technique - Modules M10-4, 5, 6, 7, 8, 9, 10

Energieeffizienz von Gebäuden - Teil 1: Einfluss von Gebäudeautomation und Gebäudemanagement - Module M10-4, 5, 6, 7, 8, 9, 10

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

**iTeh STANDARD PREVIEW**

(standards.itih.eu)  
This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

<b>Contents</b>	<b>Page</b>
European foreword.....	5
Introduction .....	6
<b>1 Scope.....</b>	<b>7</b>
<b>2 Normative references.....</b>	<b>9</b>
<b>3 Terms and definitions .....</b>	<b>10</b>
<b>4 Symbols, subscripts and abbreviations.....</b>	<b>13</b>
4.1 Symbols.....	13
4.2 Subscripts.....	13
<b>5 Description of the method .....</b>	<b>14</b>
5.1 Output of the method.....	14
5.2 General description of the method(s) .....	14
5.3 Selection criteria between the methods.....	14
5.4 BAC and TBM functions having an impact on the energy performance of buildings.....	15
5.5 BAC Efficiency Class.....	32
5.6 BAC and TBM functions assigned to the BAC efficiency classes.....	33
5.7 Applying BAC for EMS and maintaining BAC energy efficiency .....	46
5.7.1 General.....	46
5.7.2 Applying BAC for EMS.....	46
5.7.3 Maintaining BAC energy efficiency.....	46
<b>6 Method 1 - Detailed calculation procedure of the BAC contribution to the energy performance of buildings (Detailed method).....</b>	<b>46</b>
6.1 Output data.....	46
6.2 Calculation time steps .....	48
6.3 Input data - Source of data.....	48
6.4 Calculation procedure .....	48
6.4.1 Applicable timestep.....	48
6.4.2 Energy performance calculation .....	49
<b>7 Method 2 - Factor based calculation procedure of the BAC impact on the energy performance of buildings (BAC factor method).....</b>	<b>51</b>
7.1 Output data.....	51
7.2 Calculation interval.....	52
7.3 Calculation procedure - Energy calculation .....	52
<b>8 Simplified input data correlations.....</b>	<b>56</b>
<b>9 Quality control .....</b>	<b>56</b>
<b>10 Compliance check.....</b>	<b>56</b>
<b>Annex A (informative) BAC efficiency factors.....</b>	<b>57</b>
A.1 Overall BAC efficiency factors for the thermal energy $f_{BAC,th}$ .....	57
A.2 Overall BAC efficiency factors for electric energy $f_{BAC,el}$ .....	58
A.3 Detailed BAC efficiency factors for heating and cooling .....	59

A.4	Detailed BAC efficiency factors for DHW.....	60
A.5	Detailed BAC efficiency factors for lighting and auxiliary energy .....	61
Annex B (informative) Minimum BAC function type requirements.....		62
Annex C (informative) Determination of the BAC efficiency factors.....		67
C.1	Determination procedure.....	67
C.2	Detailed modelling approaches and user profiles.....	68
C.2.1	General .....	68
C.2.2	Efficiency class C (reference).....	69
C.2.3	Efficiency class D.....	70
C.2.4	Efficiency class B.....	71
C.2.5	Efficiency class A.....	72
C.3	Boundary condition.....	72
C.3.1	General .....	72
C.3.2	Office.....	73
C.3.3	Hotel.....	74
C.3.4	Education, school.....	75
C.3.5	Lecture hall.....	76
C.3.6	Restaurant.....	77
C.3.7	Wholesale centre .....	78
C.3.8	Hospital .....	79
C.4	BAC efficiency classes - Domestic Hot Water (DHW).....	80
C.5	Impact of geographical location on the BAC efficiency factors .....	80
C.6	Influence of the different user profiles on the BAC factors .....	83
Annex D (informative) Examples of how to use the BAC function list of EN ISO 16484-3 to describe functions from this European Standard.....		85
D.1	General .....	85
D.2	Direct representation by a function defined in EN ISO 16484-3 .....	85
D.2.1	Example 1 - Night cooling .....	85
D.2.2	Example 2 - h,x- directed control.....	85
D.3	Representation by a combination of functions defined in EN ISO 16484-3.....	86
D.3.1	Example 3 - Individual room automatic control.....	86
D.3.2	Example 4 - Outside temperature compensated control .....	86
Annex E (informative) Applying BAC for EMS specified in EN ISO 50001 .....		88
E.1	General .....	88
E.2	Guideline for using BACS for EMS .....	88
Annex F (informative) Maintain BAC energy efficiency.....		102
F.1	General .....	102

## EN 15232-1:2017 (E)

<b>F.2</b>	<b>Activity 1 - Maintain and improve the BAC efficiency class .....</b>	<b>102</b>
<b>F.2.1</b>	<b>General.....</b>	<b>102</b>
<b>F.2.2</b>	<b>Monitoring.....</b>	<b>102</b>
<b>F.2.3</b>	<b>Operation .....</b>	<b>102</b>
<b>F.2.4</b>	<b>Energy Efficiency.....</b>	<b>102</b>
<b>F.2.5</b>	<b>Modernizations, Upgrades and new Technologies .....</b>	<b>102</b>
<b>F.3</b>	<b>Activity 2 - Upgrading of the BAC efficiency class .....</b>	<b>103</b>
<b>F.3.1</b>	<b>General.....</b>	<b>103</b>
<b>F.3.2</b>	<b>Procedure for meeting an BAC efficiency class .....</b>	<b>103</b>
	<b>Annex G (informative) Control accuracy .....</b>	<b>105</b>
	<b>Bibliography.....</b>	<b>106</b>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 15232-1:2018

<https://standards.iteh.ai/catalog/standards/sist/1d98a1f5-2879-4e1c-b09f-1351eacb5152/sist-en-15232-1-2018>

## European foreword

This document (EN 15232-1:2017) has been prepared by Technical Committee CEN/TC 247 “Building Automation, Controls and Building Management”, the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2017, and conflicting national standards shall be withdrawn at the latest by November 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15232:2012.

The most important changes are:

- respect the presentation of this project in the frame EPB in accordance with the drafting rules;
- a structured updated list of Building Automation and Control (BAC) functions;
- a set of new BMS function introduced in the new EPBD standard EN 16947-1 has been added to the list of functions thus completing the former TBM functions.

This document has been prepared under a mandate [22] given to CEN by the European Commission and the European Free Trade Association.

[SIST EN 15232-1:2018](https://standards.iteh.ai/catalog/standards/sist/1d98a1f5-2879-4e1c-b09f-1551eac65152/sist-en-15232-1-2018)

This document is part of the set of standards on the energy performance of buildings (the set of EPB standards).

In case this standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements.

Further target groups are users of the voluntary common European Union certification scheme for the energy performance of non-residential buildings (EPBD art.11.9) and any other regional (e.g. Pan European) parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## EN 15232-1:2017 (E)

## Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “EPB set of standards”.

As part of the “EPB set of standards” it complies with the requirements for the set of basic EPB documents EN ISO 52000-1 (see Normative references), CEN/TS 16628 and CEN/TS 16629 (see Bibliography [2] and [3]) developed under a mandate given to CEN by the European Commission and the European Free Trade Association (Mandate M/480).

The standards issued by TC 247 for M/480 belong to the EPB set of standards and are in line with the over-arching standard (EN ISO 52000-1) and drafted in accordance with the basic principles and detailed technical rules developed in the Phase I of the mandate.

Also these standards are clearly identified in the modular structure developed to ensure a transparent and coherent EPB standard set. BAC (Building Automation and Control) is identified in the modular structure as Technical Building System M10. However, the standards of TC 247 deal with control accuracy, control functions and control strategies using standards communications protocol (these last standards do not belong to the EPB standards set).

To avoid a duplication of calculation due to the BAC (avoid double impact), no calculation are done in BAC EPB standard set, but in each underlying standard of EPB set of standards (from M1 to M9 in the Modular Structure), an IDENTIFIER developed and present in the M10 covered by EN 15232-1 is used where appropriate. These way of interaction is described in detailed in the Technical Report (CEN ISO/TR 52000-2) accompanying the over-arching standard. As consequence, the Annex A and Annex B concept as EXCEL sheet with the calculation formulas used in the EPB standards are not applicable for the standards issued by TC 247 for M/480.

The main target groups of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 15232-2 [5]).



## 1 Scope

This European Standard specifies:

- a structured list of control, building automation and technical building management functions which contribute to the energy performance of buildings; functions have been categorized and structured according to building disciplines and so called Building automation and control (BAC);
- a method to define minimum requirements or any specification regarding the control, building automation and technical building management functions contributing to energy efficiency of a building to be implemented in building of different complexities;
- a factor based method to get a first estimation of the effect of these functions on typical buildings types and use profiles;
- detailed methods to assess the effect of these functions on a given building.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively.

(standards.iteh.ai)

SIST EN 15232-1:2018

<https://standards.iteh.ai/catalog/standards/sist/1d98a1f5-2879-4e1c-b09f-1351eacb5152/sist-en-15232-1-2018>

**Table 1 — Position of this standard (in casu M10–4,5,6,7,8,9,10), within the modular structure of the set of EPB standards**

	Over-arching	Building (as such)	Technical Building System									
Submodule	Descriptions	Descriptions	Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot waters	Lighting	Building automation and control	PV, wind, ..
sub1	M1	M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General	General	General									
2	Common terms and definitions; symbols, units and subscripts	Building Energy Needs	Needs									
3	Application	(Free) Indoor Conditions without Systems	Maximum Load and Power									
4	Ways to Express Energy Performance	Ways to Express Energy Performance	Ways to Express Energy Performance								x	
5	Building Functions and Building Boundaries	Heat Transfer by Transmission	Emission and control								x	
6	Building Occupancy and Operating Conditions	Heat Transfer by Infiltration and Ventilation	Distribution and control								x	
7	Aggregation of Energy Services and Energy Carriers	Internal Heat Gains	Storage and control								x	
8	Building Partitioning	Solar Heat Gains	Generation and control								x	
9	Calculated Energy Performance	Building Dynamics (thermal mass)	Load dispatching and operating conditions								x	
10	Measured Energy Performance	Measured Energy Performance	Measured Energy Performance								x	
11	Inspection	Inspection	Inspection									
12	Ways to Express Indoor Comfort		BMS									
13	External Environment Conditions											
14 <sup>a</sup>	Economic Calculation											

<sup>a</sup> The shaded modules are not applicable.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13779, *Ventilation for non-residential buildings — Performance requirements for ventilation and room-conditioning systems*

EN 15193-1, *Energy performance of buildings — Energy requirements for lighting*

EN 15243:2007, *Ventilation for buildings — Calculation of room temperatures and of load and energy for buildings with room conditioning systems*

EN 15316 (all parts), *Heating systems in buildings — Method for calculation of system energy requirements and system efficiencies*

EN 15316-2, *Energy performance of buildings — Method for calculation of system energy requirements and system efficiencies — Part 2: Space emission systems (heating and cooling), Module M3-5, M4-5*

EN 15316-4-5, *Energy performance of buildings — Method for calculation of system energy requirements and system efficiencies — Part 4-5: District heating and cooling, Module M3-8-5, M4-8-5, M8-8-5, M11-8-5*

EN 16798-5-1, *Energy performance of buildings — Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8 — Ventilation for buildings — Calculation methods for energy requirements of ventilation and air conditioning systems — Part 5-1: Distribution and generation (revision of EN 15241) — Method 1*

EN 16798-7, *Energy performance of buildings — Part 7: Ventilation for buildings — Modules M5-1, M5-5, M5-6, M5-8 — Calculation methods for the determination of air flow rates in buildings including infiltration*

EN 16798-9, *Energy performance of buildings — Part 09: Ventilation for buildings — Module M4-1, M4-4, M4-9 — Calculation methods for energy requirements — Calculation methods for energy requirements of cooling systems — General*

EN 16798-13, *Energy performance of buildings — Part 13: Module M4-8 — Calculation of cooling systems — Generation*

EN 16798-15, *Energy performance of buildings — Part 15: Module M4-7 — Calculation of cooling systems — Storage — General*

EN 16947 series, *Energy Performance of Buildings — Building Management*

EN ISO 7345:1995, *Thermal insulation — Physical quantities and definitions (ISO 7345:1987)*

EN ISO 50001:2011, *Energy management systems — Requirements with guidance for use (ISO 50001:2011)*

EN ISO 52000-1:2017, *Energy performance of buildings — Overarching EPB assessment — Part 1: General framework and procedures (ISO 52000-1:2017)*

EN ISO 52016-1, *Energy performance of buildings — Energy needs for heating and cooling, internal temperatures and sensible and latent heat loads — Part 1: Calculation procedures (ISO 52016-1)*

**EN 15232-1:2017 (E)****3 Terms and definitions**

For the purposes of this document, the terms and definitions given in EN ISO 7345:1995, in EN ISO 52000-1:2017 and the following apply.

**3.1 auxiliary energy**  
electrical energy used by technical building systems to support energy transformation to satisfy energy needs

Note 1 to entry: This includes energy for fans, pumps, electronics etc. Electrical energy input to the ventilation system for air transport and heat recovery is not considered as auxiliary energy, but as energy use for ventilation.

Note 2 to entry: In EN ISO 9488 the energy used for pumps and valves is called “parasitic energy”.

[SOURCE: EN ISO 52000-1]

**3.2 building automation and control BAC**  
products, software, and engineering services for automatic controls, monitoring and optimization, human intervention, and management to achieve energy-efficient, economical, and safe operation of building services equipment

[SOURCE: EN ISO 52000-1:2017, modified – The symbol BAC was added.]

**3.3 building automation and control system BACS**  
system, comprising all products, software and engineering services for automatic controls (including interlocks), monitoring, optimization, for operation, human intervention, and management to achieve energy-efficient, economical, and safe operation of building services

Note 1 to entry: BACS is also referred to as BMS (Building management system).

Note 2 to entry: The use of the word ‘control’ does not imply that the system/device is restricted to control functions. Processing of data and information is possible.

Note 3 to entry: If a building control system, building management system, or building energy management system complies with the requirements of the EN ISO 16484- series, it should be designated as a building automation and control system (BACS).

Note 4 to entry: Building services is divided in technical, infrastructural and financial building services and energy management is part of technical building management.

Note 5 to entry: Building energy management system is part of a BMS.

Note 6 to entry: Building energy management system comprising data collection, logging, alarming, reporting, and analysis of energy usage etc. The system is designed to reduce the energy consumption, improve the utilization, increase the reliability, and predict the performance of the technical building systems, as well as optimize energy usage and reducing its cost.

[SOURCE: EN ISO 16484-2:2004, modified – Notes 1, 4 and 5 have been added.]

### 3.4 building management BM

totality of services involved in the management operation and monitoring of buildings (including plants and installations)

Note 1 to entry: Building management can be assigned as part of facility management.

[SOURCE: CEN/TS 15379:2006, modified – Second part of the definition became Note 1 to entry.]

### 3.5 control function

BAC effect of programs and parameters

Note 1 to entry: BAC functions are referred to as control functions, I/O, processing, optimization, management and operator functions. They are listed in the BAC FL (function list) for a specification of work.

Note 2 to entry: Function is a program unit that delivers exactly one data element, which can be a multiple value (i.e. an array or a structure). Functions can be an operand in a program. [EN 61131-3]

### 3.6 delivered energy

energy, expressed per energy carrier, supplied to the technical building systems through the assessment boundary, to satisfy the uses taken into account or to produce the exported energy

Note 1 to entry: Delivered energy can be calculated for defined energy uses or it can be measured.

[SOURCE: EN ISO 52000-1]

### 3.7 energy carrier

substance or phenomenon that can be used to produce mechanical work or heat or to operate chemical or physical processes

[SOURCE: EN ISO 52000-1]

### 3.8 energy need for heating or cooling

heat to be delivered to or extracted from a thermally conditioned space to maintain the intended space temperature conditions during a given period of time

Note 1 to entry: The energy need can include additional heat transfer resulting from non-uniform temperature distribution and non-ideal temperature control, if they are taken into account by increasing (decreasing) the effective temperature for heating (cooling) and not included in the heat transfer due to the heating (cooling) system.

ITeH STANDARD PREVIEW  
(standards.iteh.ai)

SIST EN 15232-1:2018

<https://standards.iteh.ai/catalog/standards/sist/1d98a1f5-2879-4e1c-b09f-1351eacb5152/sist-en-15232-1-2018>

**EN 15232-1:2017 (E)****3.9  
energy efficiency**

ratio or other quantitative relationship between an output of performance, service, goods or energy, and an input of energy

EXAMPLE Efficiency conversion energy; energy required/energy used; output/input; theoretical energy used to operate/energy used to operate.

Note 1 to entry: Both input and output need to be clearly specified in quantity and quality, and be measurable.

[SOURCE: EN ISO 50001-1:2011 modified - Symbol removed]

**3.10  
energy efficiency improvement**

increase in energy efficiency as a result of technological, behavioural or economic changes

[SOURCE: EN ISO 50001-1:2011]

**3.11  
integrated building automation and control systems**

BACS designed to be interoperable and with the ability to be connected to one or more specified 3rd party building automation and control devices/systems through open data communication network or interfaces performed by standardized methods, special services and permitted responsibilities for system integration

EXAMPLE Interoperability between 3rd party BACS devices/systems for HVAC, domestic hot water, lighting, electrical power distribution, energy metering, elevators and escalators, other plants, as well as systems for communications, access control, security, life safety etc.

**3.12  
integrated function**

BAC effect of programs, shared data points and parameters for multi-discipline interrelationships between various building services and technologies

**3.13  
measured energy performance**

energy performance based on measured amounts of delivered and exported energy

Note 1 to entry: The measured rating is the weighted sum of all energy carriers used by the building, as measured by meters or derived from measured energy by other means. It is a measure of the in-use performance of the building after correction or extrapolation. This is particularly relevant to certification of actual energy performance.

Note 2 to entry: Also known as “operational rating”.

[SOURCE: EN ISO 52000-1]

**3.14  
set-point temperature of a conditioned zone**

internal (minimum) temperature, as fixed by the control system in normal heating mode, or internal (maximum) temperature, as fixed by the control system in normal cooling mode

Note 1 to entry: The corrected value of a temperature setpoint is used for the calculation of energy performance. It enables the impact of the accuracy of the control system on the energy performance to be taken into account.

### 3.15 thermally activated building systems

#### TABS

massive building fabric actively heated or cooled by integrated air or water based systems

### 3.16 technical building management

#### TBM

process(es) and services related to operation and management of buildings and technical building system through the interrelationships between the different disciplines and trades

Note 1 to entry: The disciplines and trades comprise all technical building services for the purpose of optimized maintenance and energy consumption.

EXAMPLE Optimization of buildings through interrelationships ranging from heating, ventilation and air conditioning (HVAC) to lighting and day lighting to life safety and security to electric power systems and energy monitoring and metering; to its services, including communications and maintenance and to its management.

### 3.17 technical building system

technical equipment for heating, cooling, ventilation, humidification, dehumidification, domestic hot water, lighting and electricity production

Note 1 to entry: A technical building system can refer to one or to several building services (e.g. heating, heating and DHW).

Note 2 to entry: A technical building system is composed of different subsystems.

Note 3 to entry: Electricity production can include cogeneration and photovoltaic systems.

[SOURCE: EN ISO 52000-1]

## 4 Symbols, subscripts and abbreviations

### 4.1 Symbols

For the purposes of this document, the symbols given in EN ISO 52000-1:2017, Clause 4 and Annex C and the specific symbols listed in Table 2 apply.

Table 2 — Symbols and units

Symbol	Quantity	Unit
$a$	normalized level, e.g. occupancy or gains	-
$\bar{\beta}$	mean part load	-
$\phi$	heat flow rate, thermal power	kW

### 4.2 Subscripts

For the purposes of this document, the subscript given in EN ISO 52000-1:2017, Clause 4 and Annex C and the specific subscripts listed in Table 3 apply.