

---

---

**Fire protection — Automatic sprinkler  
system —**

Part 9:

**Requirements and test methods for water  
mist nozzles**

*Protection contre l'incendie — Systèmes d'extinction automatiques du  
type sprinkler —*

*Partie 9: Prescriptions et méthodes d'essai des ajutages (brouillard)*

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

ISO 6182-9:2005

<https://standards.itih.ai/catalog/standards/iso/bd836930-7070-4314-b5c2-95925be2dd4e/iso-6182-9-2005>



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

**iTeh Standards**  
**(<https://standards.iteh.ai>)**  
**Document Preview**

[ISO 6182-9:2005](https://standards.iteh.ai/catalog/standards/iso/bd836930-7070-4314-b5c2-95925be2dd4e/iso-6182-9-2005)

<https://standards.iteh.ai/catalog/standards/iso/bd836930-7070-4314-b5c2-95925be2dd4e/iso-6182-9-2005>

© ISO 2005

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

Foreword.....	v
Introduction .....	vi
1 Scope .....	1
2 Normative references .....	1
3 Terms and definitions.....	2
4 Product consistency.....	5
5 General requirements.....	5
5.1 Materials .....	5
5.2 Prevention of field adjustment .....	5
5.3 Drawing review.....	5
5.4 Pipe and fitting threads .....	5
5.5 Strainers and filters .....	5
6 Elastomeric materials.....	6
6.1 Properties .....	6
6.2 Test specimen .....	6
7 Water mist nozzle requirements.....	7
7.1 Dimensions.....	7
7.2 Nominal operating temperatures .....	7
7.3 Operating temperatures .....	7
7.4 Water flow and distribution and droplet size.....	7
7.5 Function .....	8
7.6 Strength of body .....	8
7.7 Strength of release element.....	8
7.8 Leak resistance and hydrostatic strength.....	9
7.9 Heat exposure .....	9
7.10 Thermal shock for glass bulb nozzles.....	9
7.11 Corrosion.....	9
7.12 Integrity of nozzle coatings .....	10
7.13 Water hammer .....	10
7.14 Dynamic heating .....	10
7.15 Resistance to heat .....	10
7.16 Resistance to vibration .....	10
7.17 Resistance to impact.....	11
7.18 Lateral discharge .....	11
7.19 30-day leakage resistance .....	11
7.20 Vacuum resistance .....	11
7.21 Clogging .....	11
7.22 Fire tests .....	11
7.23 Shipboard machinery spaces.....	12
7.24 Shipboard passenger cabins.....	12
7.25 Shipboard public spaces .....	13
7.26 Shipboard storage and shopping areas .....	14
7.27 Low hazard areas.....	14
7.28 Standard hazard areas .....	14
7.29 Resistance to low temperature.....	14
8 Test methods.....	14
8.1 General.....	14
8.2 Visual examination .....	14

8.3	Service load and body strength test .....	15
8.4	Leak resistance and hydrostatic strength tests .....	15
8.5	Functional test.....	15
8.6	Heat-responsive element operating characteristics .....	16
8.7	Heat exposure test .....	19
8.8	Thermal shock test for glass bulb nozzles.....	20
8.9	Strength test for release elements .....	21
8.10	Water flow test.....	21
8.11	Water distribution and droplet size tests .....	22
8.12	Corrosion tests.....	22
8.13	Nozzle coating tests.....	25
8.14	Heat-resistance test .....	25
8.15	Water-hammer test.....	25
8.16	Vibration test .....	25
8.17	Impact test .....	26
8.18	Lateral discharge test .....	26
8.19	30-day leakage test .....	26
8.20	Vacuum test .....	26
8.21	Clogging test .....	26
8.22	Shipboard machinery space fire test method .....	27
8.23	Passenger cabin fire tests.....	31
8.24	Shipboard public space fire tests.....	36
8.25	Freezer test .....	38
9	Water mist nozzle marking.....	38
9.1	General .....	38
9.2	Nozzle housings .....	39
10	Design, installation and maintenance instructions .....	39
10.1	General .....	39
10.2	Requirements .....	39
Annex A	(normative) Tolerance limit calculation methods.....	53
Annex B	(informative) Analysis of the strength test for fusible elements.....	56
Annex C	(informative) Nozzle response sample calculations.....	57
Annex D	(normative) Tolerances .....	59
Bibliography	.....	60

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6182-9 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 5, *Fixed firefighting systems using water*.

ISO 6182 consists of the following parts, under the general title *Fire protection — Automatic sprinkler systems*:

- *Part 1: Requirements and test methods for sprinklers*
- *Part 2: Requirements and test methods for wet alarm valves, retard chambers and water motor alarms*
- *Part 3: Requirements and test methods for dry pipe valves*
- *Part 4: Requirements and test methods for quick-opening devices*
- *Part 5: Requirements and test methods for deluge valves*
- *Part 6: Requirements and test methods for check valves*
- *Part 7: Requirements and test methods for early suppression fast response (ESFR) sprinklers*
- *Part 8: Requirements and test methods for pre-action dry alarm valves*
- *Part 9: Requirements and test methods for water mist nozzles*
- *Part 10: Requirements and test methods for domestic sprinklers*
- *Part 11: Requirements and test methods for pipe hangers*
- *Part 12: Requirements and test methods for grooved end pipe couplings*
- *Part 13: Requirements and test methods for extended coverage sprinklers*

## **Introduction**

This part of ISO 6182 is one of a number of ISO Standards prepared by ISO/TC 21 covering components for automatic sprinkler systems.

They are included in a series of ISO Standards planned to cover the following:

- a) carbon dioxide systems,
- b) explosion suppression systems,
- c) foam systems.

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

[ISO 6182-9:2005](https://standards.itih.ai/catalog/standards/iso/bd836930-7070-4314-b5c2-95925be2dd4e/iso-6182-9-2005)

<https://standards.itih.ai/catalog/standards/iso/bd836930-7070-4314-b5c2-95925be2dd4e/iso-6182-9-2005>

# Fire protection — Automatic sprinkler system —

## Part 9: Requirements and test methods for water mist nozzles

### 1 Scope

This part of ISO 6182 specifies performance requirements, test methods and marking requirements for water mist nozzles.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 37, *Rubber, vulcanized or thermoplastic — Determination of tensile stress-strain properties*

ISO 188, *Rubber, vulcanized or thermoplastic — Accelerated ageing and heat resistance tests*

ISO 5660-1, *Reaction-to-fire tests — Heat release, smoke production and mass loss rate — Part 1: Heat release rate (cone calorimeter method)*

ANSI/UL 723:2003, *Test for surface burning characteristics of building materials*

ASTM E11:2004, *Standard specification for wire cloth and sieves for testing purposes*

ASTM E799:2003, *Standard practice for determining data criteria and processing for liquid drop size analysis*

IMO Resolution A.653(16), *Recommendation on improved fire test procedures for surface flammability of bulkhead, ceiling and deck finish materials*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### **assembly load**

force exerted on the nozzle body at 0 MPa [0 bar<sup>1)</sup>] hydraulic pressure at the inlet

#### 3.2

##### **conductivity factor**

*C*

measure of the conductance between the nozzle's heat-responsive element and the fitting

NOTE The conductivity factor is expressed in units of (m/s)<sup>0.5</sup>.

#### 3.3

##### **control spaces**

shipboard areas such as the bridge, radio room and emergency power room

#### 3.4

##### **corrosion-resistant material**

material of bronze, brass, copper-and-nickel-base alloy, stainless steel or plastic

#### 3.5

##### **design load**

force exerted on the release element at the service load of the nozzle

#### 3.6

##### **fire control**

limiting the growth of a fire and controlling ceiling gas temperatures to prevent structural damage

#### 3.7

##### **fire suppression**

sharply reducing the rate of heat release of a fire and preventing its regrowth

#### 3.8

##### **fire extinguishment**

zero rate of heat release, definite stoppage of flames and no re-ignition

#### 3.9

##### **flame spread index**

**FSI**

fire-spread characteristic measured in accordance with ANSI/UL 723

#### 3.10

##### **fuel package**

combustible materials in which the fire is ignited and the combustible materials covering the walls and ceiling

#### 3.11

##### **low hazard area**

area where the quantity and/or combustibility of contents is low and fires with relatively low rates of heat release are expected

---

1) 1 bar = 10<sup>5</sup>N/m<sup>2</sup> = 0,1 MPa.



**3.12****shipboard machinery spaces**

engine rooms and cargo pump rooms containing combustible or flammable liquids having fire characteristics no more severe than that of light diesel oil

**3.13 Nozzles****3.13.1****automatic nozzle**

thermosensitive device designed to react at a predetermined temperature by automatically releasing water mist into a designated area and volume having a response time index (RTI) of not more than  $50 \text{ (m}\cdot\text{s)}^{1/2}$  and a conductivity factor ( $C$ ) not more than  $1,0 \text{ (m/s)}^{1/2}$

**3.13.2****coated nozzle**

nozzle that has a factory applied coating for corrosion protection

**3.13.3****fast response nozzle**

automatic nozzle having a response time index (RTI) not more than  $50 \text{ (m}\cdot\text{s)}^{1/2}$  and a conductivity factor ( $C$ ) not more than  $1,0 \text{ (m/s)}^{1/2}$

**3.13.4****fusible element nozzle**

nozzle that opens under the influence of heat by the melting of a component

**3.13.5****glass bulb nozzle**

nozzle that opens under the influence of heat by the bursting of the glass (frangible) bulb through pressure resulting from expansion of the enclosed fluid

**3.13.6****multiple orifice nozzle**

nozzle having two or more outlet orifices arranged to distribute the water discharge in a specified pattern and quantity for a definite protection area

**3.13.7****open nozzle**

nozzle without a thermosensitive element

**3.13.8****pendent nozzle**

nozzle that is arranged in such a way that the water mist is directed initially downward by striking a distribution plate or by nozzle orientation

**3.13.9****upright nozzle**

nozzle that is arranged in such a way that the water mist is initially directed upwards against a distribution plate

**3.14****operating pressure**

service pressure at which a nozzle is intended to operate

**3.15****rated working pressure**

maximum service pressure at which a nozzle is intended to operate, but no less than 1,2 MPa (12 bar)

**3.16**  
**protective cap**

device attached to the nozzle for the purpose of protecting the nozzle throughout transport and installation but mainly for the protection of the nozzle while in service

**3.17**  
**response time index**  
**RTI**

measure of automatic nozzle sensitivity

$$RTI = \tau u^{1/2}$$

where

$\tau$  is the time constant of the heat-responsive element, expressed in units of seconds;

$u$  is the gas velocity, expressed in meters per second

NOTE 1 RTI is expressed in units of (m·s)<sup>1/2</sup>.

NOTE 2 RTI can be used in combination with the conductivity factor ( $C$ ) to predict the response of a nozzle in fire environments defined in terms of gas temperature and velocity versus time.

**3.18**  
**service load**

combined force exerted on the nozzle body by the assembly load of the nozzle and the equivalent force of the rated working pressure applied at the inlet

**3.19**  
**shipboard passenger cabin**

area with sleeping facilities that are assigned to passengers for their private use

**3.20**  
**shipboard public space**

area where people may gather such as restaurants, dining rooms, lounges, corridors and offices

**3.21**  
**shipping cap**

device attached to the nozzle for the purpose of protecting the nozzle only during transport and installation

NOTE Shipping caps are not intended to remain on the nozzle after the installation is complete.

**3.22**  
**standard hazard area**

area where the quantity and combustibility of contents is moderate, stockpiles of combustibles do not exceed 1,5 m and fires with moderate rates of heat release are expected

**3.23**  
**standard orientation**

orientation where the airflow is perpendicular to both the axis of the nozzle's inlet and the plane of the frame arms, if provided, that produces the shortest response time

**3.24**  
**worst-case orientation**

orientation that produces the longest response time with the axis of the nozzle inlet perpendicular to the airflow

## 4 Product consistency

It shall be the responsibility of the manufacturer to implement a quality control program to ensure that production continuously meets the requirements in the same manner as the originally tested samples. Before testing, nozzles shall be examined with respect to marking, conformity to manufacturer's drawings and obvious defects.

Every automatic water mist nozzle shall pass a leak resistance test equivalent to a hydrostatic pressure of at least 2,5 times the rated working pressure, but no less than 3,0 MPa (30,0 bar), applied for at least 2 s.

## 5 General requirements

### 5.1 Materials

**5.1.1** All water mist nozzles shall be made from corrosion-resistant materials.

**5.1.2** A water mist nozzle shall be constructed to effect closure of its water seat for extended periods of time without leakage and to open as intended and release all parts from the minimum operating pressure up to the rated working pressure. For nozzles with intended operating pressures of 1,2 MPa (12 bar) or less, the closure of the water seat shall not be achieved by the use of a dynamic O-ring or similar seal (an O-ring or similar seal that moves during operation or is in contact with a component that moves during operation).

### 5.2 Prevention of field adjustment

The load on the heat-responsive element in automatic nozzles shall be set by the manufacturer in such a manner so as to prevent field adjustment or replacement. The nozzle orifice/deflector shall be permanently attached to the nozzle so as to prevent field adjustment or replacement.

### 5.3 Drawing review

The requirements and tests in Clauses 7 and 8 shall be conducted for each type of nozzle. Before testing, precise drawings of parts and the assembly shall be submitted together with the appropriate specifications and a copy of the manufacturer's design and installation instructions.

### 5.4 Pipe and fitting threads

**5.4.1** Pipe and fitting threads shall conform to the applicable requirements of ISO 7-1.

**5.4.2** If International Standards are not applicable, then National Standards are permitted to be used.

### 5.5 Strainers and filters

**5.5.1** All nozzles shall be constructed so that a sphere of diameter 5 mm can pass through each water passage in the nozzle. Nozzle with smaller openings shall utilize an integral strainer with each nozzle.

**5.5.2** Nozzle strainers or filters shall be constructed from corrosion-resistant materials. The maximum dimension of an opening in the strainer or filter shall not exceed 80 % of the smallest orifice diameter being protected.

## 6 Elastomeric materials

### 6.1 Properties

An elastomer used to provide a water seal shall be tested to determine that it has the following properties.

- a) As-received materials, when tested in accordance with ISO 37, shall be of minimum tensile strength of 3,4 MPa for silicone rubber having the characteristic constituent of poly-organo-siloxane and 10,3 MPa for other elastomers.
- b) When tested in accordance with ISO 188, the physical properties after oven aging at the time and temperature specified in Table 1 shall be at least 60 % of the original tensile strength and elongation values.

### 6.2 Test specimen

A part with an inside diameter larger than 25 mm shall be subjected in whole to the above tests. If the size of the actual part is less than 25 mm or otherwise precludes accurate testing, larger samples of similar parts or sheet material made of the same compound are to be subjected to the tests.

**Table 1 — Oven ageing**

Maximum service temperature °C	Oven time h	Oven temperature °C
60	70	100
75	168	100
80	168	113
90	168	121
105	168	136
115	1 440	123
125	1 440	133
135	1 440	143
145	1 440	153
150	1 440	158
155	1 440	164
165	1 440	174
175	1 440	184
185	1 440	194
195	1 440	204
200	1 440	210
210	1 440	220
220	1 440	230
230	1 440	240
240	1 440	250
250	1 440	260

## 7 Water mist nozzle requirements (see Clause 8)

### 7.1 Dimensions

Nozzles shall be provided with a 6 mm or larger nominal inlet thread. The dimensions of all threaded connections shall conform to International Standards where applied. If International Standards are not applicable, National Standards may be used.

### 7.2 Nominal operating temperatures

**7.2.1** The nominal operating temperatures of automatic glass bulb nozzles shall be as indicated in Table 2.

**7.2.2** The nominal operating temperatures of automatic fusible element nozzles shall be specified in advance by the manufacturer and verified in accordance with 7.3. They shall be determined as a result of the nominal release temperature test. See 8.6.1. Nominal operating temperatures shall be within the ranges specified in Table 2.

**7.2.3** The nominal operating temperature that is to be marked on the nozzle shall be that which is determined when the nozzle is tested in accordance with 8.6.1, taking into account the specifications of 7.3.

**Table 2 — Nominal release temperature**

Glass bulb nozzles		Fusible element nozzles	
Nominal release temperature °C	Liquid colour code	Nominal release temperature °C	Colour code
57	orange	57 to 77	uncoloured
68	red	80 to 107	white
79	yellow	121 to 149	blue
93 to 107	green	163 to 191	red
121 to 141	blue		
163 to 182	mauve		

### 7.3 Operating temperatures

Automatic nozzles shall open within a temperature range of  $\vartheta \pm (0,035\vartheta + 0,62)$  °C where  $\vartheta$  is the nominal operating temperature.

### 7.4 Water flow and distribution and droplet size

#### 7.4.1 Flow constant (see 8.10)

**7.4.1.1** The flow constant  $K$  for nozzles shall be calculated by the following formula:

$$K = \frac{q}{p^{0,5}}$$

where

$p$  is the pressure, in bars;

$q$  is the flow rate, in l/min.

**7.4.1.2** The value of the flow constant  $K$  published in the manufacturer's design and installation instructions shall be verified using the test method of 8.10. The average flow constant  $K$  shall be within  $\pm 5\%$  of the manufacturer's value.

**7.4.2 Water distribution** [see 8.11.1 and 10.2 g)]

The discharge characteristics of the nozzle shall be determined in accordance with 8.11.1.

**7.4.3 Water droplet size and velocity** [see 8.11.2 and 10.2 g)]

The water droplet size distribution and droplet velocity distribution of the nozzle shall be determined in accordance with 8.11.2.

**7.5 Function** (see 8.5)

**7.5.1** When tested in accordance with 8.5.1 to 8.5.4, an open nozzle fitted with a protective device for the outlet shall release within 10 s after the application of pressure. An automatic nozzle shall open and, within 5 s after the release of the heat responsive element, shall operate satisfactorily by complying with the requirements of 7.4.1. Any lodgement of released parts shall be cleared within 10 s of release or the nozzle shall then comply with the requirements of 7.4.2 and 7.4.3.

**7.5.2** A nozzle shall not sustain damage as a result of the functional test specified in 8.5.5 and shall have the same flow constant range and water droplet size and velocity within 5 % of values as previously determined in 7.4.1 and 7.4.3.

**7.6 Strength of body** (see 8.3)

An automatic nozzle shall not show permanent elongation of more than 0,2 % between the load-bearing points after being subjected to two times the average service load as determined using the method of 8.3.

**7.7 Strength of release element**

**7.7.1 Glass bulb** (see 8.9.1)

When tested in accordance with 8.9.1, glass bulb elements shall

- a) have an average strength of at least six times the average service load, and
- b) have a design strength lower tolerance limit ( $L_{tol,1}$ ) on the strength distribution curve of at least two times the upper tolerance limit ( $L_{tol,2}$ ) of the service load distribution curve based on calculations with a degree of confidence ( $I$ ) of 0,99 for 99 % of the samples ( $P$ ). Calculations will be based on Normal or Gaussian distribution except where other distribution can be shown to be more applicable due to manufacturing of design factors.

**7.7.2 Fusible elements**

Fusible heat-responsive elements in the ordinary temperature range shall be designed to

- a) sustain a load of 15 times its design load corresponding to the maximum service load measured in 8.3 for a period of 100 h when tested in accordance with 8.9.2 or
- b) demonstrate the ability to sustain the design load when tested in accordance with 8.9.2.