

---

---

**Cogeneration systems — Technical  
declarations for planning, evaluation and  
procurement**

*Systèmes de cogénération — Déclarations techniques pour la  
planification, l'évaluation et l'acquisition*

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

ISO 26382:2010

<https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010>



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

ISO 26382:2010

<https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2010

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

Foreword .....	iv
<b>1 Scope .....</b>	<b>1</b>
<b>2 Normative references .....</b>	<b>1</b>
<b>3 Terms and definitions .....</b>	<b>1</b>
<b>4 Key project information and analysis for evaluation.....</b>	<b>3</b>
4.1 General .....	3
4.2 Site conditions and energy demands.....	3
4.3 Related policies and regulations .....	5
4.4 CGS planning .....	5
4.5 System's operational simulation .....	8
4.6 Planning of comparison with a target comparable to the CGS .....	9
<b>5 CGS evaluation .....</b>	<b>9</b>
5.1 Economic evaluation.....	9
5.2 Energy saving evaluation .....	10
5.3 Environmental evaluation.....	11
5.4 Availability and reliability evaluation .....	11
5.5 Total evaluation .....	11
5.6 Evaluation procedure.....	12
<b>6 Primary information and works for CGS procurement.....</b>	<b>13</b>
6.1 Inquiry phase .....	13
6.2 Formal procurement.....	13
<b>Annex A (informative) Typical evaluation procedure for CGS planning .....</b>	<b>14</b>
<b>Annex B (informative) Typical life-cycle cost analysis .....</b>	<b>16</b>
<b>Annex C (informative) Typical CGS diagram and flowcharts .....</b>	<b>17</b>
<b>Annex D (informative) Calculation method for the period of time during which the CGS and the conventional system have equal expenditures.....</b>	<b>21</b>
<b>Annex E (informative) Calculation method for total profit during the plant life time.....</b>	<b>23</b>
<b>Annex F (informative) Job classification related to information and works for CGS procurement .....</b>	<b>24</b>
<b>Bibliography.....</b>	<b>26</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 26382 was prepared by Technical Committee ISO/TC 192, *Gas turbines*.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[ISO 26382:2010](https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4f1e-b002-3933a0d16081/iso-26382-2010)

<https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4f1e-b002-3933a0d16081/iso-26382-2010>

# Cogeneration systems — Technical declarations for planning, evaluation and procurement

## 1 Scope

This International Standard describes the technical declarations for a cogeneration system (CGS) that simultaneously supplies electric power and heating and/or cooling, for planning, evaluation and procurement.

It applies to the identification of investigation items for project evaluation, CGS evaluation, and primary information works for CGS procurement.

It also specifies necessary check items in CGS planning, provides a procedure to obtain the satisfactory configuration of the CGS for each project, and includes a detailed process diagram of the key development steps.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 15663-2:2001, *Petroleum and natural gas industries — Life-cycle costing — Part 2: Guidance on application of methodology and calculation methods*

## 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

### 3.1

#### **asset**

resource owned by an organization, normally for the purpose of generating income or increasing value

### 3.2

#### **auxiliary heating and/or cooling sources**

equipment installed in the CGS which supply additional heating and/or cooling, as required

EXAMPLE Steam and/or hot water boilers, direct-fired absorption chillers/heaters, and motor-driven machines.

### 3.3

#### **availability**

share of the total time that the CGS is available to produce electric power, heating and/or cooling as required during a defined period, normally a calendar year

### 3.4

#### **capital expenditure**

money used to purchase, install and commission a capital asset

[ISO 15663-1:2000, definition 2.1.6]

**3.5**  
**cogeneration system**  
**CGS**

facility which simultaneously generates electric power and heating and/or cooling using exhaust gas or waste heat from engines or prime movers

**3.6**  
**conventional system**

system or equipment which supplies electric power (including imported electric power from an external grid) and heating and/or cooling independently without using exhaust gas or waste heat from engines or prime movers

**3.7**  
**fuel supply agreement**

agreement entered into with a fuel supplier which provides the basis of ensuring the fuel supply requirements of the facility over a defined period

**3.8**  
**internal rate of return**  
**IRR**

discount rate that gives a net present value equal to zero

NOTE For more information on this time-discounted measure of investment desirability, see ISO 15663-2:2001, 4.1.4.

**3.9**  
**life cycle**

all development stages of an item of equipment or function, from when the study commences up to and including disposal

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

[ISO 15663-1:2000, definition 2.1.14]

[ISO 26382:2010](https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010)

**3.10**  
**life-cycle cost**  
**LCC**

<https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010>

discounted cumulative total of all costs incurred by a special function or item of equipment over its life cycle

[ISO 15663-1:2000, definition 2.1.15]

NOTE Life-cycle cost means the sum of all the expenditures associated with the project during its entire service life. A method for calculating the life-cycle cost is shown in Annex B.

**3.11**  
**net present value**  
**NPV**

sum of the total discounted costs and revenues

[ISO 15663-1:2000, definition 2.1.18]

**3.12**  
**operating expenditure**

money used for operation and maintenance, including associated costs such as logistics and spares

[ISO 15663-1:2000, definition 2.1.19]

**3.13****payback period**

period after which the initial capital invested has been paid back by the accumulated net revenue earned

[ISO 15663-1:2000, definition 2.1.20]

NOTE The payback-period method is not equivalent to the internal-rate-of-return method. The payback-period method is recommended only as a secondary method of measuring investment worth. In particular, it is suggested that the payback-period method be used in addition to a method based on the time value of money.

**3.14****reliability**

share of the time outside of planned maintenance and other planned shut-downs that the CGS can produce electric power and heat as required during a defined period, normally a calendar year

**3.15****scheduled maintenance**

maintenance of the CGS at regularly scheduled times

NOTE Scheduled maintenance includes planning times for the inspection, adjustment and exchange of equipment to prevent the CGS from malfunctioning and to recover efficiency and performance.

**3.16****sensitivity analysis**

analysis for determining the effects of the uncertainties in estimating parameter values, which is tested by independently varying one parameter at a time to determine how sensitive each parameter is to the project analysis and, therefore, the project risk

NOTE The testing process for any item under evaluation establishes whether or not the final conclusion is sensitive to a change in assumption. The variables subjected to sensitivity analysis will usually include capital costs, overall conversion efficiency, completion time, fuel costs and the escalation of costs.

<https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010>

**3.17****system design**

design of the CGS

**4 Key project information and analysis for evaluation****4.1 General**

In order to carry out the proper evaluation of the CGS, the following items shall be accurately analysed at each stage of the investigation. The important investigation items are listed in 4.2 through 4.4, and descriptions on detailed parameters are provided. Items included in this category should basically be provided by the purchaser.

**4.2 Site conditions and energy demands****4.2.1 Site conditions**

The purchaser of a CGS shall identify the installation site and related conditions necessary for the planning of the CGS. The following environmental conditions and various regulatory requirements which may affect the planning of the CGS shall be considered:

- weather conditions, average and maximum (predominant wind direction, wind speed, precipitation of rain and snow, etc.);
- general air quality (industrial emissions, sand, salt, soil, pollen, etc.);

- ambient conditions (temperature, pressure and humidity) including annual averages, maximum and minimum conditions;
- water supply temperature, its quality and quantity (hot-water supply, cooling water, de-mineralised water, water processing, etc.);
- land-use classification (business district, rural area, etc.);
- environmental air and effluent emission regulations (CO, CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>x</sub>, particulate matters, unburned hydrocarbon, visible smoke, cooling tower plume, etc.);
- regulations for vibration and noise (influence on neighbourhood);
- input fuel [type of fuel, specific energy, chemical composition, temperature (maximum and minimum), pressure (maximum and minimum), other properties];
- installation site (indoor, outdoor, seismic zone, site history, load-bearing capacity of soil, ground water level, frost line, snow load, sandstorms, transportation conditions, grid voltage, regulations for health and safety, etc.).

#### 4.2.2 Energy demands

##### 4.2.2.1 Investigation items for specifying energy demand

Maximum and minimum values, as well as data about variations in energy demand, shall be investigated carefully by the purchaser, including the demands for electric power and heating and/or cooling.

The following conditions related to energy demands shall also be clarified:

- electric power demand and voltage, frequency and power factor to be delivered;
- restrictions from the electrical grid, maximum power output, frequency variations, etc.;
- thermal demand, flow rate, pressure, temperature and quality requirements for heating and/or cooling to be delivered and to be returned;
- electrical and/or thermal load profile over a weekday and a weekend day (24 hours) allowing for process or seasonal demand variation.

##### 4.2.2.2 Investigation of energy demand pattern

When a CGS is installed at a given site, it is important to identify the site classification because requirements for electric power and heating and/or cooling differ among various types of sites.

Typical types of facilities are as follows:

- office;
- hotel (resort, city, business, etc.);
- hospital (general, independent, etc.);
- store (retail, restaurant, department, supermarket, etc.);
- public site (government, hall, library, museum, etc.);
- sport, health or leisure facilities (swimming pool, gym, aquarium, etc.);
- computer centre;



- residence (apartment, detached house, etc.);
- welfare facility;
- educational institution (university, elementary or junior/senior high schools, etc.);
- compound facility (integrated building including different categories);
- district heating and/or cooling facility (facility which supplies heating and/or cooling to buildings located in a district);
- industrial factory (food, chemical and pharmaceutical machinery, electrical equipment, iron and metal, textile, pulp and paper, gas/oil and/or other energy, glass soda and ceramics, etc.).

If the facility is a building, it is important to know the total floor space, number of floors, area classification for each usage, and both the total area and the lay-down areas which are available during the construction.

### 4.3 Related policies and regulations

Related government policies and regulations, both local and national, are applicable to the installation of a CGS.

A detailed consideration of such policies is necessary. These policies may include:

- business assistance policies (tax reduction, financial loans, subsidy system, etc.);
- deregulations for power supply (liberalization, etc.).

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

### 4.4 CGS planning

#### 4.4.1 General [ISO 26382:2010 https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010](https://standards.iteh.ai/catalog/standards/sist/5d2ffb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010)

When considering the planning of the CGS, the items included in this category shall be decided by the purchaser with reference to technical data proposed by the manufacturers.

#### 4.4.2 System diagrams

Examples of the types of systems to be considered are shown in the diagram and flowcharts provided for guidance purposes in Annex C.

#### 4.4.3 Type of prime mover

The type of prime mover shall be examined and selected by taking into consideration the specified or desired electric power and heat demands, heat-to-electric power ratio and other particular requirements of the project.

The type to be examined may include:

- gas turbine<sup>1)</sup>;
- reciprocating internal combustion engines (gas engine, diesel engine);
- steam turbine.

See the related flowcharts in Annex C.

---

1) A CGS using one or more gas turbine(s) is called a “gas turbine CGS”.

#### 4.4.4 Electric power output

Electric power output and generating efficiency vary with the type of prime mover, operating loads and ambient conditions.

Considerations shall include:

- output at electric generator terminal;
- output at export delivery point;
- rated and partial load efficiencies.

#### 4.4.5 Heat recovery

Exhaust heat from the prime mover is recovered as heating and/or cooling outputs.

Quantities of heating and/or cooling outputs will vary depending upon the load conditions and the ambient conditions.

Considerations shall include:

- type of heat recovery medium (hot and/or chilled water, steam, hot oil and/or direct use in drying or thermally activated equipment);
- thermal process demand (mass flow rate, supply pressure, supply temperature, total rated thermal demand, other specific requirement);
- heat recovery rate;
- heating medium return flow and condition (e.g. condensate).

**STANDARD PREVIEW**  
**(standards.itech.ai)**

ISO 26382:2010

<https://standards.itech.ai/catalog/standards/sist/5d2fb7b-84d1-4fle-b002-3933a0d16081/iso-26382-2010>

#### 4.4.6 Fuel

The CGS input fuel may be gas, liquid or solid and shall be selected after careful consideration of availability and economics. Some prime movers may have strict limitations affecting the selection of gas and liquid fuels such as residual oil, heavy fuel oils, blast furnace gas or gases with high hydrogen content. The types of fuel shall be selected by taking into consideration service conditions (supply temperature, pressure), environmental factors and the cost at the time the prime mover is being selected.

Other considerations shall include:

- serviceable fuels, their properties and variability (composition, net specific energy, Wobbe index, sulfur content, etc.);
- fuel handling, delivery steam for pipe heating of heavy oil, fuel treatment and storage (if applicable); including the clarification of the storage capacity, supply pressure and supply temperature;
- standby or alternative fuel; when the CGS is used for both continuous and intermittent uses, it is advisable to consider the necessity of a standby (or alternative) fuel; there can be certain special conditions attached to the fuel supply agreement that require a standby fuel;
- fuel consumption rate;
- net specific energy;
- reliability of main fuel supply.

#### 4.4.7 Planning of electric power use

Electric power systems shall be designed from economic and reliability viewpoints taking into account items that will affect the electric power demand's pattern and factors, such as:

- factors concerning introduction of a CGS (peak shaving, base load, common use together with emergency service, back-up for temporary electric power failure);
- whether it will be grid-connected or independently operated;
- the possibility of exporting electric power back to the grid;
- allowable minimum importing power to minimize operating costs;
- operation of the CGS if there is a grid-failure accident (shutdown, shutdown and automatic re-start without shutdown);
- number of cogeneration units;
- contracted electric power, including terms of agreement;
- possibility of importing electric power from the commercial grid during the failure or maintenance of the CGS;
- type of operation (electric power or heat-oriented);
- type of control of electric power system (such as constant import/export control);
- load factor of electric generator (maximum, minimum);
- necessary auxiliary electric power.

#### 4.4.8 Planning of recovered heat use

The energy flow of air-conditioning, export steam, hot and/or chilled water supply shall be planned by taking into consideration the pattern of the heat-use equipment and the order of the recovered heat use.

The heat balance between the demands for heat and the capacity of the water equipment shall be confirmed. Heat balances shall be prepared for a number of defined operational modes and plant configurations to ensure compatibility between production and off-take, taking into account factors such as:

- type of recovered heat use (space heating and/or cooling, hot water and/or steam supply);
- auxiliary heat source (for supplemental use and/or usage in case of CGS outage);
- storage tank;
- order of recovered heat use (space heating and/or cooling and hot water and/or steam supply);
- efficiency of heat-use equipment;
- return of condensate;
- existing process equipment such as steam turbines, boilers and heat exchangers.

#### 4.4.9 Planning of operation and maintenance

The operational stage of the CGS is planned by taking into account annual, monthly and daily maintenance schedules through a one-year period. Consideration shall be given to the planning of maintenance between major overhauls, which may occur over a number of years. Typical considerations include:

- operational planning (continuous, intermittent, seasonal usage, days on standby, maintenance months and days required considering operational and process restrictions of customer site);
- number of generators possible to operate under normal circumstances;
- daytime, night-time, weekday and weekend considerations.

#### 4.5 System's operational simulation

##### 4.5.1 General

After determining the factors or parameters in 4.2 through 4.4, the system's operational simulation shall be performed to obtain detailed figures for the evaluation of the CGS.

This operational simulation shall take into account monthly, hourly, weekly and holiday patterns of electric power and heating and/or cooling. In addition, the long-term energy-demands profile shall be considered. The relevant time period used in the evaluation of the CGS shall be decided after considering all these terms.

##### 4.5.2 Operational patterns

iTeh STANDARD PREVIEW

(standards.iteh.ai)

Operational patterns shall be compiled for performing the system's operational simulations. Typical patterns include:

- operational pattern of electric power through more than one year (electric generator, auxiliary units, electric power from and to the grid);
- operational pattern of recovered heat through more than one year (hot and/or chilled water, and/or steam);
- operational pattern of auxiliary heat through more than one year;
- operational pattern of fuel consumption through more than one year (gas, oil);
- operating days through more than one year.

##### 4.5.3 Energy costs and incomes

Calculated costs and incomes are based on the result of an operational simulation for economic evaluation of the CGS.

These costs and incomes are calculated with parameters, such as:

- electric power and heating and/or cooling through more than one year (electric generator, auxiliary units, electric power from and to the grid);
- necessary fuel consumption through one year (gas, oil) for the prime mover during normal operation, and for the auxiliary heat source during maintenance;
- contracted electric power;
- charge rate (electric power from and to the grid, gas, oil);