



SLOVENSKI STANDARD
SIST ISO 383:1995

01-avgust-1995

Laboratorijska steklovina - Medsebojno zamenljivi stožčasto brušeni spoji

Laboratory glassware -- Interchangeable conical ground joints

Verrerie de laboratoire -- Assemblages coniques rodés interchangeables

Ta slovenski standard je istoveten z: ISO 383:1976

[SIST ISO 383:1995](https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995)

<https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>

ICS:

71.040.20	Laboratorijska posoda in aparati	Laboratory ware and related apparatus
-----------	----------------------------------	---------------------------------------

SIST ISO 383:1995

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 383:1995

<https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>

INTERNATIONAL STANDARD**383**

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION · МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ · ORGANISATION INTERNATIONALE DE NORMALISATION

Laboratory glassware — Interchangeable conical ground joints

Verrerie de laboratoire — Assemblages coniques rodés interchangeables

iTeh STANDARD PREVIEW

First edition — 1976-08-01

(standards.iteh.ai)

SIST ISO 383:1995

<https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>

UDC 542.231.7

Ref. No. ISO 383-1976 (E)

Descriptors : laboratory glassware, joints (junctions), conical components, specifications, interchangeability.

FOREWORD

ISO (the International Organization for Standardization) is a worldwide federation of national standards institutes (ISO Member Bodies). The work of developing International Standards is carried out through ISO Technical Committees. Every Member Body interested in a subject for which a Technical Committee has been set up has the right to be represented on that Committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the Technical Committees are circulated to the Member Bodies for approval before their acceptance as International Standards by the ISO Council.

Prior to 1972, the results of the work of the Technical Committees were published as ISO Recommendations; these documents are now in the process of being transformed into International Standards. As part of this process, Technical Committee ISO/TC 48 has reviewed ISO Recommendation R 383 and found it technically suitable for transformation. International Standard ISO 383 therefore replaces ISO Recommendation R 383-1964 to which it is technically identical.

ISO Recommendation R 383 was approved by the Member Bodies of the following countries :

Australia	Germany	Romania
Austria	Greece	Spain
Belgium	India	Sweden
Canada	Israel	United Kingdom
Chile	Japan	U.S.A.
Colombia	Netherlands	U.S.S.R.
Czechoslovakia	New Zealand	
France	Poland	

The Member Body of the following country expressed disapproval of the Recommendation on technical grounds :

Italy*

* Subsequently, this Member Body approved the Recommendation.

No Member Body disapproved the transformation of ISO/R 383 into an International Standard.

Laboratory glassware — Interchangeable conical ground joints

0 INTRODUCTION

The purpose of this International Standard is to ensure interchangeability between standard conical ground glass joints, irrespective of where they are manufactured. In order to achieve interchangeability, it is necessary that each of the following requirements be adequately specified, including appropriate tolerances :

- a) taper;
- b) large end diameter;
- c) length of ground zone;
- d) surface finish.

The nominal dimensions listed below are based on the series of joints already widely used in many countries; in particular, the series of large end diameters represents the nearest acceptable compromise to the R 40/3 series of preferred numbers (5, 3, ..., 100) laid down in ISO 3, *Preferred numbers — Series of preferred numbers*.

From the practical point of view, and especially because of the difficulty of carrying out precise measurements on the ground portions of the finished joints, it is desirable to apply a gauging system which allows rapid checking of the essential dimensions. The definition of these dimensions in clause 6 is an integral part of this International Standard, but the system of gauging described in annex A, while it has been proved in practice as fully satisfactory, is not the only one which can be applied for the purpose.

The leakage test described in annex B is one which is commonly used for testing joints, but its inclusion in this International Standard is not intended to preclude the use of other tests which may be found more convenient for particular purposes. Attention is specifically drawn to the method of pneumatic gauging.¹⁾

1 SCOPE AND FIELD OF APPLICATION

This International Standard specifies the essential geometric requirements for interchangeability in relation to four series of conical ground glass joints for laboratory use.

2 REFERENCE

ISO/R 468, *Surface roughness*.

3 TAPER

The taper of the joints shall be such as to give one increment on diameter for ten increments on axial length, with a tolerance of $\pm 0,006$ on the diameter increment, i.e. a taper of $(1,00 \pm 0,006)/10$.

NOTE — Actual manufacturing techniques normally result in a tighter tolerance than that given above, but owing to the lack of experimental evidence it is not yet possible to reduce the specified value.

4 LARGE END DIAMETERS

The following series of large end diameters shall be adopted :

5 — 7,5 — 10 — 12,5 — 14,5 — 18,8 — 21,5 — 24 — 29,2 —
34,5 — 40 — 45 — 50 — 60 — 71 — 85 — 100 mm

5 LENGTH OF GROUND ZONE

The length of the ground zone l , in millimetres, is calculated using the formula

$$l = k\sqrt{d}$$

where

k is a constant;

d is the large end diameter, in millimetres.

1) This method is described in *Laboratory practice*, March 1958, Vol. 7, No. 3, "Pneumatic gauging applied to standard ground glass joints", by I.C.P. Smith.

ISO 383-1976 (E)

The calculated length is rounded off to the nearest whole number.

The four series of joints listed in table 1 are obtained by using the values, 2, 4, 6 and 8 for the constant k .

$k6$ is the preferred series.

TABLE 1 – Series of joints

Dimensions in millimetres

Large end diameter	Length of ground zone			
	k2 series	k4 series	k6 series	k8 series
5		9	13	18
7,5		11	16	22
10		13	19	25
12,5		14	21	28
14,5		15	23	30
18,8	9	17	26	35
21,5		19	28	37
24	10	20	29	39
29,2	11	22	32	43
34,5	12	23	35	47
40	13		38	
45	13		40	
50	14		42	
60			46	
71			51	
85			55	
100			60	

6 TOLERANCES ON DIAMETER AND LENGTH

The diameter and length of the ground zone shall be such that, when it is placed with its axis in the plane of the dimensional frame shown in figure 1, it fits in such a way that the upper and lower edges of the ground surface fall within the zones of height h_1 and h_2 respectively, the values of d , l , h_1 and h_2 for any particular joint size being taken from table 2. For special purposes, the ground surface may extend beyond these limits, provided that the zone of length l is always included within this ground portion.

A system of gauging suitable for finding out whether joints fall within these limits is described in annex A.




FIGURE 1

<https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>

TABLE 2 – Dimensions and tolerances
(see clause 6 and figure 1)

Dimensions in millimetres

Nominal diameter of joint	d	k2 series			k4 series			k6 series			k8 series		
		l^*	h_1^{**}	h_2^{**}	l^*	h_1^{**}	h_2^{**}	l^*	h_1^{**}	h_2^{**}	l^*	h_1^{**}	h_2^{**}
5	5,1 ± 0,008				8	2	2	12	2	2	17	2,5	2
7,5	7,6 ± 0,008				10	2	2	15	2	2	21	2,5	2
10	10,1 ± 0,008				12	2	2	18	2	2	24	2,5	2
12,5	12,6 ± 0,010				13	2	2	20	2	2	27	2,5	2
14,5	14,6 ± 0,010				14	2	2	22	2	2	29	2,5	2
18,8	18,9 ± 0,015	8	2,5	2	16	2	2	25	2	2	34	2,5	2
21,5	21,6 ± 0,015				18	2	2	27	2	2	36	2,5	2
24	24,1 ± 0,015	9	2,5	2	19	2	2	28	2	2	38	2,5	2
29,5	29,3 ± 0,015	10	2,5	2	21	2	2	31	2	2	40	2,5	3,5
34,5	34,6 ± 0,015	11	2,5	2	22	2	2	34	2	2	43	2,5	3,5
40	40,1 ± 0,015	11	2,5	2,5				37	2	2			
45	45,1 ± 0,015	11	2,5	2,5				39	2	2			
50	50,1 ± 0,015	12	2,5	2,5				41	2	3			
60	60,1 ± 0,015							45	2	3			
71	71,1 ± 0,020							50	2	3			
85	85,1 ± 0,020							54	2	3			
100	100,1 ± 0,020							59	2	3			

* Tolerance on $l = \pm 0,015$.

** Tolerance on h_1 and $h_2 = \pm 0,010$.

7 SURFACE FINISH

The centre-line-average height of the ground surface shall not exceed $1\ \mu\text{m}$ and should preferably be less than $0,5\ \mu\text{m}$.

NOTE — The “centre-line-average height” of the ground surface is the average value R_a of the roughness as defined in ISO/R 468.

8 DESIGNATION

For convenience of reference to joints complying with the geometric requirements of this International Standard, the

use is recommended of a designation consisting of the following dimensions, expressed in millimetres :

- large end diameter of the joint (7,5 – 12,5 – 14,5 – 18,8 – 21,5 – 29,2 – 34,5 being rounded to 7 – 12 – 14 – 19 – 21 – 29 – 34 respectively), and
- length of ground zone,

separated by an oblique or horizontal stroke,

Example : 19/26 or $\frac{19}{26}$

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 383:1995

<https://standards.iteh.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>

ANNEX A

**SUITABLE GAUGING SYSTEM
FOR DIAMETER AND LENGTH OF CONICAL JOINTS**

The suggested gauges are made of hardened steel or other suitable material. The gauges for sockets are conical plugs with a step at each end, and the gauges for cones are conical rings with a step at each end; they are shown in figures 2 and 3. The cone semi-angle of each gauge is $2^{\circ} 51' 45'' \pm 15''$. (The sine of the specified angle is $0,049\ 94 \pm 0,000\ 07$.)

A separate gauge is required for each size of cone or socket, the gauge dimensions being given in table 2. When a socket or cone is fitted to its appropriate gauge, it should rest in such a position that the upper and lower ends of the ground zone lie wholly within the steps of height h_1 and h_2 respectively. For special purposes, the ground surface may extend beyond the outer extremity of the step at the smaller end, provided that it also extends to at least the inner extremity of the step at the larger end.




FIGURE 2 – Gauge for sockets




FIGURE 3 – Gauge for cones

iTech STANDARD PREVIEW
(standards.itech.ai)

SIST ISO 383:1995

<https://standards.itech.ai/catalog/standards/sist/99122942-c280-4a0e-9b2a-6b157360d14c/sist-iso-383-1995>