



**SLOVENSKI STANDARD**  
**SIST EN 300 119-6 V1.1.1:2015**  
**01-junij-2015**

---

**Okoljski inženiring (EE) - Evropski telekomunikacijski standard za prakso pri opremi - 6. del: Tehnične zahteve za harmonizirana stojala in ohišja z razširjenimi lastnostmi**

Environmental Engineering (EE) - European telecommunication standard for equipment practice - Part 6: Engineering requirements for harmonized racks and cabinets with extended features

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

<https://standards.iteh.ai/catalog/standards/sist/157b9259-05df-4162-a386-625f16c7198c/sist-en-300-119-6-v1-1-1-2015>

**Ta slovenski standard je istoveten z: EN 300 119-6 V1.1.1**

---

**ICS:**

19.040	Preskušanje v zvezi z okoljem	Environmental testing
33.050.01	Telekomunikacijska terminalna oprema na splošno	Telecommunication terminal equipment in general

**SIST EN 300 119-6 V1.1.1:2015**      **en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 300 119-6 V1.1.1:2015

<https://standards.iteh.ai/catalog/standards/sist/157b9259-05df-4162-a386-625f16c7198c/sist-en-300-119-6-v1-1-1-2015>

# ETSI EN 300 119-6 V1.1.1 (2015-02)



**Environmental Engineering (EE);  
European telecommunication standard  
for equipment practice;  
Part 6: Engineering requirements for  
harmonized racks and cabinets with extended features**

SIST EN 300 119-6 V1.1.1:2015  
625f16c7198c/sist-en-300-119-6-v1-1-1-2015

---

Reference

DEN/EE-0031

---

Keywords

environment, equipment practice, rack

**ETSI**

---

650 Route des Lucioles  
F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - NAF 742 C  
Association à but non lucratif enregistrée à la  
Sous-Préfecture de Grasse (06) N° 7803/88

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 300 119-6 V1.1.1:2015

<https://standards.iteh.ai/catalog/standards/sist/157b9259-05df-4162-a386-625f16c7194c/etsi-en-300-119-6-v1-1-1-2015>  
**Important notice**

The present document can be downloaded from:

<http://www.etsi.org/standards-search>

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the only prevailing document is the print of the Portable Document Format (PDF) version kept on a specific network drive within ETSI Secretariat.

Users of the present document should be aware that the document may be subject to revision or change of status. Information on the current status of this and other ETSI documents is available at

<http://portal.etsi.org/tb/status/status.asp>

If you find errors in the present document, please send your comment to one of the following services:

<https://portal.etsi.org/People/CommiteeSupportStaff.aspx>

---

**Copyright Notification**

---

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI.

The content of the PDF version shall not be modified without the written authorization of ETSI.

The copyright and the foregoing restriction extend to reproduction in all media.

© European Telecommunications Standards Institute 2015.

All rights reserved.

**DECT™**, **PLUGTESTS™**, **UMTS™** and the ETSI logo are Trade Marks of ETSI registered for the benefit of its Members. **3GPP™** and **LTE™** are Trade Marks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners.

**GSM®** and the GSM logo are Trade Marks registered and owned by the GSM Association.

# Contents

Intellectual Property Rights .....	4
Foreword.....	4
Modal verbs terminology.....	5
1 Scope .....	6
2 References .....	6
2.1 Normative references .....	6
2.2 Informative references.....	6
3 Abbreviations .....	7
4 Dimensions for miscellaneous racks/cabinets .....	7
4.1 Height .....	7
4.2 Width.....	7
4.3 Depth.....	7
4.4 Other dimensions.....	8
5 Accessibility and line-up of miscellaneous racks/cabinets.....	8
6 Floor loading .....	8
6.1 Weight per unit area of fully equipped miscellaneous rack/cabinet .....	8
6.2 Weight per unit area of cable support structure and cabling .....	8
6.3 Point loading .....	8
7 Structural load on a miscellaneous rack/cabinet .....	9
7.1 Static load.....	9
7.2 Dynamic load .....	9
8 External cable access.....	9
9 Dimensions of packaged rack/cabinet with extended features.....	9
<b>Annex A (informative): Illustrative figures.....</b>	<b>11</b>
History .....	16

---

## Intellectual Property Rights

IPRs essential or potentially essential to the present document may have been declared to ETSI. The information pertaining to these essential IPRs, if any, is publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: "*Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards*", which is available from the ETSI Secretariat. Latest updates are available on the ETSI Web server (<http://ipr.etsi.org>).

Pursuant to the ETSI IPR Policy, no investigation, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

---

## Foreword

This European Standard (EN) has been produced by ETSI Technical Committee Environmental Engineering (EE).

The present document is part 6 of a multi-part deliverable aimed at setting out, on a common basis, the installation engineering requirements for telecommunication practice, for housing equipment forming part of a public telecommunications network.

ETSI EN 300 119-1 [i.1] is a general introduction and explains the terminology used. ETSI EN 300 119-2 [i.2] specifies the engineering requirements for racks and cabinets. ETSI EN 300 119-3 [i.3] specifies the engineering requirements for miscellaneous racks and cabinets. ETSI EN 300 119-4 [i.4] covers engineering requirements for subracks in miscellaneous racks and cabinets. ETSI EN 300 119-5 [i.5] covers the preferred thermal management solutions for subracks, racks/cabinets and miscellaneous racks/cabinets installed indoors in restricted access locations, for the removal of heat dissipated by one or more subracks in a rack complying to the requirements of this multi-part standard.

The present document, ETSI EN 300 119-6, is defining extension to the existing parts of the standard to harmonize dimensions and to extend rack installation capabilities.

These extended features are:

- mounting bracket depth adjustment only on subrack level (as normally done on many other standardized equipment practices; e.g. 19 inches)
- full installation compatibility for installing rack line-ups with 300 mm and 600 mm depth (see ETSI EN 300 119-3 [i.3])
- common position of mounting brackets for both 300 mm and 600 mm depth
- recessed subrack mounting plane compared to ETSI EN 300 119-3 [i.3] and ETSI EN 300 119-4 [i.4] to allow more room for cable management and better cable access from front/rear aisle
- modular design for 300 mm/600 mm racks to improve installation and thermal management (e.g. back-to-back with 200 mm off-set)
- split up of 600 mm deep footprint into 2x300 mm so that both rack types allow the same subrack fixation plane
- 300 mm and 600 mm deep racks with back-to-back installation compatibility for subracks (option to mount two 280 mm deep subracks back to back in a 600x600 mm footprint)
- 300 mm and 600 mm deep racks with detachable side/rear covers to allow full cable duct access from the side
- common 10 mm thick door design for both 300 mm and 600 mm rack to improve commonality
- design subrack mounting plane in a manner so that not only 600 mm deep rack is a earthquake proof design but also the 300 mm rack (600 mm: ~7 inches deep upright; 300 mm ~3,5 inches deep upright; commonality with EIA rack standard for SNBF)

- option for rack side extensions to create enhanced cabling space and thermal management options (e.g. heat exchangers for water cooling to gain best energy efficiency for IT infrastructure) for both rack types (300 mm and 600 mm depth)
- keep the rack side structure open with optional side plates to increase cabling space and reduce costs in rack line-ups (only first and last rack would need a side plate)
- make ETSI mounting principle similar to SNBF (5 inches deep upright) which is used in USA telecommunication offices to gain more commonality for international markets
- Seismic Proof Design (target: IEC 61587-2 [i.6]) for both 300 mm and 600 mm deep rack
- Define extra front side cabling space for accommodating optical and electrical I/O cables
- 300 mm/600 mm commonalities (e.g. doors, feet, rack alarm indicator strip, etc.) provide various options for cost reduction due to higher volume and cost reduction, lower CAPEX due to less complexity and simplified logistics for deployment

The present document applies to all telecommunication equipment forming part of the public telecommunications network.

The present document is part 6 of a multi-part deliverable. Full details of the entire series can be found in part 1 [i.1].

<b>National transposition dates</b>	
Date of adoption of this EN:	19 February 2015
Date of latest announcement of this EN (doa):	31 May 2015
Date of latest publication of new National Standard or endorsement of this EN (dop/e):	30 November 2015
Date of withdrawal of any conflicting National Standard (dow):	30 November 2015

<https://standards.iteh.ai/catalog/standards/sist/157b9259-05df-4162-a386-625f16c7198c/sist-en-300-119-6-v1-1-1-2015>

## Modal verbs terminology

In the present document "**shall**", "**shall not**", "**should**", "**should not**", "**may**", "**may not**", "**need**", "**need not**", "**will**", "**will not**", "**can**" and "**cannot**" are to be interpreted as described in clause 3.2 of the [ETSI Drafting Rules](#) (Verbal forms for the expression of provisions).

"**must**" and "**must not**" are **NOT** allowed in ETSI deliverables except when used in direct citation.

---

# 1 Scope

The present document details requirements for racks and cabinets with extended features supplied unequipped. The racks/cabinets with extended features can be used for housing telecommunication equipment forming part of a public telecommunication network installed either on the public telecommunication operators' sites or in the premises of operator's customers. The racks/cabinets with extended features allow to accommodate various equipment, e.g. subracks (see ETSI EN 300 119-4 [i.4]) and have provisions for doors or covers.

ETSI EN 300 119-1 [i.1] defines the meaning of rack or cabinet in the context of the present document.

---

## 2 References

### 2.1 Normative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the reference document (including any amendments) applies.

Referenced documents which are not found to be publicly available in the expected location might be found at <http://docbox.etsi.org/Reference>.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are necessary for the application of the present document.

- [1] IEC 60917-2-1: "Modular order for the development of mechanical structures for electronic equipment practices - Part 2: Sectional specification - Interface co-ordination dimensions for the 25 mm equipment practice at Section 1: Detail specification - Dimensions for cabinets and racks".  
625f16c7198c/sist-en-300-119-6-v1-1-1-2015

### 2.2 Informative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the reference document (including any amendments) applies.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are not necessary for the application of the present document but they assist the user with regard to a particular subject area.

- [i.1] ETSI EN 300 119-1: "Environmental Engineering (EE); European telecommunication standard for equipment practice; Part 1: Introduction and terminology".
- [i.2] ETSI EN 300 119-2: "Environmental Engineering (EE); European telecommunication standard for equipment practice; Part 2: Engineering requirements for racks and cabinets".
- [i.3] ETSI EN 300 119-3: "Environmental Engineering (EE); European telecommunication standard for equipment practice; Part 3: Engineering requirements for miscellaneous racks and cabinets".
- [i.4] ETSI EN 300 119-4: "Environmental Engineering (EE); European telecommunication standard for equipment practice; Part 4: Engineering requirements for subracks in miscellaneous racks and cabinets".
- [i.5] ETSI EN 300 119-5: "Environmental Engineering (EE); European telecommunication standard for equipment practice; Part 5: Thermal management".



- [i.6] IEC 61587-2: "Mechanical structures for electronic equipment - Tests for IEC 60917 and 60297 - Part 2: Seismic tests for cabinets and racks".
- [i.7] ECIA EIA/ECA-310-E: "Cabinets, Racks, Panels, and Associated Equipment".

---

## 3 Abbreviations

For the purposes of the present document, the following abbreviations apply:

CAPEX	Capital Expenditure
EIA	Electronic Industries Alliance
IT	Information Technology
SNBF	Seismic Network Bay Frame

NOTE: Based on 23 inches EIA-310-E standard [i.7].

USA United States of America

---

## 4 Dimensions for miscellaneous racks/cabinets

### 4.1 Height

The height dimension (H) includes covers, feet or castors if these are an integral part of the rack/cabinet structure with extended features.

For telecommunication centres and customer sites, H shall be 2 200 mm.

The rack/cabinet with extended features shall have provision within its height for the attachment of parts for interfacing to any overhead structure.

The miscellaneous racks/cabinets shall also be provided with devices which can be height-adjusted to compensate for any unevenness in the floor. The scope for height adjustment shall be at least 25 mm. The nominal miscellaneous rack/cabinet height shall be measured when the adjustment devices are at their fully retracted positions.

### 4.2 Width

The width dimension (W) includes covers if they are an integral part of the miscellaneous rack/cabinet.

W shall be 600 mm.

The sides of any rack/cabinet with extended features shall not interfere with the assembly of adjacent racks/cabinets (into a straight line-up). The suppliers shall ensure that the rack/cabinet with extended features will fit into the space between the grid lines, as illustrated in figure A.1. Manufacturing tolerances shall therefore be so arranged that this objective will always be achieved, even when miscellaneous racks/cabinets are delivered from different suppliers.

NOTE: If additional equipment at the end(s) of a suite of racks/cabinets with extended features is required the associated coordination dimensions should be specified as an integer multiple of the mounting pitch of 25 mm for each side during equipment practice design and should be agreed between supplier and user.

### 4.3 Depth

The depth dimension (D) includes:

- doors or covers of the rack/cabinet structure with extended features if present;
- protruding parts e.g. switches, lamps, hinges, locks, electro-static discharge points, etc.;
- connectors, cabling, cooling fins, etc.