

Designation: D 3017 - 01

# Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth)<sup>1</sup>

This standard is issued under the fixed designation D 3017; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

## 1. Scope

1.1 This test method covers the determination of water content of soil and rock by the thermalization or slowing of fast neutrons where the neutron source and the thermal neutron detector both remain at the surface.

1.2 The water content in mass per unit volume of the material under test is determined by comparing the detection rate of thermalized or slow neutrons with previously established calibration data.

1.3 The values stated in SI units are to be regarded as the standard. The inch-pound equivalents may be approximate.

1.3.1 It is common practice in the engineering profession to concurrently use pounds to represent both a unit of mass (lbm) and of force (lbf). This implicitly combines two systems of units, that is, the absolute system and the gravitational system. This test method has been written using the absolute system for water content (kilograms per cubic metre) in SI units. Conversion to the gravitational system of unit weight in lbf/ft<sup>3</sup> may be made by multiplying by 0.06243 or in kN/m<sup>3</sup> by multiplying by 9.807. The recording of water content in pound-force per cubic foot should not be regarded as non-conformance with this test method although the use is scientifically incorrect.

1.4 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

# 2. Referenced Documents

2.1 ASTM Standards:

- D 1556 Test Method for Density and Unit Weight of Soil in Place by the Sand-Cone Method<sup>2</sup>
- D 2167 Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon  $Method^2$

- D 2216 Test Method for Laboratory Determination of Water (Moisture) Content of Soil and Rock by Mass<sup>2</sup>
- D 2922 Test Methods for Density of Soil and Soil Aggregate in Place by Nuclear Methods (Shallow Depth)<sup>2</sup>
- D 2937 Test Method for Density of Soil in Place by the Drive-Cylinder  $Method^2$
- D 4643 Test Method for Determination of Water (Moisture) Content of Soil by the Microwave Oven Heating<sup>2</sup>
- D 4718 Practice for Correction of Unit Weight and Water Content for Soils Containing Oversize Particles<sup>2</sup>

# 3. Significance and Use

3.1 The test method described is useful as a rapid, nondestructive technique for the in-place determination of water content of soil and rock.

3.2 The test method is used for quality control and acceptance testing of compacted soil and rock for construction and for research and development. The non-destructive nature allows repetitive measurements at a single test location and statistical analysis of the results.

3.3 The fundamental assumptions inherent in the test method are that the hydrogen present is in the form of water as defined by Test Method D 2216, and that the material under test is homogeneous.

3.4 Test results may be affected by chemical composition, sample heterogeneity, and, to a lesser degree, material density and the surface texture of the material being tested. The technique also exhibits spatial bias in that the apparatus is more sensitive to water contained in the material in close proximity to the surface and less sensitive to water at deeper levels.

#### 4. Interferences

4.1 The chemical composition of the sample may dramatically affect the measurement and adjustments may be necessary. Hydrogen in forms other than water, as defined by Test Method D 2216, and carbon will cause measurements in excess of the true value. Some chemical elements such as boron, chlorine, and minute quantities of cadmium will cause measurements lower than the true value.

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States.

<sup>&</sup>lt;sup>1</sup> This test method is under the jurisdiction of ASTM Committee D18 on Soil and Rock and is the direct responsibility of Subcommittee D18.08 on Special and Construction Control Tests.

Current edition approved June 10, 2001. Published August 2001. Originally published as D 3017 - 72. Last previous edition D  $3017 - 96^{\epsilon 1}$ .

<sup>&</sup>lt;sup>2</sup> Annual Book of ASTM Standards, Vol 04.08.

4.2 The water content determined by this test method is not necessarily the average water within the volume of the sample involved in the measurement. The measurement is heavily influenced by the water content of the material closest to the surface. The volume of soil and rock represented in the measurement is indeterminate and will vary with the water content of the material. In general, the greater the water content of the material, the smaller the volume involved in the measurement. At  $160 \text{ kg/m}^3$  (10 lbf/ft<sup>3</sup>), approximately 50 % of the typical measurement results from the water content of the upper 50 to 75 mm (2 to 3 in.).

4.2.1 If samples of the measured material are to be taken for purposes of correlation with other test methods or rock correction, the volume measured can be approximated by a 200-mm (8-in.) diameter cylinder located directly under the center line of the fast neutron source and thermal neutron detector. The height of the cylinder to be excavated is approximated by:

Moisture Content		Cylinder Height		Volume	
kg/m <sup>3</sup>	lbf/ft <sup>3</sup>	mm	in.	m <sup>3</sup>	ft <sup>3</sup>
80	5	250	10	0.0079	0.29
160	10	200	8	0.0063	0.23
240	15	150	6	0.0047	0.17
320	20	125	5	0.0039	0.15
400	25	112	4.5	0.0035	0.13
480	30	100	4	0.0031	0.12

NOTE 1—The volume of field compacted material sampled by the test can effectively be increased by repeating the test at immediately adjacent (vertically or horizontally) locations and averaging the results.

4.3 Other neutron sources must not be within 8 m (25 ft) of equipment in operation.

# 5. Apparatus

5.1 While exact details of construction of the apparatus may vary, the system shall consist of: ds/astm/b02ct510-3ecc-4

5.1.1 *Fast Neutron Source*—A sealed mixture of a radioactive material such as americium or radium and a target material such as beryllium.

5.1.2 *Slow Neutron Detector*—Any type of slow neutron detector such as boron trifluoride or helium-3 proportional counter.

5.1.3 *Readout Device*—A suitably timed scaler(s). Usually the readout device will contain the high-voltage supply necessary to operate the detector, and low-voltage power supply to operate the readout and accessory devices.

5.1.4 *Housing*—The source, detector, readout device, and power supply shall be in housings of rugged construction which shall be water and dust resistant.

5.1.5 *Reference Standard*—A block of hydrogeneous material for checking equipment operation and to establish conditions for a reproducible count rate.

5.1.6 *Site Preparation Device*—A steel plate, straightedge, or other suitable leveling tools which may be used to plane the test site to the required smoothness.

5.2 Calibrate apparatus in accordance with Annex A1.

5.3 Determine the precision of the apparatus in accordance with Annex A2.

## 6. Hazards

6.1 This equipment utilizes radioactive materials which may be hazardous to the health of the users unless proper precautions are taken.

6.2 Effective operator instruction together with routine safety procedures such as source leak tests, recording and evaluation of film badge data, use of survey meters, etc., are a recommended part of the operation of equipment of this type.

## 7. Standardization

7.1 All nuclear water content instruments are subject to long-term aging of the radioactive source, detectors, and electronic systems, which may change the relationship between count rate and water content. To offset this aging, instruments are calibrated as a ratio of the measurement count rate to a count rate made on a reference standard. The reference count rate should be in the same or higher order of magnitude than the range of measurement count rates over the useful water range of the equipment.

7.2 Standardization of equipment on the reference standard is required at the start of each day's use and a permanent record of these data shall be retained. The standardization shall be performed with the equipment located at least 8 m (25 ft) away from other gages and clear of large masses of water or other items which may affect the gage readings.

7.2.1 Turn on the instrument and allow for stabilization in accordance with the manufacturer's recommendations. If the instrument is to be used either continuously or intermittently during the day, it is generally best to leave it in the "power on" condition to prevent having to repeat the stabilization. This will provide more stable, consistent results.

7.2.2 Using the reference standard take at least four repetitive readings at the normal measurement period and obtain the mean. If available on the instrument, one measurement at a period of four or more times the normal period is acceptable. This constitutes one standardization check.

7.2.3 If the value obtained above is within the limits stated below, the equipment is considered to be in satisfactory condition and the value may be used to determine the count ratios for the day of use. If the value obtained is outside these limits, another standardization check should be made. If the second standardization check is within the limits, the equipment may be used, but if it also fails the test, the equipment shall be adjusted or repaired as recommended by the manufacturer.

$$N_s \le N_o + \frac{2.0\sqrt{N_o}}{\sqrt{F}} \tag{1}$$

and

$$N_s \ge N_o - \frac{2.0\sqrt{N_o}}{\sqrt{F}} \tag{2}$$

where:

- $N_s$  = value of current standardization check (7.2.2) on the reference standard,
- $N_o$  = average of the past four values of N<sub>s</sub> taken for prior usage, and

F = value of prescale (A2.2.1).