



SLOVENSKI STANDARD
oSIST ISO 16000-19:2013
01-april-2013

Notranji zrak - 19. del: Strategija vzorčenja gliv

Indoor air - Part 19: Sampling strategy for moulds

Air intérieur - Partie 19: Stratégie d'échantillonnage des moisissures

Ta slovenski standard je istoveten z: ISO 16000-19:2012

ICS:

13.040.20 Kakovost okoljskega zraka Ambient atmospheres

oSIST ISO 16000-19:2013

en,fr

INTERNATIONAL STANDARD

ISO
16000-19

First edition
2012-06-01

Indoor air —

Part 19: **Sampling strategy for moulds**

Air intérieur —

Partie 19: Stratégie d'échantillonnage des moisissures



Reference number
ISO 16000-19:2012(E)

© ISO 2012



COPYRIGHT PROTECTED DOCUMENT

© ISO 2012

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction.....	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Properties, origin and occurrence of moulds in indoor environments	4
5 Sampling and detection methods	5
6 Measurement strategy	6
6.1 General aspects	6
6.2 Selection of appropriate procedure.....	9
7 Quality requirements and uncertainty considerations	17
Annex A (informative) Moisture damage indicators	18
Annex B (informative) Devices for total spore count and detection of culturable fungi	19
Annex C (informative) Field inspection report to describe sampling procedure and to document potential mould damage	21
Bibliography.....	27

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 16000-19 was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 6, *Indoor air*.

ISO 16000 consists of the following parts, under the general title *Indoor air*:

- *Part 1: General aspects of sampling strategy*
- *Part 2: Sampling strategy for formaldehyde*
- *Part 3: Determination of formaldehyde and other carbonyl compounds in indoor air and test chamber air — Active sampling method*
- *Part 4: Determination of formaldehyde — Diffusive sampling method*
- *Part 5: Sampling strategy for volatile organic compounds (VOCs)*
- *Part 6: Determination of volatile organic compounds in indoor and test chamber air by active sampling on Tenax TA® sorbent, thermal desorption and gas chromatography using MS or MS–FID*
- *Part 7: Sampling strategy for determination of airborne asbestos fibre concentrations*
- *Part 8: Determination of local mean ages of air in buildings for characterizing ventilation conditions*
- *Part 9: Determination of the emission of volatile organic compounds from building products and furnishing — Emission test chamber method*
- *Part 10: Determination of the emission of volatile organic compounds from building products and furnishing — Emission test cell method*
- *Part 11: Determination of the emission of volatile organic compounds from building products and furnishing — Sampling, storage of samples and preparation of test specimens*
- *Part 12: Sampling strategy for polychlorinated biphenyls (PCBs), polychlorinated dibenzo-p-dioxins (PCDDs), polychlorinated dibenzofurans (PCDFs) and polycyclic aromatic hydrocarbons (PAHs)*
- *Part 13: Determination of total (gas and particle-phase) polychlorinated dioxin-like biphenyls (PCBs) and polychlorinated dibenzo-p-dioxins/dibenzofurans (PCDDs/PCDFs) — Collection on sorbent-backed filters*

- *Part 14: Determination of total (gas and particle-phase) polychlorinated dioxin-like biphenyls (PCBs) and polychlorinated dibenzo-p-dioxins/dibenzofurans (PCDDs/PCDFs) — Extraction, clean-up and analysis by high-resolution gas chromatography and mass spectrometry*
- *Part 15: Sampling strategy for nitrogen dioxide (NO₂)*
- *Part 16: Detection and enumeration of moulds — Sampling by filtration*
- *Part 17: Detection and enumeration of moulds — Culture-based method*
- *Part 18: Detection and enumeration of moulds — Sampling by impaction*
- *Part 19: Sampling strategy for moulds*
- *Part 23: Performance test for evaluating the reduction of formaldehyde concentrations by sorptive building materials*
- *Part 24: Performance test for evaluating the reduction of volatile organic compound (except formaldehyde) concentrations by sorptive building materials*
- *Part 25: Determination of the emission of semi-volatile organic compounds by building products — Micro-chamber method*
- *Part 26: Sampling strategy for carbon dioxide (CO₂)*
- *Part 28: Determination of odour emissions from building products using test chambers*

The following parts are under preparation:

- *Part 21: Detection and enumeration of moulds — Sampling from materials*
- *Part 27: Determination of settled fibrous dust on surfaces by SEM (scanning electron microscopy) (direct method)*
- *Part 29: Test methods for VOC detectors*
- *Part 30: Sensory testing of indoor air*
- *Part 31: Measurement of flame retardants and plasticizers based on organophosphorus compounds — Phosphoric acid ester*
- *Part 32: Investigation of constructions on pollutants and other injurious factors — Inspections*

Introduction

Mould spores and metabolites can be inhaled via the air and cause allergic and irritating reactions and/or complex symptoms in humans. Moreover, mould growth can be associated with severe odour nuisances. In rare cases, some mould species can cause infections (so-called mycoses) in certain risk groups.^{[14][18][19]}

There is sufficient epidemiological evidence that damp and mouldy buildings increase the risk of respiratory symptoms, respiratory infections and enhances asthma symptoms of the occupants.^[8] In addition, there is some evidence for increased risk of development of allergic rhinitis and asthma. Furthermore, there is clinical evidence for rare symptoms like allergic alveolitis, chronic rhinosinusitis and allergic sinusitis. Toxicological studies *in vivo* and *in vitro* show irritating and toxic reactions of microorganisms (including spores, cell components and metabolites) from damp buildings.^[8]

Growth of microorganisms in damp buildings can lead to increased concentrations of spores, cell fragments, allergens, mycotoxins, endotoxins, β -glucanes and MVOC (microbial volatile organic compounds). From the studies conducted so far it is not clear which compounds are the causative agents of the health effects observed. Nevertheless, increased concentrations of each of these compounds are considered a potential health risk^{[8][18]} and growth of mould in buildings should, therefore, be avoided.

The prime objective of this part of ISO 16000 is to provide assistance in identifying mould sources in indoor environments.