
Components for fire-extinguishing systems using gas — Requirements and test methods — Container valve assemblies and their actuators; selector valves and their actuators; nozzles; flexible and rigid connectors; and check valves and non-return valves

Composants pour les systèmes d'extinction d'incendie utilisant des agents gazeux — Exigences et méthodes d'essai — Vannes de réservoir et leurs dispositifs d'asservissement; vannes de sélection et leurs dispositifs d'asservissement; diffuseurs; connecteurs flexibles et rigides; et vannes d'arrêt et clapets de retenue

ISO 16003:2008

<https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008>



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 16003:2008

<https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

| | |
|---|-----------|
| Foreword..... | v |
| Introduction | vi |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions..... | 2 |
| 4 Requirements | 5 |
| 4.1 General design | 5 |
| 4.2 Connection threads and flanges | 8 |
| 4.3 Valve function | 8 |
| 4.4 Temperature range | 8 |
| 4.5 Resistance to internal pressure | 8 |
| 4.6 Resistance to bursting | 8 |
| 4.7 Leakage..... | 9 |
| 4.8 Impact resistance, check valves | 9 |
| 4.9 Resistance to internal pressure and leakage | 9 |
| 4.10 Operational reliability | 9 |
| 4.11 Nozzle distribution characteristics | 9 |
| 4.12 Nozzle resistance to pressure and heat | 9 |
| 4.13 Nozzle protection covers | 9 |
| 4.14 Type 2 flexible connector resistance of to pressure and heat..... | 10 |
| 4.15 Type 2 flexible connector resistance to heat and cold shock | 10 |
| 4.16 Type 2 flexible connectors resistance to cold | 10 |
| 4.17 Type 2 flexible connector resistance to flexing..... | 10 |
| 4.18 Flow characteristics | 10 |
| 4.19 Corrosion..... | 10 |
| 4.20 Stress corrosion | 10 |
| 4.21 Vibration resistance..... | 11 |
| 4.22 Diptube..... | 11 |
| 4.23 Operating force, container-valve actuator | 11 |
| 4.24 Operating force, selector-valve actuator..... | 11 |
| 4.25 Functional reliability, valves and actuators | 11 |
| 4.26 Manually powered actuators | 11 |
| 4.27 Marking and data | 12 |
| 4.28 Documentation | 13 |
| 5 Test methods..... | 13 |
| 5.1 Test conditions | 13 |
| 5.2 Test samples and order of tests..... | 13 |
| 5.3 Compliance..... | 16 |
| 5.4 Function test | 16 |
| 5.5 Resistance to internal pressure | 18 |
| 5.6 Resistance to bursting | 19 |
| 5.7 Leakage test | 20 |
| 5.8 Nozzle cover | 22 |
| 5.9 Nozzle distribution characteristics | 22 |
| 5.10 Operational reliability | 22 |
| 5.11 Performance at temperature extremes | 22 |
| 5.12 Test for resistance to pressure and heat | 24 |
| 5.13 Test for resistance of type 2 and type 4 flexible connectors to heat and cold shock..... | 24 |
| 5.14 Test of type 2 flexible connectors for resistance to cold | 24 |

| | | |
|------|--|----|
| 5.15 | Test of type 2 flexible connectors for resistance to flexing | 24 |
| 5.16 | Impact test for check valves | 25 |
| 5.17 | Flow characteristics of container valves | 25 |
| 5.18 | Flow characteristics of selector valves | 25 |
| 5.19 | Corrosion | 26 |
| 5.20 | Stress corrosion..... | 28 |
| 5.21 | Vibration..... | 28 |
| 5.22 | Diptube | 29 |
| 5.23 | Operating force and functional reliability..... | 30 |
| 5.24 | Other tests | 30 |
| | Bibliography | 31 |

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 16003:2008](https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008)

<https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 16003 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media and firefighting systems using gas*.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 16003:2008](https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008)

<https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008>

Introduction

This International Standard has been prepared by a specialist working group of ISO/TC 21/SC 8 as a companion document to ISO 14520 (all parts) and is compatible with corresponding documents prepared by CEN. It does not cover all components incorporated in gaseous fire extinguishing systems dealt with in ISO 14520 (all parts); rather, it is restricted to key components only, viz., container valve assemblies, flexible connectors, check valves and non-return valves, selector valves and associated actuators and discharge nozzles.

CO₂ system components are also covered by this International Standard (see ISO 6183).

NOTE The components requirements of this International Standard are also satisfied by the requirements of EN 12094 (all parts).

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 16003:2008](https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008)

<https://standards.iteh.ai/catalog/standards/iso/d72ca11a-5f10-46a4-9277-93b53901a461/iso-16003-2008>

Components for fire-extinguishing systems using gas — Requirements and test methods — Container valve assemblies and their actuators; selector valves and their actuators; nozzles; flexible and rigid connectors; and check valves and non-return valves

1 Scope

This International Standard specifies requirements and describes test methods for the following components used in gaseous fire-extinguishing systems: container valve assemblies, which include container valve, actuator and, if applicable, a diptube; selector valves and their actuators; agent distribution nozzles; flexible connectors; and check and non-return valves.

Container valve assemblies are designed to control the extinguishant flow from the container to the distribution pipe work. They are normally in the closed position. The automatic control device triggers the actuator and the valve opens. Where applicable, the requirements contained in the test methods also apply to separate container valves.

The design of the nozzles influences the area coverage, the height limitations, the discharge rate and the flow rate.

This International Standard is applicable to check valves installed between container valve and manifold and non-return valves installed in pilot lines, except those valves that are tested in combination with non-electrical control devices. It is required that non-return and check valves allow the passage in the direction of flow and prevent flow in the reverse direction.

NOTE For the purpose of this International Standard, the pressure in megapascals (bars) means gauge pressure, unless otherwise indicated.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 7005 (all parts), *Metallic flanges*

ISO 14520-1:2006, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 1: General requirements*

IEC 60068-2-6, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60730-2-14, *Automatic electrical controls for household and similar use — Part 2-14: Particular requirements for electric actuators*

ASTM B117, *Standard Practice for Operating Salt Spray (Fog) Apparatus*

3 Terms and definitions

For the purpose of this document, the following terms and definitions apply.

- 3.1 actuator**
component that causes a valve to operate
- 3.2 check valve**
valve that is installed between container and manifold and that permits flow in only one direction
- 3.3 container valve**
valve that retains the extinguishing agent in a container, releasing it when actuated
- 3.4 CO₂ high-pressure installation**
fire-extinguishing installation in which the CO₂ is stored at ambient temperature
- NOTE At 21 °C, the vapour pressure of CO₂ is 5,88 MPa (58,8 bar) absolute, or 5,88 MPa (57,8 bar) gauge.
- 3.5 CO₂ low-pressure installation**
fire-extinguishing installation in which the CO₂ is stored at low temperature, normally –18 °C, at which the nominal pressure is 2,07 MPa (20,7 bar)
- 3.6 diptube**
pipe connected to a container valve inlet that allows the discharge of a liquid extinguishing medium out of a vertical container with the valve at the top
- 3.7 distribution characteristics**
limitations of enclosure dimensions within which a nozzle is approved for use
- 3.8 fill ratio**
mass of extinguishing medium related to the net capacity of a container
- NOTE The fill ratio is expressed in units of kilograms per litre.
- 3.9 filter**
component to prevent blockage of nozzles or other operating components by foreign materials
- 3.10 flexible connector**
link between two parts employed to compensate for installation spacing tolerances or to provide allowance for relative movement

3.10.1**type 1 flexible connector**

flexible connector for connecting a container to a manifold

3.10.2**type 2 flexible connector**

flexible connector for use in distribution pipe work downstream of the manifold

3.10.3**type 3 flexible connector**

flexible connector for use in a pneumatic pilot line

3.10.4**type 4 flexible connector**

flexible connector for use in distribution pipework downstream of the manifold/selector valve for the connection of moving parts, which allow for dimensional adjustments

3.10.5**type 5 rigid connector**

rigid connector for connecting a container to a manifold

3.11**flow rate**

mass flow of extinguishing agent per unit of time

3.12**functional reliability**

ability to function under different working conditions

3.13**halocarbon gas**

extinguishing agent that contains as primary components one or more organic compounds containing one or more of the agent's fluorine, chlorine, bromine or iodine

ISO 16003:2008

EXAMPLES Include, but are not limited to, halons, hydrofluorocarbons (HFCs), hydrochlorofluorocarbons (HCFCs), perfluorocarbons (PFCs) and fluoroketones (FKs).

3.14**halocarbon gas installation**

fire-extinguishing installation in which the halocarbon gas is stored at ambient temperature

3.15**high-pressure container**

container having a working pressure greater than 3,5 MPa (35 bar)

3.16**inert gas**

non-liquefied gas or mixture of gases, such as argon, nitrogen, CO₂ or mixtures of these gases, that extinguishes fire mainly by reducing the oxygen-concentration in the protected space

3.17**inert gas installation**

fire-extinguishing installation in which the inert gas is stored at ambient temperature

3.18**local application nozzle**

nozzle from which the extinguishing agent is discharged onto the surface of a partially enclosed or open hazard

3.19

low-pressure container

container having a working pressure not greater than 3,5 MPa (35 bar)

NOTE For the purpose of this International Standard, the pressure in megapascals (bars) means gauge pressure, unless otherwise indicated.

3.20

manifold

pipe section connected to two or more extinguishing agent containers

3.21

non-return valve

component that permits flow in one direction only

NOTE This component is intended for installation in pilot lines.

3.22

nozzle

component to achieve a predetermined flow rate and a uniform distribution characteristic of the extinguishing agent into or onto a protected hazard

3.23

nozzle cover

component to prevent entry of foreign matter into a nozzle

3.24

pressure-relief device

device, such as a rupture disk, that protects an agent container against dangerous overpressure

3.25

pressure-relief valve

valve that protects a closed part of a pipe work against dangerous overpressure

3.26

resistance coefficient

factor used in calculating the pressure drop due to fluid flow through a component

3.27

selector valve

valve used to admit extinguishing agent into a section of a pipe system permitting the agent to flow to a specific hazard in a multi-hazard application

NOTE Also called a "directional" valve.

3.28 Valve

3.28.1

type 1 valve

valve without a pressure-relief device

3.28.2

type 2 valve

valve with a pressure-relief device relieving other than into the valve discharge outlet

3.28.3

type 3 valve

valve with a pressure-relief device relieving into the valve discharge outlet

3.29**working pressure**

maximum pressure at which the component is used in the system

NOTE See Table 1.

4 Requirements**4.1 General design****4.1.1 Test samples**

4.1.1.1 The test sample shall comply to the technical description (drawings, parts list, description of functions, operating and installation instructions) when checked in accordance with 5.3.

The body and internal parts of the component shall be made of materials of suitable strength and of corrosion resistance sufficient to satisfy the performance requirements of this International Standard.

4.1.1.2 All materials shall be chemically compatible with the agent(s) with which they come into contact.

4.1.1.3 The operation of a component shall not be adversely affected by ageing or environmental influences.

4.1.1.4 Non-metallic materials and elastomers shall not be altered, such that the operation of the component is impaired, after any of the tests or over the working life recommended by the manufacturer.

4.1.2 Maximum rated working pressure

Components subject to pressure, including flexible connectors of Type 1, shall be specified by the manufacturer for working pressure according to Table 1 or as otherwise specified by national standards.

ISO 16003:2008
<https://standards.iteh.ai/catalog/standards/iso-16003-2008/2008-07-01/iso-16003-2008>
Table 1 — Working pressure for components

| Component | CO ₂ high pressure component | | CO ₂ low pressure component | | Inert gas component | Halocarbon gas component |
|---|---|-----|--|-----|---------------------|--------------------------|
| | MPa | bar | MPa | bar | | |
| Container valve ^c , selector valve, non-return valve, check valve, type 1 flexible connector | 14,0 | 140 | a | | b | b |
| Type 2 and type 4 flexible connectors | 6,0 | 60 | 2,5 | 25 | a | a |
| Type 5 connector | 14,0 | 140 | Not applicable | | a | a |
| Pneumatic actuator ^c , type 3 flexible connector | As specified by the manufacturer | | | | | |
| ^a To be determined. ^b This value is given as the pressure developed in a container at its maximum fill ratio and developed pressure at 50 °C, where applicable. ^c Actuators may have a different working pressure than container valves. | | | | | | |