



Designation: D5750/D5750M – 95 (Reapproved 2006)

Standard Guide for Width and Length of Pressure-Sensitive Tape¹

This standard is issued under the fixed designation D5750/D5750M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This guide provides guidelines for widths and lengths of pressure-sensitive tape, including tolerances and labeling in the inch-pound and SI systems. It is not intended for tapes used for medical, surgical, or label stock purposes.

1.2 Units stated in the inch-pound system followed by a calculated unit in the SI system are to be regarded separately as standard and should not be interchangeable with units stated in the SI system. The units stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

D4332 Practice for Conditioning Containers, Packages, or Packaging Components for Testing

3. Terminology

3.1 *Definitions:*

3.1.1 *pressure-sensitive tape*—a pressure-sensitive adhesive coated substrate in roll form wound on a core, equal to or greater than 12 in. (0.305 m) in length.

¹ This guide is under the jurisdiction of ASTM Committee D10 on Packaging and is the direct responsibility of Subcommittee D10.14 on Tape and Labels.

Current edition approved April 1, 2006. Published April 2006. Originally approved in 1995. Last previous edition approved in 2001 as D5750/D5750M – 95 (2001). DOI: 10.1520/D5750_D5750M-95R06.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

3.1.2 *roll length*—the length of tape on a roll minus the tab and any tape on the core which cannot be removed and used for the intended purpose.

4. Significance and Use

4.1 Conformance to this guide will reduce chances of misunderstanding between suppliers and users of pressure-sensitive tapes.

4.2 It is recommended that this guide be referenced where widths and lengths of pressure-sensitive tapes are stated, such as in contracts, orders, advertisements, and labeling.

5. Units of Measurement

5.1 All widths and lengths are to be stated using a primary and a secondary system, the latter being a calculated value using procedures stated in Section 11.

5.2 The unit of width shall be inches or millimetres.

5.3 The unit of length shall be yards or metres. For rolls 72 yd (2592 in.) and under, the length may be stated in inches.

5.4 When width is stated in inches, the length shall be stated in yards. When width is stated in millimetres, the length shall be stated in metres.

6. Widths

6.1 When the inch-pound system is used as the primary measurement system, roll widths are stated in a modular system with $\frac{1}{8}$ in. increments for roll widths under 1 in., $\frac{1}{4}$ in. increments for roll widths between 1 and 2 in., and $\frac{1}{2}$ in. increments for roll widths over 2 in.

6.1.1 The SI width shall be calculated (11.1) and listed in addition to the primary inch-pound width, and should be stated in millimetres rounded to the nearest $\frac{1}{10}$ mm.

6.2 When the SI system is used as the primary measurement system, widths are stated in a modular systems, with 3-mm increments for rolls under 24 mm, 6 mm for increments for roll widths between 24 and 48 mm, and 12 mm for roll widths over 48 mm.