



Designation: D 3380 – 90 (Reapproved 1995)<sup>ε1</sup>

## Standard Test Method for Relative Permittivity (Dielectric Constant) and Dissipation Factor of Polymer-Based Microwave Circuit Substrates<sup>1</sup>

This standard is issued under the fixed designation D 3380; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

<sup>ε1</sup> NOTE—Keywords were added in March 1995.

### 1. Scope

1.1 This test method permits the rapid measurement of apparent relative permittivity and loss tangent (dissipation factor) of metal-clad polymer-based circuit substrates in the X-band (8 to 12.4 GHz).

1.2 This test method is suitable for testing PTFE (polytetrafluorethylene) impregnated glass cloth or random-oriented fiber mats, glass fiber-reinforced polystyrene, polyphenyleneoxide, irradiated polyethylene, and similar materials having a nominal specimen thickness of 1.6 mm. The materials are applicable to service at nominal frequency of 9.6 GHz.

NOTE 1—See Appendix X1 for additional information about range of permittivity, thickness other than 1.6 mm, and tests at frequencies other than 9.6 GHz.

1.3 The values stated in inch-pound units are to be regarded as the standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

#### 2.1 ASTM Standards:

D 150 Test Methods for A-C Loss Characteristics and Permittivity (Dielectric Constant) of Solid Electrical Insulation<sup>2</sup>

D 618 Practice for Conditioning Plastics and Electrical Insulating Materials for Testing<sup>3</sup>

D 1711 Terminology Relating to Electrical Insulation<sup>2</sup>

D 2520 Test Methods for Complex Permittivity (Dielectric Constant) of Solid Electrical Insulating Materials at Microwave Frequencies and Temperatures to 1650°C<sup>4</sup>

<sup>1</sup> This test method is under the jurisdiction of ASTM Committee D-9 on Electrical and Electronic Insulating Materials and is the direct responsibility of Subcommittee D09.12 on Electrical Tests.

Current edition approved Feb. 23, 1990. Published April 1990. Originally published as D 3380 – 75. Last previous edition D 3380 – 89.

<sup>2</sup> Annual Book of ASTM Standards, Vol 10.01.

<sup>3</sup> Annual Book of ASTM Standards, Vols 08.01 and 10.01.

<sup>4</sup> Annual Book of ASTM Standards, Vol 10.02.

#### 2.2 IPC Standards:<sup>5</sup>

IPC-TM-650 Test Methods Manual Method 2.5.5.5.

IPC-CF-150E Copper Foil for Printed Wiring Applications.

#### 2.3 IEEE Standards:<sup>6</sup>

Standard No. 488.1 Standard Digital Interface for Programmable Instrumentation.

Standard No. 488.2 Standards, Codes, Formats, Protocols and Common Commands for use with ANSI and IEEE Standard 488.1.

### 3. Terminology

3.1 *Definitions*—See Terminology D 1711 for the definitions of terms used in this test method. See also Test Methods D 2520, D 150, and IPC TM-650 for additional information regarding the terminology.

#### 3.2 Definitions of Terms Specific to This Standard:

3.2.1 *D*—a symbol used in this test method for the dissipation factor.

3.2.2  $\Delta L$ —a correction factor associated with length which corrects for the fringing capacitance at the ends of the resonator element.

3.2.3  $\kappa'$ —symbol used in this test method to denote relative permittivity.

NOTE 2—The preferred symbol for permittivity is Greek kappa prime but some persons use other symbols to denote this property such as *DK*, *SIC*, or  $\epsilon'_R$ .

3.2.4 *microstrip line*—a microwave transmission line employing a flat strip conductor bonded to one surface of a dielectric board or sheet, the other surface of which is clad with, or bonded to, a continuous conductive foil or plate which is substantially wider than the strip. Microstrip provides easier accessibility than stripline for attaching components and devices to the strip circuitry.

3.2.5 *microwave substrate*—a board or sheet of low-loss dielectric material which may be clad with metal foil on one, or both, surfaces. In this test method all metal is removed by etching prior to testing.

<sup>5</sup> Available from The Institute for Interconnecting and Packaging Electronics Circuits, 7380 N. Lincoln Ave., Lincolnwood, IL 60646.

<sup>6</sup> Available from the Institute of Electrical and Electronics Engineers, Inc., 345 E. 47th St., New York, NY 10017.

3.2.6 *stripline*—microwave transmission line using a flat strip conductor clamped, or bonded, between two substantially wider dielectric boards. The outer surfaces of both boards are bonded to, or in intimate contact with, conducting foils or plates (ground planes). Stripline may be conceived as a flattened version of cylindrical coaxial cable.

3.2.7 *stripline resonator*—a disconnected section of stripline loosely coupled at each end by capacitive gaps to feed or probe lines. The strip becomes resonant at those frequencies at which the strip length, increased by an increment due to the fringing fields at the ends, is equal to an integral multiple of half-wavelengths in the dielectric. As frequency varies gradually, the power transmitted from the input to the output feed lines becomes maximum at resonance, and falls off sharply to essentially zero at frequencies which are a few parts per thousand above and below resonance.

#### 4. Summary of Test Method

4.1 Substrate specimens, with metal cladding removed, become the supporting dielectric spacers of a microwave stripline resonator when properly positioned and clamped in the test fixture. The measured values of resonant frequency of the stripline resonator and the half-power frequencies are used to compute the relative permittivity (dielectric constant or  $\kappa'$ ) and the dissipation factor ( $D$ ) of the test specimen. The test specimen consists of one or more pairs of test cards.

#### 5. Significance and Use

5.1 Permittivity and dissipation factor are fundamental design parameters for design of microwave circuitry. Permittivity plays a principal role in determining the wavelength and the impedance of transmission lines. Dissipation factor (along with copper losses) influence attenuation and power losses.

5.2 This test method is suitable for polymeric materials having permittivity in the order of two to eleven. Such materials are popular in applications of stripline and microstrip configurations used in the 1 to 18 GHz range.

5.3 This test method is suitable for design, development, acceptance specifications, and manufacturing quality control.

NOTE 3—See Appendix X1 for additional information regarding significance of this test method and the application of the results.

#### 6. Apparatus


6.1 The preferred assembly fixture shown in Fig. 1, Fig. 2, and Fig. 3 is hereby designated Fixture A. This design of test specimen fixture provides advantages over the design of Fixture B shown in Fig. 4, Fig. 5, Fig. 6, and Fig. 7.

6.1.1 The Fixture B design has been included since this fixture has been, and still is, in service in numerous laboratories.


6.1.2 The Fixture B design relies upon close control of the room temperature in the laboratory for control of the test specimen temperature.

6.1.3 Changing of test pattern cards in the Fixture B design is less convenient than with the Fixture A design.


6.1.4 For Fixture A the preferred assembly for Resonator Card and Specimen uses a Lap Conductor Joint. See Fig. 3 for details.



**FIG. 1 Face View of Fixture Assembly**




**FIG. 2 Exploded Side View of Assembly**



**FIG. 3 Enlarged Exploded Side View Sectioned Through a Probe Line Showing a Lap Conductor Joint for Fixture A**

6.2 *Fixture A*—The elements of the fixture include the following:

- 6.2.1 *Resonator Pattern Card* (see Fig. 8),
- 6.2.2 *Base Stripline Board* (see Fig. 9),
- 6.2.3 *Base Cover Board* (see Fig. 10),
- 6.2.4 *End-Launcher Bodies*, adapted (see Fig. 11),
- 6.2.5 *Aluminum Base Plates* (see Fig. 12),
- 6.2.6 *Aluminum Clamping Plates* (see Fig. 13),
- 6.2.7 *Aluminum Blocks*, for temperature control (see Fig. 14).




| In.   | mm    |
|-------|-------|
| 0.001 | 0.03  |
| 0.002 | 0.05  |
| 0.086 | 2.18  |
| 0.100 | 2.54  |
| 0.143 | 3.63  |
| 0.200 | 5.08  |
| 0.214 | 5.44  |
| 0.250 | 6.35  |
| 0.500 | 12.70 |
| 1.000 | 25.40 |
| 1.500 | 38.10 |
| 2.000 | 50.80 |
| 2.700 | 68.58 |

NOTE 1—Dimensions are in inches.

NOTE 2—Metric equivalents are given for general information only.

**FIG. 4 Generalized Resonator Pattern Card for Fixture B Showing Dimensions of Table 1 and Made of Laminate Matching the Nominal Permittivity of Material to be Tested**



**FIG. 5 Test Fixture Construction, Older Design (Fixture B)**

6.2.8 *Sliders and Blocks* (see Fig. 15), and  
 6.3 *Microwave Signal Source*, capable of providing an accurate signal. An accurate signal provides a leveled power output that falls within a 0.1 dB range during the required time period and over the range of frequency needed to make a permittivity and loss measurement, and maintains output within 5 MHz of the set value for the time required to make a measurement when the signal source is set for a particular frequency.

6.4 *Frequency Measuring Device*, having a resolution 5 MHz or less.

6.5 *Power Level Detecting Device*, having a resolution of 0.1 dB or less and capable of comparing power levels within a 3-dB range with an accuracy of 0.1 dB.

6.6 *Compression Force Gage*,<sup>7</sup> capable of measuring to 5000 N (1100 lb) with an accuracy of  $\pm 1\%$  of full scale.

6.7 *Vise*, or a press, for exerting a controlled force of 4448 N (1000 lb) on the test fixture and having an opening of at least 5 in. (130 mm) to accept the force gage and test fixture.

6.8 *Apparatus for Manual Test Setup:*

6.8.1 *Sweep Frequency Generator*.<sup>8</sup>

6.8.2 *X-Band Frequency Plug-In Unit*.<sup>9</sup>

<sup>7</sup> A Dillon force gage, Compression Model X, part #381612301, has been found satisfactory for this purpose.

<sup>8</sup> The Hewlett Packard (HP) 8350B or 8620C generator has been found satisfactory for this purpose.

<sup>9</sup> The Hewlett Packard (HP) 83545A or 86251A plug-in unit has been found satisfactory for this purpose.

6.8.3 *Frequency Meter*.<sup>10</sup>

6.8.4 *Crystal Detector*,<sup>11</sup> two required.

6.8.5 *Matched Load Resistor*,<sup>12</sup> for one of the crystal detectors.

6.8.6 *Directional Rectified (SWR) Meter*,<sup>13</sup> two required.

6.8.7 *Directional Coupler*.<sup>14</sup>

6.8.8 *Attenuator*,<sup>15</sup> rated at 10 dB.

6.8.9 *Semi-Rigid Coaxial Cable and Connectors*.

6.8.10 *Adapter*,<sup>16</sup> for waveguide to coaxial interconnection.

6.8.11 The assembly of this equipment is shown schematically in Fig. 16.

6.9 *Apparatus for Computer Acquisition of Data*—The following alternative equipment or its equivalent, when properly interconnected, may be used effectively with a computer-control program for automated testing:

<sup>10</sup> The Hewlett Packard (HP) X532B meter has been found to be satisfactory for this purpose.

<sup>11</sup> The Hewlett Packard 423B Neg. detector has been found to be satisfactory for this purpose.

<sup>12</sup> The Hewlett Packard 11523A option .001 resistor has been found to be satisfactory for this purpose.

<sup>13</sup> The Hewlett Packard 415E meter has been found to be satisfactory for this purpose.

<sup>14</sup> The Hewlett Packard 779D coupler has been found to be satisfactory for this purpose.

<sup>15</sup> The Hewlett Packard attenuator 8491B has been found to be satisfactory for this purpose.

<sup>16</sup> The Hewlett Packard adapter X281A has been found to be satisfactory for this purpose.




FIG. 6 Test Fixture Construction, Older Design (Fixture B)

6.9.1 Sweep Frequency Generator,<sup>17</sup> see also 6.8.1.  
 6.9.2 Radio Frequency (RF) Plug-In Unit,<sup>18</sup> having a range from 0.01 to 20 GHz.

NOTE 4—A plug-in of a narrower frequency range (in the X-band from 5.9 to 12.4 GHz) may be selected at significant cost savings.<sup>19</sup>

- 6.9.3 Power Splitter.<sup>20</sup>
- 6.9.4 Automatic Frequency Counter.<sup>21</sup>
- 6.9.5 Source Synchronizer.<sup>22</sup>
- 6.9.6 Attenuator,<sup>23</sup> 10 dB, see also 6.8.8.
- 6.9.7 Programmable Power Meter.<sup>24</sup>

<sup>17</sup> The Hewlett Packard generator 8350B has been found to be satisfactory for this purpose.

<sup>18</sup> The Hewlett Packard plug-in #83592A has been found to be satisfactory for this purpose.

<sup>19</sup> The Hewlett Packard plug-in #83545A has been found to be satisfactory for this purpose.


<sup>20</sup> The Hewlett Packard power splitter #11667A has been found to be satisfactory for this purpose.

<sup>21</sup> The Hewlett Packard frequency counter #5343A has been found to be satisfactory for this purpose.

<sup>22</sup> The Hewlett Packard synchronizer #5344A has been found to be satisfactory for this purpose.

<sup>23</sup> The Hewlett Packard attenuator #8491B has been found to be satisfactory for this purpose.

<sup>24</sup> The Hewlett Packard power meter #436A has been found to be satisfactory for this purpose.



DETAIL-C- MATERIAL - ALUMINUM 2-REQ




FIG. 7 Test Fixture Construction, Older Design (Fixture B)




FIG. 8 Generalized Resonator Pattern Card for Fixture A Showing Dimensions of and Made of Laminate Matching the Nominal Permittivity of Materials to be Tested


6.9.8 Power Sensor,<sup>25</sup> having a range from -70 to +10 dBm.  
 6.9.9 Controlling Computer, with a General Purpose Interface Bus (GPIB) interface.

6.9.10 IEEE 488 (GPIB) Cables, Adapters, and Coaxial Cables, suitable for proper interconnecting of all of the components as illustrated in Fig. 17 and described in 6.9.11.


6.9.11 Interconnecting Instructions (applicable to 6.9 only):

6.9.11.1 Connect the power splitter directly to the RF plug-in output. Connect one output of the splitter to the counter input using an RF cable. With another RF cable, connect the other output to the attenuator. Connect the attenuator to one of the test fixture probe lines.


<sup>25</sup> The Hewlett Packard power sensor #8484A has been found to be satisfactory for this purpose.



**FIG. 9 Base Stripline Board with Copper Foil and Dielectric Matching the Nominal Permittivity of the Material to be Tested**



**FIG. 10 Base Cover Board with Copper Foil Ground Plane**



OMNI-SPECTRA MODEL NUMBER 245-2SF, OR EQUIVALENT

**FIG. 11 Detail of the Supplied End Launcher Body Adapted by Boring Out the Tapped Holes**


6.9.11.2 Connect the counter and the synchronizer as specified by the manufacturer of this equipment. Connect the FM output from the synchronizer to the FM input on the sweep frequency generator using a BNC connector.

6.9.11.3 Use GPIB cables to parallel connect sweeper, synchronizer, power meter, and computer interface.

6.9.11.4 Connect the power sensor to the other probe of the test fixture and connect its special cable to the power meter.


6.9.11.5 A synthesized continuous wave (CW) generator may be used to replace the sweeper, plug-in, power splitter connector, and the source synchronizer to provide the simplified automated set-up shown in Fig. 18.

6.10 *Signal Source*—The type of signal source used in a manual test setup will dictate the method by which the half-power points are determined. If the power input to the test fixture is maintained constant as the frequency is varied, then an SWR meter may be used to determine the half-power points at the output of the test fixture. This may be accomplished by using a sweep generator or by using a tunable klystron (at a



NOTE:  
 NOMINAL THICKNESS 0.050 0.062  
 DIMENSION 'A' 0.062 0.074

**FIG. 12 Aluminum Base Plate for Clamping the Base Cards and Connecting Launcher Bodies to the Base Card**



**FIG. 13 Aluminum Clamping Plate Provided with Tapped Holes for the Pressure Block and a Thermocouple Well**

significantly lower cost) and manually adjusting the power input to the test fixture to a prescribed level using a variable attenuator.

6.11 *Alternative Equipment*—Alternative types or models of equipment may be used if it can be demonstrated that equivalent results are obtained. For example, if a power levelling system is not used, and the power output of the source varies widely with frequency, a ratiometer may be substituted for the two SWR meters. If only a measurement of permittivity is desired, it may not be necessary to level the input.

6.11.1 *Frequency Measurement Apparatus Alternatives:*

6.11.1.1 Digital frequency meter with automatic phase-locking (requires unmodulated signal).

6.11.1.2 Digital frequency meter, manually tuned heterodyne type.


6.11.1.3 Manually tuned resonant wavemeter (less accurate than digital types). Use of this requires a resonance indicator.

6.11.2 *Resonance Indicator Alternatives:*


6.11.2.1 Power meter with thermistor transducer.

6.11.2.2 SWR meter with crystal transducer, (requires modulated signal).

6.11.2.3 Dual-trace oscilloscope when a sweep generator is used.




**FIG. 14 Aluminum Block for Temperature Control and Transfer of Pressure to the Clamp Plates, Fitted with Tapped Holes for Slide, Embedded Steel Ball, and Tapped for Tubing Fittings for Circulating Fluid**



**FIG. 15 Slider and Block for Connecting Pressure Block and Base Plate with Allowance for Opening the Fixture**


**6.11.3 Power Measurement Alternatives:**

- 6.11.3.1 Calibrated variable attenuator in conjunction with one of the above resonance indicators (see 6.11.1).
- 6.11.3.2 Calibrated power meter with thermister transducer.
- 6.11.3.3 Calibrated SWR meter with crystal transducer (requires modulated signal) and must be operated in the square



- NOTE 1—All coaxial cable connections.
- NOTE 2—Equivalent makes and models of equipment may be substituted where it can be shown that equivalent results are obtained.
- NOTE 3—Alternate test setups may be used provided that equivalent results are obtained.

**FIG. 16 X-Band Permittivity Test Setup**



**FIG. 17 Automated Permittivity Test Setup**

law range of the crystal).

6.11.3.4 Calibrated dual-trace oscilloscope when a sweep oscillator is used.

**6.11.4 Signal Generator Alternatives:**

6.11.4.1 Variable-frequency signal generator with a variable attenuator and internal square-wave modulation (may be operated either modulated or unmodulated). Square-wave modulation may also be obtained from a PIN modulator between the signal generator and the resonant cavity.

6.11.4.2 Klystron tube and mount with power supply and the means for varying the frequency.

6.11.4.3 Variable-frequency sweep oscillator with expanded sweep capability for bandwidths of 25 MHz or less.

6.12 *Temperature Control Apparatus*—Temperature control apparatus for use with Fixture A design shall include the following: