



Designation: C1355/C1355M – 96 (Reapproved 2006)

Standard Specification for Glass Fiber Reinforced Gypsum Composites¹

This standard is issued under the fixed designation C1355/C1355M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers glass fiber reinforced gypsum (GRG) composites having minimum properties and quality suitable to allow the production of GRG parts for non-loading bearing, thin section, ornamental shapes for architectural embellishment of interior building construction.

1.2 The values stated in either inch-pound units or SI (metric) are to be regarded separately as standard. Within the text, the SI units are shown in brackets. The values stated in each system shall be independent of the other. Values from the two systems shall not be combined.

1.3 The text of this standard references footnotes which provide explanatory material. These footnotes shall not be considered as requirements of the standard.

2. Referenced Documents

2.1 *ASTM Standards:*²

C11 Terminology Relating to Gypsum and Related Building Materials and Systems

C472 Test Methods for Physical Testing of Gypsum, Gypsum Plasters and Gypsum Concrete

C473 Test Methods for Physical Testing of Gypsum Panel Products

C947 Test Method for Flexural Properties of Thin-Section Glass-Fiber-Reinforced Concrete (Using Simple Beam With Third-Point Loading)

D256 Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics

D578 Specification for Glass Fiber Strands

D696 Test Method for Coefficient of Linear Thermal Expansion of Plastics Between -30°C and 30°C with a Vitreous Silica Dilatometer

D2583 Test Method for Indentation Hardness of Rigid Plastics by Means of a Barcol Impressor

E84 Test Method for Surface Burning Characteristics of Building Materials

E136 Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C

3. Terminology

3.1 *Definitions:* Definitions of terms shall be in accordance with Terminology **C11**.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *GRG composite, n*—a thin section laminate made from the combination of alpha gypsum cement, glass fiber, additives and water.

3.2.2 *GRG part, n*—an individual molded component used as architectural embellishment.

4. Materials and Manufacture

4.1 *Materials:*

4.1.1 *Alpha Gypsum Cement*—Alpha-calcium sulfate hemihydrate-plaster which is noncombustible, has a low water demand, neutral (pH) or low alkalinity, and a purity of not less than 90 % by weight of $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$.

4.1.2 *“E” Glass Fiber*—Chopped glass fiber strands or continuous strand mats of calcia-alumina silicate glasses conforming to Specification **D578**.

4.1.3 *Water*—Potable water.

4.1.4 *Additives*—In accordance with the alpha gypsum cement manufacturer’s specifications.

4.2 *Manufacturer’s Certification of Raw Materials:*

4.2.1 *Alpha Gypsum Cement*—Each lot of alpha gypsum cement shall be certified to be in compliance with **4.1** and **5.1**.

4.2.2 *Glass Fiber Reinforcement*—Each lot of glass fiber reinforcement shall be certified to be in compliance with Specification **D578**.

4.3 *Composite Preparation:*

4.3.1 Prepare a flat, rectangular composite of sufficient size to obtain specimens required in **5.2**. The composite prepared shall be the same formula as the intended GRG part.

5. Mechanical Properties

5.1 *Neat Alpha Gypsum Cement:*

¹ This specification is under the jurisdiction of ASTM Committee **C11** on Gypsum and Related Building Materials and Systems and is the direct responsibility of Subcommittee **C11.01** on Specifications and Test Methods for Gypsum Products.

Current edition approved May 1, 2006. Published May 2006. Originally approved in 1996. Last previous addition approved in 2001 as C1355/C1355M – 96(2001). DOI: 10.1520/C1355_C1355M-96R06.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard’s Document Summary page on the ASTM website.