

### **SLOVENSKI STANDARD** SIST EN 23270:1997

01-december-1997

### Barve in laki in njihove surovine - Temperatura in vlaga pri kondicioniranju in preskušanju (ISO 3270:1984)

Paints and varnishes and their raw materials - Temperatures and humidities for conditioning and testing (ISO 3270:1984)

Lacke, Anstrichstoffe und deren Rohstoffe - Temperaturen und Luftfeuchten für Konditionierung und Prüfung (ISO 3270:1984) RD PREVIEW

Peintures et vernis et leurs matieres premieres - Températures et humidités pour le conditionnement et l'essai (ISO 3270:1984), 23270:1997

https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626-

Ta slovenski standard je istoveten z: EN 23270:1991

ICS:

87.040 Barve in laki Paints and varnishes

SIST EN 23270:1997

en



## iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 23270:1997 https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626fd513d05109b/sist-en-23270-1997 SIST EN 23270:1997

### EUROPEAN STANDARD

NORME EUROPEENNE

EUROPAISCHE NORM

August 1991

UDC 667.612:620.1:551.584

Descriptors: Paints, varnishes, raw materials, conditioning, temperature,test atmospheres, humidity

### English version

Paints and varnishes and their raw materials -Temperatures and humidities for conditioning and testing (ISO 3270, edition 1984)

Peintures et vernis et leurs matières premières - Températures et humidités pour le conditionnement et l'essai (ISO Luftfeuchten für Konditionierung und 3270, édition 1984) Prüfung (ISO 3270, Ausgabe 1984)

This European Standard was approved by CEN on 1991-08-05 and is identical to the ISO standard as referred to ARD PREVIEW CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for triving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical stellerences concerning such national standards may be obtained 100 application for to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CEN

European Committee for Standardization Comité Européen de Normalisation Europäisches Komitee für Normung

Central Secretariat: rue de Stassart 36, B-1050 Brussels

(c) CEN 1991 Copyright reserved to all CEN members

Ref. No. EN 23270:1991 E

EN 23270:1991

Page 2 EN 23270:1991

### Forward

This European Standard is the endorsement of ISO 3270. Endorsement of ISO 3270 was recommended by CEN/TC 139 Paints and varnishes, under whose competence this European Standard will henceforward fall.

National Standards identical to this European Standard shall be published at the latest by 92-02-08 and conflicting national standards shall be withdrawn at the latest 92-02-08.

The standard was approved and in accordance with CEN/CENELEC Internal Regulations, the following countries are bound to implement this European Standard : Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

# iTeh STANDARD PREVIEW

The text of the International standard fso 3270:1984 was approved by CEN as a European Standard without any modification.

SIST EN 23270:1997 https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626fd513d05109b/sist-en-23270-1997





INTERNATIONAL ORGANIZATION FOR STANDARDIZATION®MEЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ®ORGANISATION INTERNATIONALE DE NORMALISATION

### Paints and varnishes and their raw materials — Temperatures and humidities for conditioning and testing

Peintures et vernis et leurs matières premières – Températures et humidités pour le conditionnement et l'essai

iTeh STANDARD PREVIEW Third edition – 1984-03-01

> SIST EN 23270:1997 https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626fd513d05109b/sist-en-23270-1997

(standards.iteh.ai)

### SIST EN 23270:1997

### Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of developing International Standards is carried out through ISO technical committees. Every member body interested in a subject for which a technical committee has been authorized has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council.

#### IEW `eh International Standard ISO 3270 was developed by Technical Committee ISO/TC 35 Paints and varnishes, and was circulated to the member bodies in November 1982.

It has been approved by the member bodies of the following countries; 997

https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626-		
Australia	India	fd513d051099land-en-23270-1997
Belgium	Iran	Romania
Brazil	Iraq	South Africa, Rep. of
Bulgaria	Israel	Sri Lanka
China	Italy	Sweden
Czechoslovakia	Jamaica	Switzerland
France	Kenya	Thailand
Germany, F. R.	Netherlands	United Kingdom
Hungary	Norway	USSR

The member body of the following country expressed disapproval of the document on technical grounds :

#### Canada

This third edition cancels and replaces the second edition (i.e. ISO 3270-1980).

International Organization for Standardization, 1984 C

### Paints and varnishes and their raw materials — Temperatures and humidities for conditioning and testing

### iTeh STANDARD PREVIEW (standards.i?eReference

### 0 Introduction

The physical and mechanical properties of paints, varnishes ISO 558, *Conditioning and testing – Standard atmospheres –* and their raw materials are generally dependent on the test en-23270:*Definitions.* vironmental conditions, the most important variables/being inds/sist/e836e493-27a0-4add-b626-temperature and humidity.

 temperature and humidity.
 fd513d05109b/sist-en-23270-1997

 The degree to which each of these variables needs to be con 3 Definition

trolled is determined by the significance of the effect of the variable on the property being measured. Thus for measurement of viscosity, refractive index and density, it is essential to specify and control the temperature of the test portion to much closer limits than those required for the conditioning and testing atmosphere (see the note to 4.2).

It is recognized that many data on, for example, viscosity, flow times and density have been determined, historically, at temperatures different from that specified in this International Standard. In order to preserve the validity of such data and since much laboratory apparatus (for example burettes, pipettes, pyknometers) is not calibrated at 23 °C, specific deviation from this International Standard may be necessary.

It is strongly recommended that in these cases physical data should also be determined at the conditions specified in this International Standard in order to facilitate a progressive move towards general adoption of the standard conditions at some future date.

### 1 Scope and field of application

This International Standard specifies conditions of temperature and relative humidity for general use in the conditioning and testing of paints and varnishes and their raw materials. It is applicable to paints and varnishes in liquid or powder form, to wet or dry films, and their raw materials.

### 3 Definitions (derived from ISO 558)

**3.1** conditioning atmosphere : The atmosphere in which a sample or test piece is kept before being subjected to test. It is characterized by specified values for either one or both parameters : temperature and relative humidity, which are kept within the prescribed tolerances for a given period of time. The selected values and period of time depend on the nature of the sample or test piece to be tested.

### NOTES

1 The term "conditioning" refers to the operation as a whole designed to bring a sample or test piece, before testing, into a specified condition in relation to temperature and humidity, by keeping it for a given period of time in the conditioning atmosphere.

2 The conditioning can be done either in the laboratory or in a special enclosure termed "the conditioning chamber" or in the test chamber.

**3.2 test atmosphere** : The atmosphere to which a sample or test piece is exposed throughout the test. It is characterized by specified values for either one or both parameters : temperature and relative humidity, which are kept within the prescribed tolerances.

NOTE — The test may be carried out either in the laboratory or in a special chamber termed "the test chamber", or in the conditioning chamber, the choice depending on the nature of the sample or test piece and on the test itself. For example, close control of the test atmosphere may not be necessary if the change of properties of the sample or test piece is insignificant in the test period.

### 4 Temperatures and humidities for conditioning and testing

4.1 Standard conditions (to be used whenever possible)

23  $\pm$  2 °C and 50  $\pm$  5 % relative humidity.

#### 4.2 Standard temperature

23  $\pm$  2 °C and ambient relative humidity.

NOTE - For some tests the limits for control of temperature are more strict. For example when determining viscosity or consistency, control limits of at most  $\pm$  0,5 °C are recommended.

#### 4.3 Other conditions

**4.3.1** For countries where the standard conditions of 4.1 and 4.2 are difficult to maintain, and for other than referee purposes, other conditions may be specified, and these shall be noted in the test report.

### 5 Conditioning

**5.1** The period of conditioning shall be as specified in the particular test method under consideration.

**5.2** The products to be tested shall be placed in the conditioning atmosphere so that they reach equilibrium with the atmosphere as soon as possible. The relevant parts of the apparatus shall also be placed in the conditioning atmosphere so that they reach equilibrium. The products shall be protected from direct sunlight and the atmosphere should be clean.

Test panels shall be separated from each other and from the walls of the enclosure by a distance of at least 20 mm.

### 6 Testing

Unless otherwise specified, the products shall be tested under the same conditions as those in which they have been conditioned.

If the standard conditions, specified in 4.1, have been used for conditioning and testing, the test report shall state :

iTeh STANDA Conditioned, for ..., h, and tested under the standard conditions conforming to ISO 3270.

**4.3.2** Ambient conditions, where neither the temperature not all of the standard conditions specified in 4.1 have not been used, relative humidity have to be controlled, but these conditions, if but other conditions have been chosen, the test report shall known, should be noted in the test report.

https://standards.iteh.ai/catalog/standards/sist/e836e493-27a0-4add-b626fd513d05109b/sist-en-23270-1997