

SLOVENSKI STANDARD
SIST ETS 300 019-2-3:1999/A2:1999
01-november-1999

Inženiring opreme (EE) - Pogoji okolja in preskusi vplivov okolja za telekomunikacijsko opremo – Del 2-3: Specifikacija preskusov vplivov okolja T 3.1 do T 3.5 - Mirujoča (stacionarna) uporaba na lokacijah, zaščiteneh pred vremenskimi vplivi

Equipment Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 2-3: Specification of environmental tests T 3.1 to T 3.5; Stationary use at weatherprotected locations

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ETS 300 019-2-3:1999/A2:1999](https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999)
<https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999>

Ta slovenski standard je istoveten z: ETS 300 019-2-3/A2 Edition 1

ICS:

19.040	Preskušanje v zvezi z okoljem	Environmental testing
33.050.01	Telekomunikacijska terminalna oprema na splošno	Telecommunication terminal equipment in general

SIST ETS 300 019-2-3:1999/A2:1999 **en**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ETS 300 019-2-3:1999/A2:1999](https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999)

<https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999>



AMENDMENT

ETS 300 019-2-3

A2

May 1998

Source: EE

Reference: RE/EE-01026-2-3

ICS: 33.020

Key words: Environment

**This amendment A2, modifies
the European Telecommunication Standard ETS 300 019-2-3 (1994)**

**Equipment Engineering (EE);
Environmental conditions and environmental tests for
telecommunications equipment;
Part 2-3: Specification of environmental tests T 3.1 to T 3.5;
Stationary use at weatherprotected location**

ETSI

European Telecommunications Standards Institute

ETSI Secretariat

Postal address: F-06921 Sophia Antipolis CEDEX - FRANCE

Office address: 650 Route des Lucioles - Sophia Antipolis - Valbonne - FRANCE

X.400: c=fr, a=atlas, p=etsi, s=secretariat - **Internet:** secretariat@etsi.fr

Tel.: +33 4 92 94 42 00 - Fax: +33 4 93 65 47 16

Copyright Notification: No part may be reproduced except as authorized by written permission. The copyright and the foregoing restriction extend to reproduction in all media.

© European Telecommunications Standards Institute 1998. All rights reserved.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ETS 300 019-2-3:1999/A2:1999](https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999)

<https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999>

Foreword

This amendment two to ETS 300 019-2-3 (1994) has been produced by the Equipment and Engineering (EE) Technical Committee of the European Telecommunications Standards Institute (ETSI).

Transposition dates	
Date of adoption of this amendment:	1 May 1998
Date of latest announcement of this amendment (doa):	31 August 1998
Date of latest publication or endorsement of this amendment (dop/e):	28 February 1999
Date of withdrawal of any conflicting National Standard (dow):	28 February 1999

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ETS 300 019-2-3:1999/A2:1999](https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999)

<https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999>

Amendments

Page 12, subclause 3.2

Replace table 3.2 with the following:

Environmental parameter			Environmental Class 3.2	Environmental test specification T 3.2: In-use, Partly temperature-controlled locations				
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	
Air temperature	low	(°C)	-5	-5	16 h	IEC 68-2-1	Ab/Ad: Cold (8) (9) (25)	
	high	(°C)	+45	+45 (2) (18) or +55	16 h	IEC 68-2-2	Bb/Bd: Dry heat (25)	
	change	temp range (°C) rate (°C/min)	0,5	+25/+55 or +25/+45 (2) or +25/+40 (18) 0,5 (4) (7) (16)	half cycle t ₁ = 3 h	IEC 68-2-14	Nb: Change of temperature (25)	
Humidity	relative	low	(%)	5	none (5)			
		high	(%) (°C)	95	93 +30	4 d	IEC 68-2-56	Cb: Damp heat steady state (25)
	absolute	condensation	(°C) (%)	yes	+30° 90-100 (22) (19)	1 cycle	IEC 68-2-30	Db: Damp heat cyclic Variant 1 (25)
		low	(g/m ³)	1	none (5) (10)			
Air	pressure	high	(kPa)	70	none			
		low	(kPa)	106	none			
	speed	(m/s)	5,0	none				
Water	rain	intensity		no				
		low temperature		no				
	other sources		no					
Radiation	icing & frosting		yes	(5)				
	solar	(W/m ²)	700	(21)				
	heat	(W/m ²)	600	(3)				

(continued)

iTeh STANDARD PREVIEW
 (standards.iteh.ai)
 https://standards.iteh.ai/standards/sist/ec3776-4e34-a9e2-a47e239010/ets-300-019-2-3-1999-2019-01-01
 1999

Page 15, subclause 3.3

Replace table T 3.3 with the following:

Environmental parameter			Environmental Class 3.3	Environmental test specification T 3.3: In-use, Not temperature-controlled locations				
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	
Air temperature	low	(°C)	-25	-25	16 h	IEC 68-2-1	Ab/Ad: Cold (8) (9) (26)	
	high	(°C)	+55	+55 (2) or +70	16 h	IEC 68-2-2	Bb/Bd: Dry heat (26)	
	change	(°C) (°C/min)	0,5	-5/+45 (4) 0,5 (7) (16)	1 cycle t ₁ = 3 h	IEC 68-2-14	Nb: Change of temperature (26)	
Humidity	relative	low	(%)	10	none (5)			
		high	(%) (°C)	100	93 +30	4 d	IEC 68-2-56	Cb: Damp heat steady state (26)
		condensation	(%) (°C)	yes	90-100 +30 (22)	2 cycles	IEC 68-2-30	Db: Damp heat cyclic Variant 1 (26)
	absolute	low	(g/m ³)	0,5	none (5) (10)			
		high	(g/m ³)	29	(12)			
Air	pressure	low	(kPa)	70	none			
		high	(kPa)	106	none			
	speed	(m/s)	5,0	none				
Water	rain	intensity		wind driven	(20)			
		low temperature		no				
	other sources			dripping water	(20)			
Radiation	icing & frosting		yes	(5)				
	solar	(W/m ²)	1200	(21)				
	heat	(W/m ²)	600	(3)				

(continued)

ITeH STANDARD PREVIEW
 (standards.iteh.ai)
 https://standards.iteh.ai/catalog/standards/sist/ets-300-019-2-3-1999/sist-ets-300-019-2-3-1999-a2-1999
 447c239010fa8181e81e72e6d-c076-4e34-a9e2-

Page 21, subclause 3.4

Replace table T 3.4 with the following:

Environmental parameter			Environmental Class 3.4	Environmental test specification T 3.4: In-use, Sites with heat trap.			
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method
Air temperature	low	(°C)	-40	-40	16 h	IEC 68-2-1	Ab/Ad: Cold (8) (9) (27)
	high	(°C)	+70	+70 (2) or +85	16 h	IEC 68-2-2	Bb/Bd: Dry heat (27)
	change	(°C) (°C/min)	0,5	-5/+45 0,5 (4) (7) (16)	2 cycles t ₁ = 3 h	IEC 68-2-14	Nb: Change of temperature (27)
Humidity	relative	low	(%)	10	none (5)		
		high	(%) (°C)	100	93 +35 (16)	4 d	IEC 68-2-56 Cb: Damp heat steady state (27)
		condensation	(%) (°C)	yes	90-100 +30 (16)	2 cycles	IEC 68-2-30 Db: Damp heat cyclic Variant 1 (27)
	absolute	low	(g/m ³)	0,1	none (5) (10)		
		high	(g/m ³)	35	(12)		
Air	pressure	low	(kPa)	70	none		
		high	(kPa)	106	none		
	speed	(m/s)	5,0	none			
Water	rain	intensity		wind driven	(20)		
		low temperature		no			
	other sources			dripping and spraying water	(20)		
	icing & frosting			yes	(5)		
Radiation	solar	(W/m ²)	1200	(21)			
	heat	(W/m ²)	600	(3)			

(continued)

<http://www.itseh.com/standards/standard-300-019-2-372-ef1-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-1999-a2-1999>
IT'SEHS STANDARD PREVIEW
 (standards.itsesh.ai)

Page 18, subclause 3.5

Replace table T 3.5 with the following:

Environmental parameter			Environmental Class 3.5	Environmental test specification T 3.5: In-use, Sheltered locations.				
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	
Air temperature	low	(°C)	-40	-40	16 h	IEC 68-2-1	Ab/Ad: Cold (8) (9) (28)	
	high	(°C)	+40	+40	16 h	IEC 68-2-2	Bb/Bd: Dry heat (28)	
	change	(°C) (°C/min)	1,0	-40/+40 1,0 (4)	2 cycles t ₁ = 3 h	IEC 68-2-14	Nb: Change of temperature (28)	
Humidity	relative	low	(%)	10	none (5)			
		high	(%) (°C)	100	93 +35 (16)	4 d	IEC 68-2-56	Cb: Damp heat steady state (28)
		condensation	(%) (°C)	yes	90-100 +35 (16)	2 cycles	IEC 68-2-30	Db: Damp heat cyclic Variant 1 (28)
	absolute	low	(g/m ³)	0,1	none (5) (10)			
		high	(g/m ³)	35	(12)			
Air	pressure	low	(kPa)	70	none			
		high	(kPa)	106	none			
	speed	(m/s)	30	none				
Water	rain	intensity		wind driven	(20)			
		low temperature		no				
	other sources			dripping and spraying water	(20)			
	icing & frosting			yes	(5)			
Radiation	solar	(W/m ²)	no					
	heat	(W/m ²)	600	none				

(continued)

ITeH STANDARD PREVIEW
 (standards.iteh.ai)
 SITS 300 019-2-3:1999/A2:1999
 a47c239010fa58e4e3-3f0-0-9-2-3-1999-a2-1999

Page 8

ETS 300 019-2-3: May 1994/A2: May 1998

Page 24, subclause 3.6

Add notes 25 to 28.

NOTE 25: The alternative test method given in annex C may be used.

NOTE 26: The alternative test method given in annex D may be used.

NOTE 27: The alternative test method given in annex E may be used.

NOTE 28: The alternative test method given in annex F may be used.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ETS 300 019-2-3:1999/A2:1999](https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999)

<https://standards.iteh.ai/catalog/standards/sist/ec372efd-c076-4e34-a9e2-a47c239010fa/sist-ets-300-019-2-3-1999-a2-1999>

Page 26, annex B

Replace by the following:

Annex B (normative): Alternative climatic test method for class 3.1

B.1 Description

This test method is an alternative to IEC 68 [2] temperature and most humidity tests. It can also contain the cold start test given in this ETS 300 019-2-3. The test uses a sequence which scans the characteristic conditions of the climatogram which is constructed from test severities specified in ETS 300 019-2-3. It may be applied to all equipment being tested for climatic conformance with class 3.1 in ETS 300 019-1.

B.2 Objectives

To provide a standard test method for determining the functionality of an equipment when it is tested in a variable climatic environment consisting of a simultaneous change in combined values of temperature and humidity.

The climatogram test takes into account the boundary climatic conditions which can affect equipment throughout Europe up to an altitude of 3000 metres. The objective of the test is the evaluation of equipment resistibility performance and no attempt is made to assess its reliability. This is why repairs are authorized during tests, provided that failures observed do not systematically recur in the same climatic conditions.

B.3 Test apparatus

The test apparatus shall consist of a single test chamber that is able to reproduce the conditions described in this annex.

The dimensions of the chamber shall be in accordance with the criteria described in IEC 68-2-56 [2].

NOTE: When climatic stabilization is specified, the time required will vary depending on the thermal mass of the equipment under test, its heat dissipation and the relative size of the test chamber.

For naturally ventilated equipment it is important that the air flow in the test chamber is controlled (less than 1 m/s) near the equipment under test in order to prevent undue influence on its ventilation system. This will allow components inside the equipment to reach their working temperature in relation to the ambient conditions of the chamber.

The test chamber is required to control the rate of change of temperature to a maximum of 0,5°C per minute and the rate of change of relative humidity to a maximum of 10 % per hour with the equipment in its operational state.

B.4 Methodology

The traditional method used for climatic testing of equipment in order to demonstrate its resistibility is to use the IEC 68-2 [2] tests (i.e. cold, dry heat, change of temperature and steady state damp heat). The severities of the tests are chosen to simulate the effects of the extreme climatic conditions of the class.

This annex describes an alternative test method which uses a sequence test following the characteristic conditions of the climatogram figure B.1.

B.5 Pre-conditioning

Pre-conditioning is required for a minimum period of one hour after temperature stabilization within the equipment under the initial condition 23°C / 50 % R.H. (i.e. point S on the climatogram of figure B.1).

B.6 Testing

B.6.1 Equipment operation

The equipment under test shall be in its operational state throughout the tests.

Input and load conditions of the equipment shall be chosen to obtain full utilization of the equipment under test. The dissipation shall be maximized, except for the low temperature test, where it shall be minimized.

B.6.2 Equipment failures

If a failure occurs, the whole test cycle shall be started again, after the failure has been recorded and rectified.

Table B.1: Test severities for class 3.1

Protected from solar and heat radiation or equipment is ventilated						Exposed to solar and heat radiation and equipment is not ventilated					
Exceptional operating conditions (8)			Normal operating conditions			Exceptional operating conditions (8)			Normal operating conditions		
Point	Temp (°C)	RH (%)	Point	Temp (°C)	RH (%)	Point	Temp (°C)	RH (%)	Point	Temp (°C)	RH (%)
S	+ 23 (3)	50 (6)	S	+23 (3)	50 (6)	S	+ 23 (3)	50 (6)	S	+23 (3)	50 (6)
A _e	+ 45 (3)	37 (6)	A _e via S	+ 40 (3)	47 (6)	A _e	+ 55 (3)	23 (6)	A _e via S	+ 50 (3)	30 (6)
B _e	+ 45 (3)	5 (5)	B	+ 40 (3)	5 (5)	B _e	+ 55 (3)	5 (5)	B	+ 50 (3)	5 (5)
C	+ 23 (3)	5 (5)	C	+23 (3)	5 (5)	C	+ 23 (3)	5 (5)	C	+23 (3)	5 (5)
D	+ 5 (2)	15 (5)	D	+5 (2)	15 (5)	D	+ 5 (2)	15 (5)	D	+5 (2)	15 (5)
E _e	- 5 (2), (7)	Any (1)	E	+ 5 (2), (7)	Any (1)	E _e	- 5 (2), (7)	Any (1)	E	+ 5 (2), (7)	Any (1)
F _e	+ 5 (2)	90 (6)	F	+ 5 (2)	85 (6)	F _e	+ 5 (2)	90 (6)	F	+ 5 (2)	85 (6)
G _e	+ 28 (3)	90 (4)	G	+ 29 (3)	85 (4)	G _e	+ 28 (3)	90 (4)	G	+ 29 (3)	85 (4)
A	+ 40 (3)	47 (6)	A	+40 (3)	47 (6)	A	+ 50 (3)	30 (6)	A	+50 (3)	30 (6)
S	+ 23 (3)	50 (6)	S	+23 (3)	50 (6)	S	+ 23 (3)	50 (6)	S	+23 (3)	50 (6)

NOTE 1: It is acceptable to perform tests without controlling the humidity when testing below 5°C (as detailed in IEC 68-2-1 test Ad).

NOTE 2: ± 3°C according to IEC 68-2-1.

NOTE 3: ± 2°C according to IEC 68-2-2 and IEC 68-2-56.
± 3°C is acceptable for certain chamber sizes, as indicated in IEC 68-2-2.

NOTE 4: ± 3% RH according to IEC 68-2-56.

NOTE 5: Low relative humidity to be ± 5%

NOTE 6: ± 3% RH.

NOTE 7: If the cold start test is required in the product specification, when arriving at the point E the equipment shall be switched off; after temperature stabilization is reached within the equipment, it shall be switched on and the test continued.

NOTE 8: Exceptional operating conditions relate to reduced performance requirements.