

Essais relatifs aux risques du feu -

Fire hazard testing -

Partie 2: Méthodes d'essai -  
Section 1/feuille 1: Essai au fil  
incandescent sur produits finis  
et guide

Part 2: Test methods -  
Section 1/sheet 1: Glow-wire  
end-product test and guidance

## C O R R I G E N D U M

Page 16 - Annexe A

Dans le tableau, section «750 °C», remplacer le texte existant par le nouveau texte amendé suivant:

750 °C	Matériel pour utilisation avec surveillance, mais sous des conditions plus sévères	
	Appareils fixes pour installations électriques	Matériels destinés à être utilisés près du tableau principal de distribution d'un immeuble
	Matériel pour utilisation sans surveillance, mais sous des conditions moins sévères	

Page 17 - Annex A

In the table, section "750 °C", replace the existing text by the following amended new text:

750 °C	Equipment for attended use but under more stringent conditions	
	Fixed accessories in installations	Equipment intended to be used near the central supply point of a building
	Equipment for unattended use but under less stringent conditions	