



SLOVENSKI STANDARD
oSIST prEN 300 019-2-3 V2.4.12:2020
01-september-2020

Okoljski inženiring (EE) - Okoljski pogoji in preskusi vplivov okolja na telekomunikacijsko opremo - 2-3. del: Specifikacija preskusov vplivov okolja - Stacionarna uporaba na lokacijah, zaščiteneh pred vremenskimi vplivi

Environmental Engineering (EE) - Environmental conditions and environmental tests for telecommunications equipment - Part 2-3: Specification of environmental tests - Stationary use at weatherprotected locations

(standards.iteh.ai)

[SIST EN 300 019-2-3 V2.5.1:2020](https://standards.iteh.ai/catalog/standards/sist/b4955a5c-cc10-4f96-8a33-ed9380e1973d/sist-en-300-019-2-3-v2-5-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/b4955a5c-cc10-4f96-8a33-ed9380e1973d/sist-en-300-019-2-3-v2-5-1-2020>

Ta slovenski standard je istoveten z: ETSI EN 300 019-2-3 V2.4.12 (2020-07)

ICS:

19.040	Preskušanje v zvezi z okoljem	Environmental testing
33.050.01	Telekomunikacijska terminalska oprema na splošno	Telecommunication terminal equipment in general

oSIST prEN 300 019-2-3 V2.4.12:2020 en

Draft **ETSI EN 300 019-2-3** V2.4.12 (2020-07)



**Environmental Engineering (EE);
Environmental conditions and environmental tests
for telecommunications equipment;
Part 2-3: Specification of environmental tests;
Stationary use at weatherprotected locations**

<https://standards.iteh.ai/catalog/standards/sist/b4955a5c-cc10-4f96-8a33-ed9380e1973d/sist-en-300-019-2-3-v2-5-1-2020>

Reference

REN/EE-017003

Keywords

environment, testing

ETSI

650 Route des Lucioles
F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - NAF 742 C
Association à but non lucratif enregistrée à la
Sous-Préfecture de Grasse (06) N° 7803/88

iTeh STANDARDS PREVIEW
(standards.iteh.ai)

Important notice

The present document can be downloaded from:

<http://www.etsi.org/standards-search>

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the prevailing version of an ETSI deliverable is the one made publicly available in PDF format at www.etsi.org/deliver.

Users of the present document should be aware that the document may be subject to revision or change of status.

Information on the current status of this and other ETSI documents is available at

<https://portal.etsi.org/TB/ETSIDeliverableStatus.aspx>

If you find errors in the present document, please send your comment to one of the following services:

<https://portal.etsi.org/People/CommitteeSupportStaff.aspx>

Copyright Notification

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI.

The content of the PDF version shall not be modified without the written authorization of ETSI.

The copyright and the foregoing restriction extend to reproduction in all media.

© ETSI 2020.

All rights reserved.

DECT™, **PLUGTESTS™**, **UMTS™** and the ETSI logo are trademarks of ETSI registered for the benefit of its Members.

3GPP™ and **LTE™** are trademarks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners.

oneM2M™ logo is a trademark of ETSI registered for the benefit of its Members and of the oneM2M Partners.

GSM® and the GSM logo are trademarks registered and owned by the GSM Association.

Contents

Intellectual Property Rights	4
Foreword.....	4
Modal verbs terminology.....	4
1 Scope	5
2 References	5
2.1 Normative references	5
2.2 Informative references.....	6
3 Definition of terms, symbols and abbreviations.....	6
3.1 Terms.....	6
3.2 Symbols.....	6
3.3 Abbreviations	6
4 Environmental test specifications.....	6
4.0 General	6
4.1 Equipment setup and configuration.....	6
4.2 Performance criteria	7
4.3 Specifications T 3.1 and T 3.1E: Temperature-controlled locations	8
4.4 Specification T 3.2: Partly temperature-controlled locations	12
4.5 Specification T 3.3: Not temperature-controlled locations.....	15
4.6 Specification T 3.4: Sites with heat-trap	19
4.7 Specification T 3.5: Sheltered locations	23
4.8 Specification T 3.6: Control room locations	27
5 Earthquake test specification.....	30
5.0 General	30
5.1 Vibration response investigation	30
5.2 Test conditioning.....	31
Annex A (informative): Impact of corrosion due to dust.....	33
A.0 General	33
A.1 Test condition.....	33
A.1.0 Introduction	33
A.1.1 Dust test condition.....	33
A.1.2 Corrosion test	33
A.1.3 Pass criteria	33
A.2 Schematic Diagram of Suspension Dust Test Chamber.....	34
Annex B (informative): Bibliography.....	36
History	37

Intellectual Property Rights

Essential patents

IPRs essential or potentially essential to normative deliverables may have been declared to ETSI. The information pertaining to these essential IPRs, if any, is publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: "*Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards*", which is available from the ETSI Secretariat. Latest updates are available on the ETSI Web server (<https://ipr.etsi.org/>).

Pursuant to the ETSI IPR Policy, no investigation, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

Trademarks

The present document may include trademarks and/or tradenames which are asserted and/or registered by their owners. ETSI claims no ownership of these except for any which are indicated as being the property of ETSI, and conveys no right to use or reproduce any trademark and/or tradename. Mention of those trademarks in the present document does not constitute an endorsement by ETSI of products, services or organizations associated with those trademarks.

Foreword

This draft European Standard (EN) has been produced by ETSI Technical Committee Environmental Engineering (EE), and is now submitted for the combined Public Enquiry and Vote phase of the ETSI standards EN Approval Procedure.

The present document is part 2, sub-part 3 of a multi-part deliverable. Full details of the entire series can be found in part 2, sub-part 0 [i.2].

Proposed national transposition dates	
Date of latest announcement of this EN (doa):	3 months after ETSI publication
Date of latest publication of new National Standard or endorsement of this EN (dop/e):	6 months after doa
Date of withdrawal of any conflicting National Standard (dow):	6 months after doa

Modal verbs terminology

In the present document "**shall**", "**shall not**", "**should**", "**should not**", "**may**", "**need not**", "**will**", "**will not**", "**can**" and "**cannot**" are to be interpreted as described in clause 3.2 of the [ETSI Drafting Rules](#) (Verbal forms for the expression of provisions).

"**must**" and "**must not**" are **NOT** allowed in ETSI deliverables except when used in direct citation.

1 Scope

The present document specifies test severities and methods for the verification of the required resistibility of equipment according to the relevant environmental class.

The tests in the present document apply to stationary use of equipment at weatherprotected locations covering the environmental conditions stated in ETSI EN 300 019-1-3 [1].

2 References

2.1 Normative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

Referenced documents which are not found to be publicly available in the expected location might be found at <https://docbox.etsi.org/Reference/>.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are necessary for the application of the present document.

- [1] ETSI EN 300 019-1-3: "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 1-3: Classification of environmental conditions; Stationary use at weatherprotected locations".
- [2] IEC 60068-2-1:2007: "Environmental testing - Part 2-1: Tests - Test A: Cold".
- [3] Void.
- [4] IEC 60721-3-3:2019: "Classification of environmental conditions - Part 3: Classification of groups of environmental parameters and their severities - Section 3: Stationary use at weatherprotected locations".
- [5] Void.
- [6] IEC 60068-2-2:2007: "Environmental testing - Part 2-2: Tests - Test B: Dry heat".
- [7] IEC 60068-2-14:2009: "Environmental testing - Part 2-14: Tests - Test N: Change of temperature".
- [8] IEC 60068-2-78:2012: "Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state".
- [9] IEC 60068-2-30:2005: "Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle)".
- [10] IEC 60068-2-64:2008+AMD1:2019: "Environmental testing - Part 2-64: Tests - Test Fh: Vibration, broadband random and guidance".
- [11] IEC 60068-2-27:2008: "Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock".
- [12] IEC 60068-2-6:2007: "Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal)".
- [13] IEC 60068-2-57:2013: "Environmental testing - Part 2-57: Tests - Test Ff: Vibration - Time-history and sine-beat method".
- [14] IEC 60068-2-68:1994: "Environmental testing - Part 2-68: Tests - Test L: Dust and sand".

2.2 Informative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are not necessary for the application of the present document but they assist the user with regard to a particular subject area.

- [i.1] ETSI EN 300 019-1-0: "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 1-0: Classification of environmental conditions; Introduction".
- [i.2] ETSI EN 300 019-2-0: "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 2-0: Specification of environmental tests; Introduction".

3 Definition of terms, symbols and abbreviations

3.1 Terms

For the purposes of the present document, the terms given in ETSI EN 300 019-1-0 [i.1] apply.

3.2 Symbols

Void.

3.3 Abbreviations

Void.

4 Environmental test specifications

4.0 General

The equipment shall be tested in its operational state throughout the test conditions described in the present document. The detailed descriptions of the environmental conditions are given in clauses 4 and 5 of ETSI EN 300 019-1-3 [1].

ETSI EN 300 019-2-0 [i.2] forms a general overview of part 2 of this multi-part deliverable.

4.1 Equipment setup and configuration

The equipment shall be tested in its operational state throughout the test conditions described in the present document unless otherwise stated. Input and load conditions of the equipment shall be chosen to obtain full utilization of the equipment under test. The heat dissipation shall be maximized, except for the steady state, low temperature test, where it shall be minimized.

4.2 Performance criteria

The following performance criteria shall apply in tests defined by the present document.

Performance criterion A:

The equipment shall function according to the manufacturer specifications before, during and after the tests. No degradation of performance or loss of function is allowed below the performance level specified by the manufacturer when the equipment is used as intended. If the minimum performance level is not specified by the manufacturer, then this may be deduced from the product description and documentation and what the user may reasonably expect from the equipment if used as intended.

Performance criterion B:

The equipment shall function according to the manufacturer specifications before and after the tests. During the test it is not required to monitor the equipment functionality. No degradation of performance or loss of function is allowed below the performance level specified by the manufacturer when the equipment is used as intended. If the minimum performance level is not specified by the manufacturer, then this may be deduced from the product description and documentation and what the user may reasonably expect from the equipment if used as intended.

Performance criterion C:

The equipment shall function according to the manufacturer specifications before and after the tests. No degradation of performance or loss of function is allowed below the performance level specified by the manufacturer when the equipment is used as intended. If the minimum performance level is not specified by the manufacturer, then this may be deduced from the product description and documentation and what the user may reasonably expect from the equipment if used as intended. During the application of the test, temporary loss of function is allowed but after the test the equipment shall restore to the normal functionality without replacement of components, manual rebooting or human intervention. The equipment shall sustain the test without permanent structural or mechanical damage.

Performance criterion D:

This performance criterion applies to the enclosure of the equipment. No corrosion traces (e.g. rust) or deterioration of the enclosure shall occur at the end of the test.

<https://standards.iteh.ai/catalog/standards/sist/b4955a5c-cc10-4f96-8a33-ed9380e1973d/sist-en-300-019-2-3-v2-5-1-2020>

4.3 Specifications T 3.1 and T 3.1E: Temperature-controlled locations

Specification T 3.1: Temperature-controlled locations - normal operating conditions.

The specification in table 1 and table 2 shall apply to permanently temperature-controlled enclosed locations where humidity is usually not controlled.

Table 1: Test specification T 3.1: Temperature-controlled locations - climatic tests

Environmental parameter			Environmental Class 3.1		Environmental test specification T 3.1: In-use, Temperature-controlled locations				
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	Performance criteria	Notes
Air temperature	Low	(°C)	+5	+5	16 h	IEC 60068-2-1 [2]	Ab/Ad/Ae: Cold	A	1
	High	(°C)	+40	+40 or +50	16 h	IEC 60068-2-2 [6]	Bb/Bd/Be: Dry heat	A	2
	Change	(°C) (°C/min)	0,5	+25 to+40 0,5	half cycle t ₁ = 3 h	IEC 60068-2-14 [7]	Nb: Change of temperature	A	3
Humidity	Relative	low (%)	5	None					4
		high (%)	85	85	4 d	IEC 60068-2-78 [8]	Cab: Damp heat steady state	A	5
		condensation	no	None					
	Absolute	low (g/m ²)	1	None					4
high (g/m ²)		25	None					7	
Air	Pressure	low (kPa)	70	None					8
		high (kPa)	106	None					8
	Speed	(m/s)	5,0	None					4
Water	Rain	Intensity	no	None					
		low temperature	no	None					
	Other sources		no	None					
	Icing & frosting		no	None					
Radiation	Solar	(W/m ²)	700	None					9
	Heat	(W/m ²)	600	None					10
Chemically active substances	Sulphur	SO ₂ (mg/m ³)	0,3/1,0	None					11
		H ₂ S (mg/m ³)	0,1/0,5	None					11
	Chlorine	salt mist	sea and road salt		None				11
		Cl (mg/m ³)		0,1/0,3	None				11
		HCl (mg/m ³)		0,1/0,5	None				11
	Nitrogen	NO _x (mg/m ³)		0,5/1,0	None				11
		NH ₃ (mg/m ³)		1,0/3,0	None				11
Hydrogen fluoride HF	(mg/m ³)		0,01/0,03	None				11	

Environmental parameter			Environmental Class 3.1	Environmental test specification T 3.1: In-use, Temperature-controlled locations					
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	Performance criteria	Notes
	Ozone O ₃	(mg/m ³)	0,05/0,1	None					11
Mechanically active substances	Dust	sedimentation (mg/(m ² h))	1,5	None					12
		suspension (mg/m ³)	0,2	None					13
	Sand	(mg/m ³)	30	None					12
Flora and fauna	Micro organisms		negligible						
	Rodents, insects		negligible						
NOTE 1:	(Air temperature, low). The equipment under test shall remain operational throughout this test (without any damage or deterioration of performance, according to product specification). If a cold start up test is performed, the characteristic severity should be used as a cold start up temperature, but it may be modified (within the class characteristic severity range) by the product specification. In this case, the cold start up test shall commence once low temperature stability is achieved.								
NOTE 2:	(Air temperature, high). The equipment under test shall remain operational throughout this test (without any damage or deterioration of performance, according to product specification). If two test temperatures are given, the lower test temperature applies if the equipment is protected against solar and heat radiation or the equipment is ventilated (natural or forced). The higher test temperature includes the heating effects of solar and/or heat radiation. If a high temperature start up test is performed, the characteristic severity should be used as a high start up temperature, but it may be modified (within the class characteristic severity range) by the product specification. In this case, the high temperature start up test shall commence once high temperature stability is achieved.								
NOTE 3:	(Air temperature, change). The change of temperature test is normally used to check design tolerance. IEC 60068-2-14 [7] Test Nb shall be used. For change of temperature of 0,5 °C/min, the cooling gradient may be reduced to 0,2 °C/min where test chamber restrictions preclude a gradient of 0,5 °C/min.								
NOTE 4:	(Relative humidity, low). There is no IEC 60068-2 series test method for this parameter.								
NOTE 5:	(Humidity, relative, high). IEC 60068-2-78 [8] Test Cab shall be used with test values not higher than climatogram limits for this class.								
NOTE 6:	(Condensation). IEC 60068-2-30 [9] Test Db shall be used with test values not higher than climatogram limits for this class.								
NOTE 7:	(Humidity, absolute, high). This effect is considered to be partly included in the damp heat test IEC 60068-2-78 [8] Test Cab.								
NOTE 8:	(Air pressure, low and high). No test is recommended for normal applications, because the effect of air pressure is evaluated at the component level.								
NOTE 9:	(Radiation, solar). The higher test temperature as described in note 2 includes the heating effect of solar radiation. Photochemical tests can be made separately for components and materials.								
NOTE 10:	(Radiation, heat). The higher test temperature as described in note 2 includes the heating effect.								
NOTE 11:	(Chemically active substances). The characteristic severities are given as mean/maximum values. These severities should be considered when designing the equipment and when choosing components and materials. No test is recommended in the present document.								
NOTE 12:	(Mechanically active substances). The characteristic severities are much lower than lowest test severity in IEC 60068-2-68 [14] Test L and therefore no test is recommended. This condition should be considered when designing the equipment and when choosing components and materials.								

Environmental parameter			Environmental Class 3.1	Environmental test specification T 3.1: In-use, Temperature-controlled locations					
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	Performance criteria	Notes
NOTE 13: (Mechanically active substances). The characteristic severities are much lower than the lowest test severity in IEC 60068-2-68 [14] Test Lb and therefore no test is required. This condition should be considered when designing the equipment and choosing components and materials. One possible test to evaluate the impact of corrosion due to dust can be found in Annex A.									

Table 2: Test specification T 3.1: Temperature-controlled locations - mechanical tests

Environmental parameter			Environmental Class 3.1	Environmental test specification T 3.1: In-use, Temperature-controlled locations					
Type	Parameter	Detail parameter	Characteristic severity	Test severity	Duration	Reference	Method	Performance criteria	Notes
Vibration	Sinusoidal	displacement (mm) acceleration (m/s ²) frequency range (Hz) axes of vibration	0,3 1,0 2-9 9-200	none					1
Shocks	Shocks	shock spectrum duration (ms) acceleration (m/s ²) number of shocks direction of shocks	Type L 22 40	half sine 11 30 6	3 in each direction	IEC 60068-2-27 [11]	Ea: Shock	A	2
NOTE 1: (Vibration, sinusoidal). No test is recommended as the characteristic severities represent insignificant levels of vibration. The severities are given as peak values.									
NOTE 2: (Shocks). The values for test severity are not specified in IEC 60068-2 series. The severities are given as peak values. The energy content and the SRS of the shock given as test severity have been considered more appropriate than that given by the characteristic severity. Equipment under test shall be mounted in the "in use" position. The equipment function shall be monitored throughout the test.									

Specification T 3.1E: Temperature-controlled locations - exceptional operating conditions.

The specification in table 3 shall apply to permanently temperature-controlled locations where humidity is usually not controlled. The reference class is the same as for T 3.1, but with extended temperature and humidity ranges.