

SLOVENSKI STANDARD oSIST prEN 300 132-3 V2.1.13:2021

01-junij-2021

Okoljski inženiring (EE) - Napajalni vmesnik na vhodu v informacijsko in komunikacijsko tehnološko opremo - 3. del: Enosmerni tok (DC) do 400 V

Environmental Engineering (EE) - Power supply interface at the input of Information and Communication Technology (ICT) equipment - Part 3: Up to 400 V Direct Current (DC)

iTeh STANDARD PREVIEW (standards.iteh.ai)

Ta slovenski standard je istoveten ²/₂: ³⁰⁰ ETSI EN 300² 132-3 V2.1.13 (2021-04) https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021

|--|

19.040	Preskušanje v zvezi z okoljem	Environmental testing
35.200	Vmesniška in povezovalna oprema	Interface and interconnection equipment

oSIST prEN 300 132-3 V2.1.13:2021 en

oSIST prEN 300 132-3 V2.1.13:2021

iTeh STANDARD PREVIEW (standards.iteh.ai)

oSIST prEN 300 132-3 V2.1.13:2021 https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021 oSIST prEN 300 132-3 V2.1.13:2021

Draft ETSI EN 300 132-3 V2.1.13 (2021-04)



Environmental Engineering (EE); Power supply interface at the input of Information and Communication Technology (ICT) equipment; Part 3: Up to 400 V Direct Current (DC)

https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021

Reference REN/EE-0265

Keywords

environment, interface, power supply

ETSI

650 Route des Lucioles F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - NAF 742 C Association à but non lucratif enregistrée à la Sous-Préfecture de Grasse (06) N° 7803/88

(standards.iteh.ai)

_ Important notice

https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3c-The present document can be downloaded from: acdanti //www.etsi.org/standards-search

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the prevailing version of an ETSI deliverable is the one made publicly available in PDF format at www.etsi.org/deliver.

Users of the present document should be aware that the document may be subject to revision or change of status. Information on the current status of this and other ETSI documents is available at <u>https://portal.etsi.org/TB/ETSIDeliverableStatus.aspx</u>

If you find errors in the present document, please send your comment to one of the following services: https://portal.etsi.org/People/CommiteeSupportStaff.aspx

Copyright Notification

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI. The content of the PDF version shall not be modified without the written authorization of ETSI. The copyright and the foregoing restriction extend to reproduction in all media.

> © ETSI 2021. All rights reserved.

DECT[™], PLUGTESTS[™], UMTS[™] and the ETSI logo are trademarks of ETSI registered for the benefit of its Members.
3GPP[™] and LTE[™] are trademarks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners.
oneM2M[™] logo is a trademark of ETSI registered for the benefit of its Members and of the oneM2M Partners.
GSM[®] and the GSM logo are trademarks registered and owned by the GSM Association.

Contents

Intell	ectual Property Rights		5
Fore	word		5
Mod	al verbs terminology		6
1	Scope		7
2 2.1 2.2	References Normative reference Informative reference	25 26 s	7 7 8
3 3.1 3.2 3.3	Definition of terms, s Terms Symbols Abbreviations	ymbols and abbreviations	8
4	Power interface "A3"		10
5 5.0 5.1 5.2 5.3 5.4 5.5	DC interface requirem General Nominal voltage Normal service volta Normal operating vo Reference test volta Abnormal service vo	nents age range at interface "A3" oltage range at interface "A3" ge (U _T) at interface "A3"	11 11 11 12 12 12 12
6	Abnormal conditions:	Voltage variations, voltage dips, short interruptions and voltage surges a	.t
6.0 6.1 6.2 6.3 6.4	interface "A3" General Voltage variations Voltage dips Short interruptions Voltage surges	- <u>o8IST prEN 300-132-3-V2.1.13:2021</u> ://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3c- acdab431d095/osist-pren-300-132-3-v2-1-13-2021	13 13 13 14 14 15
7	DC Supply protection	1	16
8	Maximum steady stat	e current I _m , in the normal service voltage range	16
9 9.1 9.2	Inrush current on con Limits Measurements	nection to interface "A3"	17 17 18
10	Installation and Cabli	ng, Earthing and Bonding	19
11	Electrical Safety requ	irements	19
12	EMC requirements at	the input of ICT equipment	20
Ann	ex A (informative):	Power supply considerations	21
Ann	ex B (informative):	Identification of interface "A3"	22
Ann	ex C (informative):	Calculation of the extreme DC voltage range at interface "A3"	23
Ann	ex D (informative):	Guide for defining inrush current energy, measuring inrush curren and test generator peak inrush current drive capability	nt 24
D.0	General	~ • • •	24
D.1	Measurement		24
D.2	Test generator peak in	nrush current drive capability	25

		4 Draft ETSI EN 300 132-3 V2.1.13 (2	021-04)
D.3	Example of inrush curr	ent waveform	25
Anne	x E (informative):	Dimensioning of over-current protective devices	27
Anne	x F (informative):	Details of the voltage transient measurement in the most common case of distribution and protective devices	28
Anne	x G (informative):	Diagram of voltage ranges and values at the interface "A3"	30
Histor	y		31

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>oSIST prEN 300 132-3 V2.1.13:2021</u> https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021

Intellectual Property Rights

Essential patents

IPRs essential or potentially essential to normative deliverables may have been declared to ETSI. The information pertaining to these essential IPRs, if any, is publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: "Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards", which is available from the ETSI Secretariat. Latest updates are available on the ETSI Web server (https://ipr.etsi.org/).

Pursuant to the ETSI IPR Policy, no investigation, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

Trademarks

The present document may include trademarks and/or tradenames which are asserted and/or registered by their owners. ETSI claims no ownership of these except for any which are indicated as being the property of ETSI, and conveys no right to use or reproduce any trademark and/or tradename. Mention of those trademarks in the present document does not constitute an endorsement by ETSI of products, services or organizations associated with those trademarks.

Foreword

This draft European Standard (EN) has been produced by ETSI Technical Committee Environmental Engineering (EE), and is now submitted for the combined Public Enquiry and Vote phase of the ETSI standards EN Approval Procedure.

The present document concerns the requirements for the interface between Information and Communication Technology (ICT) equipment and its power supply. It includes requirements relating to its stability and measurement. Various other references and detailed measurement and test arrangements are contained in informative annexes.

The introduced interface up to 400 V Direct Current (DC) is considering power consumption increase and equipment power density increase in order to get higher energy efficiency with less material than with low voltage -48 VDC or permanent AC powering solution.

The up to 400 VDC interface could also simplify the use of renewable energy source with DC output such as photovoltaic generator.

The present document is part 3 of a multi-part deliverable covering Environmental Engineering (EE); Power supply interface at the input to Information and Communication Technology ICT equipment, as identified below:

Part 1: "Alternating Current (AC)";

Part 2: "-48 V Direct Current (DC)";

Part 3: "Up to 400 V Direct Current (DC)";

Part 4: "Up to 400 V Direct Current (DC) and Alternating Current (AC)".

Proposed national transposition dates	
Date of latest announcement of this EN (doa):	3 months after ETSI publication
Date of latest publication of new National Standard or endorsement of this EN (dop/e):	6 months after doa
Date of withdrawal of any conflicting National Standard (dow):	6 months after doa

Modal verbs terminology

In the present document "shall", "shall not", "should", "should not", "may", "need not", "will", "will not", "can" and "cannot" are to be interpreted as described in clause 3.2 of the <u>ETSI Drafting Rules</u> (Verbal forms for the expression of provisions).

"must" and "must not" are NOT allowed in ETSI deliverables except when used in direct citation.

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>oSIST prEN 300 132-3 V2.1.13:2021</u> https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021

1 Scope

The present document contains requirements and measurements methods for the physical interface "A3" that is situated between the power supply system(s) and the power consuming ICT equipment:

- the nominal voltage at power interface "A3" of ICT equipment defined in the present document is DC voltage up to 400 V;
- the output performance of the power equipment including the cable network at the interface "A3";
- the input of the ICT equipment connected to interface "A3".

The DC power can be supplied by a DC output power system e.g. via on-grid AC rectifiers, from DC/DC converters in solar systems, fuel cells, standby generators including a battery backup.

The present document aims at providing compatibility at interface "A3" between the power supply equipment and different ICT equipment (including/monitoring, cooling system, etc.) connected to the same power supply.

The requirements are defined for the purpose of the present document:

- to identify a power supply system with the same characteristics for all ICT equipment defined in the area of application; the area of application may be any location where the interface "A3" is used i.e. telecommunication centres, Radio Base Stations, datacentres and customer premises;
- to facilitate interworking of different loads;
- to facilitate the standardization of power supply systems for ICT equipment; W
- to facilitate the installation, operation and maintenance in the same network of ICT equipment and systems from different origins.
- to secure robustness against temporary voltage deviations and transients during abnormal conditions https://standards.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3c-

General requirements for safety and EMC are out of the present document series unless specific requirement not defined in existing safety or EMC standards.

2 References

2.1 Normative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

Referenced documents which are not found to be publicly available in the expected location might be found at https://docbox.etsi.org/Reference.

NOTE: While any hyperlinks included in the present clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are necessary for the application of the present document.

- [1] IEC 60947-2: "Low-voltage switchgear and controlgear Part 2: Circuit-breakers".
- [2] IEC 60269-1: "Low-voltage fuses Part 1: General requirements".
- [3] IEC 61000-4-5: "Electromagnetic compatibility (EMC) Part 4-5: Testing and measurement techniques Surge immunity test".

- [4] IEC 61000-4-29: "Electromagnetic compatibility (EMC) Part 4-29: Testing and measurement techniques Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests".
- [5] IEC 60898-2: "Electrical accessories Circuit-breakers for overcurrent protection for household and similar installations Part 2: Circuit-breakers for AC and DC operation".
- [6] ETSI EN 301 605 (V1.1.1) (2013): "Environmental Engineering (EE); Earthing and bonding of 400 VDC data and telecom (ICT) equipment".
- [7] Recommendation ITU-T L.1207 (2018): "Progressive migration of telecommunication/information and communication technology site to 400 VDC sources and distribution".
- [8] IEC 60364-4-41: "Low voltage electrical installations Part 4-41: Protection for safety Protection against electric shock".
- [9] EN 60445: "Basic and safety principle for man-machine interface, marking and identification-Identification of equipment terminals, conductor terminations and conductors". (Produced by CENELEC).
- [10] Recommendation ITU-T L.1203 (2016): "Colour and marking identification of up to 400 VDC power distribution for information and communication technology systems".

2.2 Informative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are not necessary for the application of the present document but they assist the user with regard to a particular subject area hai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3cacdab431d095/osist-pren-300-132-3-v2-1-13-2021

- [i.1] ETSI EN 300 132-2: "Environmental Engineering (EE); Power supply interface at the input of Information and Communication Technology (ICT) equipment; Part 2: -48 V Direct Current (DC)".
- [i.2] IEC 60050-601: "International Electrotechnical Vocabulary. Chapter 601: Generation, transmission and distribution of electricity General".
- [i.3] ETSI EN 300 386: "Electromagnetic compatibility and Radio spectrum Matters (ERM); Telecommunication network equipment; ElectroMagnetic Compatibility (EMC) requirements".
- [i.4] EN 62368-1: "Audio/video, information and communication technology equipment Part 1: Safety requirements". (Produced by CENELEC).

3 Definition of terms, symbols and abbreviations

3.1 Terms

For the purposes of the present document, the following terms apply:

abnormal service voltage ranges: steady-state voltage ranges over which the ICT equipment will not be expected to maintain normal service but will survive undamaged

area of application: any location where the interface "A3" is used

NOTE: i.e. telecommunication centres, Radio Base Stations, datacentres and customer premises

Draft ETSI EN 300 132-3 V2.1.13 (2021-04)

customer premises: any location which is the sole responsibility of the customer

dual feeding system: independent power systems i.e. two separate power sources (A+B)

high-Ohmic distribution system: distribution system in which the equipment is connected separately to the battery with added impedance

NOTE 1: The high impedance can be achieved with long cables and in some cases additional resistors are installed.

NOTE 2: With this distribution the undervoltage effects of fuse blowing transients are reduced on other equipment connected to the battery.

ICT equipment: telecommunication or datacommunication equipment

independent power distribution: redundant power distribution i.e. dual feeders (A+B) from two separate power sources (A+B) or a single power source

NOTE: Equipment having two power feeds is fitted with OR-ing devices or separate power supply units.

interface "A3": power interface at the input terminals of ICT, physical point, at which power supply is connected in order to operate the ICT equipment

load unit: power consuming equipment, that is part of a system block

nominal voltage: value of the voltage by which the electrical installation or part of the electrical installation is designated and identified.

NOTE: This definition is based on nominal voltage defined in IEC 60050-601 [i.2].

normal operating condition: typical environmental and powering conditions for operation of ICT equipment, power supply, power distribution and battery

normal operating voltage: typical value of the voltage at "A3" interface within the normal operating voltage range

normal operating voltage range: voltage range at 2A300 nterface where the system operates most of the time, e.g. in general linked to battery floating voltages.iteh.ai/catalog/standards/sist/8b8d5236-fbf5-4bb5-ac3c-

acdab431d095/osist-pren-300-132-3-v2-1-13-2021 normal service: service mode where ICT equipment operates within its specification

normal service voltage range: range of the steady-state voltage at the "A3" interface over which the equipment will maintain normal service.

NOTE: In general this wider than the normal operating voltage range as it includes a part of the battery discharge voltage range.

operating voltage: value of the voltage under normal conditions, at a given instant and a given point ("A3" interface) of the system

power supply network: network interconnecting the power source and the ICT equipment

reference test voltage: voltage used as a reference to define the test voltage in the present document

NOTE: The test voltage may be also a percentage of this voltage.

system block: functional group of ICT equipment depending for its operation and performance on its connection to the same power supply

telecommunication centre: any location where ICT equipment is installed and is the sole responsibility of the operator

3.2 Symbols

For the purposes of the present document, the following symbols apply:

Ω	ohm
kΩ	Kilo ohm
°C	Celsius

A	Ampere
di/dt	derivative of a considered current versus time
Hz	Hertz
Ι	current
Im	maximum steady state current drain at 260 VDC at interface "A3"
I _{mss}	maximum steady state current drain in the abnormal service voltage range at interface "A3"
In	current rating of the over-current protective device
Ip	peak inrush current at interface "A3"
I _{UT}	maximum steady state current drain at U _T at interface "A3"
m	meter
ms	milli seconds
S	seconds
T ₅₀	time duration of the inrush current pulse at 50 % of Ip
Uo	output voltage range of a generator
UT	Reference Test Voltage
V	Volt
W	Watt
μs	micro seconds

3.3 Abbreviations

For the purposes of the present document, the following abbreviations apply:

AC	Alternating Current
CB	Circuit Breaker
CLD	Current Limiting Device
DC	Direct Current II SIANDARD PREVIEW
DC/DC	DC converter (standards ital si)
EE	Environmental Engeneering ICIA CONSTITUTION
EMC	ElectroMagnetic Compatibility
EN	European Standard OSIST prEN 300 132-3 V2.1.13:2021
ERM	Electromagnetic compatibility and Radio spectrum Matters5-4bb5-ac3c-
EUT	Equipment Under Test d095/osist-prep-300-132-3-v2-1-13-2021
ICT	Information and Communication Technology
Ν	Neutral conductor
PE	Protective Earth
VAC	Volts Alternating Current
VDC	Volts Direct Current
VRLA	Valve Regulated Lead Acid

4 Power interface "A3"

The power supply interface "A3" in figure 1, is a physical point to which all the requirements are related. This point is situated at the power input terminals of the ICT equipment.

Examples of configurations in which interface "A3" is identified are given in annex B.

Basic rules for marking of conductors and connectors shall be in accordance with EN 60445 [9].