
Reference

RES/EE-0266

Keywordscontrol, energy efficiency, interface,
management, network monitoring, power, system**ETSI**650 Route des Lucioles
F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - NAF 742 C
Association à but non lucratif enregistrée à la
Sous-Préfecture de Grasse (06) N° 7803/88

Important noticeThe present document can be downloaded from:
<http://www.etsi.org/standards-search>

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the prevailing version of an ETSI deliverable is the one made publicly available in PDF format at www.etsi.org/deliver.

Users of the present document should be aware that the document may be subject to revision or change of status. Information on the current status of this and other ETSI documents is available at <https://portal.etsi.org/TB/ETSIDeliverableStatus.aspx>

If you find errors in the present document, please send your comment to one of the following services:
<https://portal.etsi.org/People/CommiteeSupportStaff.aspx>

Copyright Notification

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI.

The content of the PDF version shall not be modified without the written authorization of ETSI.

The copyright and the foregoing restriction extend to reproduction in all media.

© ETSI 2019.
All rights reserved.

DECT™, **PLUGTESTS™**, **UMTS™** and the ETSI logo are trademarks of ETSI registered for the benefit of its Members.
3GPP™ and **LTE™** are trademarks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners.

oneM2M™ logo is a trademark of ETSI registered for the benefit of its Members and of the oneM2M Partners.

GSM® and the GSM logo are trademarks registered and owned by the GSM Association.

Contents

Intellectual Property Rights	5
Foreword.....	5
Modal verbs terminology.....	6
1 Scope	7
2 References	7
2.1 Normative references	7
2.2 Informative references.....	8
3 Definition of terms, symbols and abbreviations.....	10
3.1 Terms.....	10
3.2 Symbols.....	11
3.3 Abbreviations	11
4 ICT power, energy and environmental parameters monitoring system.....	12
4.1 General description.....	12
4.2 Complementarity to existing site power and air-conditioning measurements.....	14
4.3 Different site cases	15
4.3.1 Simple site case.....	15
4.3.2 Complex site case	16
4.4 Measurement and monitoring description	17
4.4.0 General description	17
4.4.1 Internal measurements type 1 (Built-in in ICT equipment).....	18
4.4.2 External measurements type 2 (external sensors) for ICT equipment	19
4.4.3 Common requirements for external (type 2) and internal (type 1) measurement	19
4.4.3.0 Principle of PEE measurement.....	19
4.4.3.1 Power and energy consumption measurement.....	19
4.4.3.2 Voltage, current measurement.....	20
4.4.3.3 Accuracy of PEE measurement.....	20
4.4.3.4 Local acquisition record.....	21
4.4.3.5 Accuracy verification	22
4.4.3.6 Data transmission period.....	23
4.4.3.7 Local record saving	23
4.5 PEE data analysis services.....	23
Annex A (normative): Summary of mandatory monitoring / supervision information and functions.....	25
A.0 General description of mandatory monitoring / supervision information and functions tables	25
A.1 Table for ICT equipment power, energy and environmental parameters measurements.....	25
Annex B (informative): Summary of non-mandatory monitoring / supervision information and functions	28
B.0 General description of non mandatory monitoring / supervision information and functions tables	28
B.1 Table for ICT equipment power, energy and environmental parameters.....	28
Annex C (normative): Mandatory XML structure and elements.....	30
C.1 Structure of an XML document for ICT Power/Energy/Environment metering (PEE).....	30
Annex D (informative): 3GPP and E-UTRAN Management reference model and unified interface Itf-N.....	32
Annex E (informative): Fixed network Management reference model and unified interface.....	33

Annex F (informative):	State of the art of power, energy measurement and monitoring systems	34
F.0	Introduction	34
F.1	Acquisition and remote metering principles.....	34
F.2	General description of measurement	36
F.2.1	General principle	36
F.2.2	Measurement sensors	36
Annex G (informative):	Bibliography.....	41
History		42

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/5059e8bc-78cf-4401-b35c-52f75d31c792/etsi-es-202-336-12-v1.2.1-2019-02>

Intellectual Property Rights

Essential patents

IPRs essential or potentially essential to normative deliverables may have been declared to ETSI. The information pertaining to these essential IPRs, if any, is publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: "*Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards*", which is available from the ETSI Secretariat. Latest updates are available on the ETSI Web server (<https://ipr.etsi.org/>).

Pursuant to the ETSI IPR Policy, no investigation, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

Trademarks

The present document may include trademarks and/or tradenames which are asserted and/or registered by their owners. ETSI claims no ownership of these except for any which are indicated as being the property of ETSI, and conveys no right to use or reproduce any trademark and/or tradename. Mention of those trademarks in the present document does not constitute an endorsement by ETSI of products, services or organizations associated with those trademarks.

Foreword

This ETSI Standard (ES) has been produced by ETSI Technical Committee Environmental Engineering (EE).

The present document is part 12 of a multi-part deliverable covering monitoring and control interface for infrastructure equipment (power, cooling and building environment systems used in telecommunication networks), as identified below:

- Part 1: "Generic Interface";
- Part 2: "DC power system control and monitoring information model";
- Part 3: "AC UPS power system control and monitoring information model";
- Part 4: "AC distribution power system control and monitoring information model";
- Part 5: "AC diesel back-up generator system control and monitoring information model";
- Part 6: "Air Conditioning System control and monitoring information model";
- Part 7: "Other utilities system control and monitoring information model";
- Part 8: "Remote Power Feeding System control and monitoring information model";
- Part 9: "Alternative Power Systems";
- Part 10: "AC inverter power system control and monitoring information model";
- Part 11: "Battery system with integrated control and monitoring information model";
- Part 12: "ICT equipment power, energy and environmental parameters monitoring information model".**

The goal of the present document is to define the measurement of electrical power and energy consumption of ICT equipment as well as environmental parameters (temperature, hygrometry) in order to improve energy monitoring and to correlate the power consumption to equipment operation activity (telecom traffic, computation, etc.). It is also to define the transfer protocol of this measurement data from site to network operation centre. Knowing power consumption gives the possibilities to reduce energy consumption of equipment and/or network. Granularity, measurement period and accuracies are defined to meet these targets. They may depend on equipment types and location in the different segments of a network (customer termination, access, core, data-center, etc.). In addition, these measurements can be used to improve engineering and operation including more accurate dimensioning of power systems, network evolution modelling and prevision, audit on field, etc.

Modal verbs terminology

In the present document "shall", "shall not", "should", "should not", "may", "need not", "will", "will not", "can" and "cannot" are to be interpreted as described in clause 3.2 of the [ETSI Drafting Rules](#) (Verbal forms for the expression of provisions).

"must" and "must not" are **NOT** allowed in ETSI deliverables except when used in direct citation.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/5059e8bc-78cf-4401-b35c-52f75d31c792/etsi-es-202-336-12-v1.2.1-2019-02>

1 Scope

The present document defines measurement and monitoring of power, energy and environmental parameters for ICT equipment in telecommunications or datacenter or customer premises.

It defines the power, energy and environmental parameters monitoring interface of ICT equipment based on generic ETSI ES 202 336-1 [1] interface so that correlations can be made with ICT equipment parameters (traffic, flowrate, number of connected lines, radio setting, QoS KPI, etc.) in the network management system.

Correlations of monitored data (power, energy consumption and environmental values) with the ICT equipment parameters and settings are not in the scope of the present document.

The monitoring interface covers:

- Internal power consumption measurement on the ICT equipment powered in DC and AC.
- Power consumption measurement external to the ICT equipment (if not implemented internally, e.g. legacy equipment).
- Energy metering based on power consumption measurement.
- Environmental parameters of the ICT equipment (e.g. temperature at air inlet of equipment).

The present document defines:

- The minimum set of exchanged information required at the interface, including parameters such as measurement type (e.g. RMS), accuracy, range, etc. and settings such as data acquisition and transmission period, etc. This includes the data preparation, recording and transmission functions.
- The testing method of some parameters and functions.
- Text tables in annexes A and B with data exchange described in "natural language".
- The XML files with tags and variables corresponding to the data in the tables of annexes A and B in complement to general rules defined in ETSI ES 202 336-1 [1] and ETSI ES 202 336-2 [3].

2 References

2.1 Normative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

Referenced documents which are not found to be publicly available in the expected location might be found at <https://docbox.etsi.org/Reference>.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are necessary for the application of the present document.

- [1] ETSI ES 202 336-1: "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks); Part 1: Generic Interface".
- [2] ETSI ETS 300 132-1: "Equipment Engineering (EE); Power supply interface at the input to telecommunications equipment; Part 1: Operated by alternating current (ac) derived from direct current (dc) sources".

- [3] ETSI ES 202 336-2: "Environmental Engineering (EE); Monitoring and control interface for infrastructure equipment (Power, Cooling and environment systems used in telecommunication networks); Part 2: DC power system control and monitoring information model".
- [4] ETSI ES 202 336-3: "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks); Part 3: AC UPS power system control and monitoring information model".
- [5] ETSI ES 202 336-10: "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks); Part 10: AC inverter power system control and monitoring information model".
- [6] ETSI EN 300 132-2: "Environmental Engineering (EE); Power supply interface at the input to telecommunications and datacom (ICT) equipment; Part 2: Operated by -48 V direct current (dc)".
- [7] ETSI ES 202 336-4: "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks); Part 4: AC distribution power system control and monitoring information model".
- [8] ETSI ES 202 336-6: "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks); Part 6: Air Conditioning System control and monitoring information model".
- [9] ETSI EN 300 019-2 (all subparts): "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 2: Specification of environmental tests".
- [10] ETSI EN 300 019-1-3: "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 1-3: Classification of environmental conditions; Stationary use at weatherprotected locations".

2.2 Informative references

References are either specific (identified by date of publication and/or edition number or version number) or non-specific. For specific references, only the cited version applies. For non-specific references, the latest version of the referenced document (including any amendments) applies.

NOTE: While any hyperlinks included in this clause were valid at the time of publication, ETSI cannot guarantee their long term validity.

The following referenced documents are not necessary for the application of the present document but they assist the user with regard to a particular subject area.

- [i.1] IEEE 802.1™ to 802.11™: "IEEE Standard for Local & Metropolitan Area Network".
- [i.2] ISO/IEC 8879: "Information processing -- Text and office systems -- Standard Generalized Markup Language (SGML)".
- [i.3] ETSI ES 203 215: "Environmental Engineering (EE); Measurement Methods and Limits for Power Consumption in Broadband Telecommunication Networks Equipment".
- [i.4] ETSI ES 202 706: "Environmental Engineering (EE); Measurement method for power consumption and energy efficiency of wireless access network equipment".

NOTE: ETSI ES 202 706 is revision of the ETSI TS 102 706.

- [i.5] ETSI ES 201 554: "Environmental Engineering (EE); Measurement method for Energy efficiency of Mobile Core network and Radio Access Control equipment".

- [i.6] ETSI ES 203 184: "Environmental Engineering (EE); Measurement Methods for Power Consumption in Transport Telecommunication Networks Equipment".
- [i.7] ETSI ES 203 136: "Environmental Engineering (EE); Measurement methods for energy efficiency of router and switch equipment".
- [i.8] ETSI EN 301 575: "Environmental Engineering (EE); Measurement method for energy consumption of Customer Premises Equipment (CPE)".
- [i.9] ETSI ES 203 237: "Environmental Engineering (EE); Green Abstraction Layer (GAL); Power management capabilities of the future energy telecommunication fixed network nodes".
- [i.10] ETSI ES 203 228: "Environmental Engineering (EE); Assessment of Mobile Network Energy Efficiency".
- [i.11] Recommendation ITU-T M.3000 series: "TMN and network maintenance: international transmission systems, telephone circuits, telegraphy, facsimile and leased circuits Telecommunications management network".
- [i.12] Recommendation ITU-T M.3010 series: "TMN and network maintenance: international transmission systems, telephone circuits, telegraphy, facsimile and leased circuits Telecommunications management network - Principles for a telecommunications management network".
- [i.13] ETSI TS 132 101 (V15.0.0) (09-2018): "Digital cellular telecommunications system (Phase 2+); Universal Mobile Telecommunications System (UMTS); LTE; Telecommunication management; Principles and high level requirements (3GPP TS 32.101 version 15.0.0 Release 12)".
- [i.14] ETSI EN 302 099: "Environmental Engineering (EE); Powering of equipment in access network".
- [i.15] ETSI EN 300 132-3-1: "Environmental Engineering (EE); Power supply interface at the input to telecommunications and datacom (ICT) equipment; Part 3: Operated by rectified current source, alternating current source or direct current source up to 400 V; Sub-part 1: Direct current source up to 400 V".
- NOTE: ETSI EN 300 132-3 is currently under revision and will replace ETSI EN 300 132-3-1.
- [i.16] ETSI ES 202 336 (all parts): "Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (Power, Cooling and Building Environment Systems used in Telecommunication Networks)".
- [i.17] LT0511 RevB datasheet: "Linear Technology LTC 1966 precision micropower RMS to DC converter".
- [i.18] Mark Strzegowski: "Realizing the Full Potential of Your AMI Deployment with Meter Diagnostic Data", Analog Device.
- NOTE: Available at <http://www.analog.com/en/technical-articles/full-potential-of-ami-deployment-with-meter-diagnostic-data.html>.
- [i.19] ETSI EN 300 019-1-4: "Environmental Engineering (EE); Environmental conditions and environmental tests for telecommunications equipment; Part 1-4: Classification of environmental conditions; Stationary use at non-weatherprotected locations".

3 Definition of terms, symbols and abbreviations

3.1 Terms

For the purposes of the present document, the following terms apply:

NOTE: Terms referring to energy interface, equipment and distribution are described in power distribution standards ETSI ETS 300 132-1 [2], ETSI EN 300 132-3-1 [i.15], ETSI EN 300 132-2 [6] for ac and dc interface A and A3 and ETSI EN 302 099 [i.14] for access network equipment powering.

AC distribution power system: device or system that distribute AC voltage or convert DC voltage to AC voltage and provides electrical power without interruption in the event that commercial power drops to an unacceptable voltage level

alarm: any information signalling abnormal state, i.e. different to specified normal state of hardware, software, environment condition (temperature, humidity, etc.)

NOTE: The alarm signal should be understood by itself by an operator and should always have at least one severity qualification or codification (colour, level, etc.). alarm message structure are defined in ETSI ES 202 336-1 [1].

EXAMPLE: Rectifier failure, battery low voltage, etc.

board: electronic part of an equipment (e.g. a blade server)

cabinet: closed enclosure including several shelves or racks

Control Unit (CU): integrated unit in an equipment to monitor and control this equipment through sensors and actuators

Data Gathering Unit (DGU): functional unit used for several functions:

- collect serial, digital, and analog data from several equipment;
- option to send (output) serial or digital commands;
- forward/receive information to/from the Local/Remote Management Application via agreed protocols;
- mediation between interfaces and protocols.

NOTE: This function may be integrated as part of specific equipment.

DC back-up system: device or system that provides electrical power without interruption in the event that commercial power drops to an unacceptable voltage level

DC distribution power system: device or system to distribute DC voltage

ethernet: LAN protocol

NOTE: Equivalent to IEEE 802.1 to 802.11 [i.1].

event: any information signalling a change of state which is not an alarm: e.g. battery test, change of state of battery charge

NOTE: The event signal should be understood by itself by an operator It should be transmitted in a formatted structure with text message and other fields like for alarm. An event can be coded as an alarm with severity "0".

eXtensible Mark-up Language (XML): application profile or restricted form of SGML

NOTE: By construction, XML documents are conforming SGML the Standard Generalized Markup Language (ISO/IEC 8879 [i.2]) documents. XML is designed to describe data and focus on what data is. XML should be discerned from the well known Hypertext Transfer Mark-up Language (HTML) which was designed to display data and to focus on how data looks.

infrastructure equipment: power, cooling and building environment systems used in telecommunications centres and Access Networks locations

EXAMPLE: Cabinets, shelters, underground locations, etc.

module: closed unit including electronic boards forming part of a larger system (e.g. sub-unit of a base station in a cabinet or separated)

rack: sub part of the cabinet including ICT equipment rest

shelf: level in a cabinet

warning: low severity alarm

World Wide Web Consortium (W3C): consortium founded in October 1994 to develop common interoperable protocols and promote World Wide Web

NOTE: See <http://www.w3c.org>.

XML enabled CU (XCU): CU enabled to communicate using XML interface as defined in the present document

xDSL: global designation of the digital subscriber line (DSL) technologies

3.2 Symbols

For the purposes of the present document, the following symbols apply:

C	Capacitor
E	electric energy
I	electric current
f	frequency
P	electric power
R	Resistance
RC	time constant of a timer circuit
T	temperature
U	electric voltage or difference of potential
T _{acq}	Voltage and Current acquisition period
T _{rec}	PEE record time period for remote transmission
T _{rms}	RMS integration period
T _{trans}	Transmission period of data records

3.3 Abbreviations

For the purposes of the present document, the following abbreviations apply:

μC	Microcontroller
AC	Alternating Current
AD	Analog Digital
ADSL	Asynchronous Digital Subscriber Line
BB	Broad-Band
BBU	Base-Band Unit
BS	Base Station
CPE	Customer Premises Equipment
CU	Control Unit of an equipment
DC	Direct Current
DGU	Data Gathering Unit
DSLAM	Digital Subscriber Line Access Multiplexer
EEPROM	Electrically Erasable Programmable Read Only Memory
EMAN	Energy Manager (abbreviation of IETF specification)
EMS	Energy Management System
E-UTRAN	Extended UTRAN

FAN	Fixed Access Network
GAL	Green Abstraction Layer
HTML	Hypertext Transfer Make-up Language
HTTP	HyperText Transfer Protocol
ICT	Information and Communication Technology
IETF	Internet Engineering Task Force
IP	Internet Protocol
KPI	Key Performance Indicator
LAN	Local Array Network
MSAN	Multiservice Access Network
NE	Network Element
NMS	Network Management System
OA	Operational Amplifier
OLT	Optical Line Termination
ONT	Optical Network Termination
ONU	Optical Network Unit
OSS	Operations Support System
PEE	Power, Energy, Environmental parameters
PF	Power Factor
PFC	Power Factor Correction
PSU	Power Supply Unit
RMA	Remote Management Application
RMS	Root Mean Square
RRU	Remote Radio Unit
SGML	Standard Generalized Markup Language
SMPS	Switched Mode Power Supply
TCP	Transmission Control Protocol for IP
TMN	Telecom Management Network

NOTE: As defined in Recommendation ITU-T M.3000 series [11].

UMTS	Universal Mobile Telecom System
UPS	Un-interruptible Power Supply
UTRAN	Extended Terrestrial Radio Access Network
VDC	Volt Direct Current
W3C	World Wide Web Consortium
x DSL	x Digital Subscriber Line

NOTE: x stands for many different type of DSL such as: A (Asymmetric), H (high-data-rate), RA (Rate Adaptive), S (Symmetric digital subscriber line), V (Very high speed), SH (Single-pair High-speed), G.SH (first version of SDSL).

XCU	XML enabled CU
XML	eXtensible Mark-up Language (see W3C)
XRMS	XML Remote Management Server

4 ICT power, energy and environmental parameters monitoring system

4.1 General description

The basic principles of power, energy and environment parameters measurements of ICT equipment (temperature, hygrometry) and their transfer to the network management systems (NMS) are shown in figure 1.

NOTE 1: The definition of specific NMS for mobile or fixed networks is out of scope of the present document. The same comment applies to OSS.