



Standard Practice for Sampling Steam¹

This standard is issued under the fixed designation D1066; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers the sampling of saturated and superheated steam. It is applicable to steam produced in fossil fired and nuclear boilers or by any other process means that is at a pressure sufficiently above atmospheric to establish the flow of a representative sample. It is also applicable to steam at lower and subatmospheric pressures for which means must be provided to establish representative flow.

1.2 For information on specialized sampling equipment, tests or methods of analysis, reference should be made to the *Annual Book of ASTM Standards*, Vols 11.01 and 11.02, relating to water.

1.3 The values stated in SI units are to be regarded as standard. The values given in parentheses are for information only.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards*:²

- A269 Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service
- A335/A335M Specification for Seamless Ferritic Alloy-Steel Pipe for High-Temperature Service
- D1129 Terminology Relating to Water
- D1192 Guide for Equipment for Sampling Water and Steam in Closed Conduits³

¹ This practice is under the jurisdiction of ASTM Committee D19 on Water, and is the direct responsibility of Subcommittee D19.03 on Sampling Water and Water-Formed Deposits, Analysis of Water for Power Generation and Process Use, On-Line Water Analysis, and Surveillance of Water.

Current edition approved Dec. 15, 2006. Published January 2007. Originally approved in 1949. Last previous edition approved in 2001 as D1066 – 97 (2001). DOI: 10.1520/D1066-06.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Withdrawn. The last approved version of this historical standard is referenced on www.astm.org.

D3370 Practices for Sampling Water from Closed Conduits
D5540 Practice for Flow Control and Temperature Control for On-Line Water Sampling and Analysis

3. Terminology

3.1 *Definitions*:

3.1.1 For definitions of terms used in this practice, refer to definitions given in Practice D1129.

3.2 *Definitions of Terms Specific to This Standard*:

3.2.1 *isokinetic sampling (representative sampling)*—a condition wherein the sample entering the port (tip) of the sampling nozzle has the same as the velocity vector (velocity and direction) as the stream being sampled. Isokinetic sampling ensures a representative sample of dissolved chemicals, solids, particles, chemicals absorbed on solid particles, and in the case of saturated and wet steam, water droplets are obtained.

3.2.2 *sample cooler*—a small heat exchanger designed to provide cooling/condensing of small process sampling streams of water or steam.

3.2.3 *sampling*—the withdrawal of a representative portion of the steam flowing in the boiler drum lead or pipeline by means of a sampling nozzle and the delivery of this portion of steam in a representative manner for analysis.

3.2.4 *saturated steam*—a vapor whose temperature corresponds to the boiling water temperature at the particular existing pressure.

3.2.5 *superheated steam*—a vapor whose temperature is above the boiling water temperature at the particular existing pressure.

4. Summary of Practice

4.1 This practice describes the apparatus, design concepts and procedures to be used in extracting and transporting samples of saturated and superheated steam. Extraction nozzle selection and application, line sizing, condensing requirements and optimization of flow rates are all described. Condensed steam samples should be handled in accordance with Practices D3370 and D5540, and Guide D1192.




FIG. 1 Effect of Nono-Isokinetic Sampling

5. Significance and Use

5.1 It is essential to sample steam representatively in order to determine the amount of all impurities (dissolved chemicals, solid particles, chemicals absorbed on solid particles, water droplets) in it (1).⁴ An accurate measure of the purity of steam provides information, which may be used to determine whether the purity of the steam is within necessary limits to prevent damage or deterioration (corrosion, solid particle erosion, flow-accelerated corrosion, and deposit buildup) of downstream equipment, such as turbines. Impurities in the steam may be derived from boiler water carryover, inefficient steam separators, natural salt solubility in the steam and other factors. The most commonly specified and analyzed parameters are sodium, silica, iron, copper, and cation conductivity.

6. Interferences

6.1 *Saturated Steam*— Sampling of steam presents difficult extraction and transport problems that affect the representativeness of the sample.

6.1.1 Isokinetic sampling requires that the velocity vector (velocity and direction) of the fluid entering the sample nozzle port (tip) be the same as the stream being sampled at the location of the sample nozzle. When the sample is not extracted isokinetically the contaminants in the steam are not properly represented in the sample. The effects of non-isokinetic sampling are illustrated in Fig. 1 and can make the sample unrepresentative. The sample should be removed at a position away from the pipe wall, located at a point of average velocity which can be calculated for both laminar and turbulent flows.

6.1.2 Traditionally, saturated steam samples with initial steam velocities above 11 m/s (36 ft/s) were considered to

provide adequate turbulent flow to ensure transport of most particulates and ionic components. More recent studies (2,3) found that because many sample lines are long and uninsulated, steam samples are frequently fully condensed prior to reaching the sample station. Partially or fully condensed samples usually have a velocity too low to prevent excessive deposition and the sample becomes nonrepresentative of the source. Detailed design of the sample line to control vapor and liquid velocity can minimize this interference but cooling of saturated steam samples at the source is recommended to assure a representative sample. See Practices D3370 and D5540 for further information on factors that affect liquid sample transport.

6.2 *Superheated Steam*—Most contaminants can be dissolved in superheated steam. However, as steam pressure and temperature are reduced the solubility of many contaminants is decreased and the contaminants precipitate and deposit on the inner surfaces of the sample line (4). This condition has been found to be prevalent only in regions of dry wall tube where the temperature of the tube wall exceeds the saturation temperature of the steam.

6.2.1 Interference also occurs when the transport tube temperature is at or below the saturation temperature. The steam loses superheat and dissolved contaminants deposit on the tube wall. The sample is no longer representative. Superheated steam samples shall be cooled or desuperheated in the sample nozzle or immediately after extraction to ensure a representative sample. Cooling the sample within the sample nozzle may cause thermal fatigue. All necessary precautions should be taken. See 7.1.3.4 and 7.2.4.

7. Materials and Apparatus

7.1 Extracting the Sample:

7.1.1 *Saturated Steam*—Since saturated steam is normally sampled as a two-phase fluid, made up of steam and small

⁴ The boldface numbers given in parentheses refer to a list of references at the end of this standard.