

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Automatic electrical controls for household and similar use –
Part 2-19: Particular requirements for electrically operated oil valves, including
mechanical requirements**

**Dispositifs de commande électrique automatiques à usage domestique et
analogue –
Partie 2-19: Règles particulières pour les électrovannes de combustible liquide,
y compris les prescriptions mécaniques**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Automatic electrical controls for household and similar use –
Part 2-19: Particular requirements for electrically operated oil valves, including
mechanical requirements**

**Dispositifs de commande électrique automatiques à usage domestique et
analogue –
Partie 2-19: Règles particulières pour les électrovannes de combustible liquide,
y compris les prescriptions mécaniques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	3
1 Scope and normative references.....	5
2 Definitions.....	6
3 General requirements.....	9
4 General notes on tests.....	9
5 Rating.....	10
6 Classification.....	10
7 Information.....	12
8 Protection against electric shock.....	14
9 Provision for protective earthing.....	14
10 Terminals and terminations.....	14
11 Constructional requirements.....	15
12 Moisture and dust resistance.....	19
13 Electric strength and insulation resistance.....	19
14 Heating.....	19
15 Manufacturing deviation and drift.....	20
16 Environmental stress.....	21
17 Endurance.....	21
18 Mechanical strength.....	22
19 Threaded parts and connections.....	23
20 Creepage distances, clearances and distances through solid insulation.....	23
21 Resistance to heat, fire and tracking.....	23
22 Resistance to corrosion.....	23
23 Electromagnetic compatibility (EMC) requirements – emission.....	23
24 Components.....	23
25 Normal operation.....	24
26 Electromagnetic compatibility (EMC) requirements – immunity.....	24
27 Abnormal operation.....	24
28 Guidance on the use of electronic disconnection.....	26
Annexes.....	27
Figures.....	26
Table 27.2.101 – Maximum winding temperature (for test of blocked output conditions and valves declared under table 7.2, requirement 110).....	25

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS FOR HOUSEHOLD AND SIMILAR USE –

Part 2-19: Particular requirements for electrically operated oil valves, including mechanical requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-19 has been prepared by IEC technical committee 72: Automatic controls for household use.

This consolidated version of IEC 60730-2-19 consists of the first edition (1997) [documents 72/350/FDIS/ and 72/373/RVD], its amendment 1 (2000) [documents 72/467/FDIS and 72/491/RVD] and its amendment 2 (2007) [documents 72/745/FDIS and 72/750/RVD].

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience.

It bears the edition number 1.2.

A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2.

This Part 2-19 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the third edition of that standard (1999) and its amendment 1 (2003). Consideration may be given to future editions of, or amendments to IEC 60730-1.

This part 2 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: *Particular requirements for electrically operated oil valves, including mechanical requirements*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

Where this part 2 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, part 2 indicates that the relevant clause or subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practice are contained in the following subclauses:

- Table 7.2, requirement 120
- Table 7.2, note 102
- 11.103
- 11.105.1
- 11.105.2
- 11.113
- 18.102
- 27.2.101.1
- H.26.10

In this publication:

1) The following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

2) Subclauses, notes or items which are additional to those in part 1 are numbered starting from 101.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

AUTOMATIC ELECTRICAL CONTROLS FOR HOUSEHOLD AND SIMILAR USE –

Part 2-19: Particular requirements for electrically operated oil valves, including mechanical requirements

1 Scope and normative references

This clause of part 1 is not applicable.

Replacement:

1.1 This part 2 of IEC 60730 applies to electrically operated oil valves for use in, on or in association with equipment for household and similar use that use electricity, in combination with fuel in the liquid state such as distillates, residual fuels, etc.

This part 2 also applies to electrically operated oil valves using NTC or PTC thermistors, requirements for which are contained in annex J.

1.1.1 This standard applies to the inherent safety, to the operating values, operating times, and operating sequences where such are associated with equipment safety, and to the testing of electrically operated oil valves used in, or in association with, household or similar equipment, but also extended to industrial purposes where no dedicated product standard exists, such as that for central heating, air conditioning, process heating, etc.

This part 2 is also applicable to controls for appliances within the scope of IEC 60335-1.

Throughout this part 2 the word "equipment" means "appliance and equipment".

This part 2 does not apply to electrically operated oil valves designed exclusively for industrial applications.

Electrically operated oil valves for equipment not intended for normal household use, but which nevertheless may be used by the public, such as equipment intended to be used by laymen in shops, in light industry and on farms, are within the scope of this part 2.

This part 2 identifies a number of mechanical features as "under consideration". Until these mechanical requirements are incorporated in this part 2, each country using this part 2 will have to quantify these requirements.

Compliance of an electrically operated oil valve with this part 2 does not imply that the valve is acceptable without further tests for these mechanical features.

1.1.2 This part 2 applies to manual controls when such are electrically and/or mechanically integral with electrically operated oil valves.

Requirements for manual switches not forming part of an electrically operated oil valve are contained in IEC 61058-1.

This part 2 does not apply to electrically operated oil valves of nominal connection size above DN 150.

Hereinafter, the term "valve" is used to denote an electrically operated oil valve (including prime mover and valve body).

1.1.3 An electric actuator that is submitted to the testing laboratory in combination with an oil valve will be evaluated under this part 2. A separate electric actuator is evaluated under IEC 60730-2-14, which provides particular requirements for electric actuators.

1.1.4 This part 2 also applies to valves utilized as part of a system, or valves mechanically integral with multifunctional controls.

1.5 Normative references

This clause of part 1 is applicable except as follows:

Addition:

IEC 60730-2-14:2001, *Automatic electrical controls for household and similar use – Part 2: Particular requirements for electric actuators*

ISO 7-1:1994, *Pipe threads where pressure-tight joints are made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 228-1:2000, *Pipe threads where pressure-tight joints are not made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 274:1975, *Copper tubes of circular section – Dimensions*

ISO 301:1981, *Zinc alloy ingots intended for casting*

ISO 4400:1994, *Fluid power systems and components – Three-pin electrical plug connectors with earth contact – Characteristics and requirements*

ISO 6952:1994, *Fluid power systems and components – Two-pin electrical plug connectors with earth contact – Characteristics and requirements*

ISO 7005-1:1992, *Metallic flanges – Part 1: Steel flanges*

ISO 7005-2:1988, *Metallic flanges – Part 2: Cast iron flanges*

2 Definitions

This clause of part 1 is applicable except as follows:

2.2 Definitions of types of control according to purpose

Additional definitions:

2.2.17.101

electrically operated oil valve

an automatic valve in which the transmission is effected by an electrical prime mover and in which the operation controls the flow of oil

A semi-automatic valve that is opened manually and closes automatically, or vice versa, is also covered by this definition.

2.2.17.102

valve body

that part which is the main pressure boundary and which provides the oil flow passageways with end connections

2.2.17.103

end connection

valve body configuration provided to make a pressure-tight joint to the fluid-connecting system

2.2.17.104

nominal size

a numerical designation of size which is common to all components in a fluid conducting system other than components designated by outside diameter or by thread size

It may be designated by DN followed by a convenient round number, for reference purposes only.

Some older international standards refer to nominal size as nominal diameter but, for the purpose of this part 2, the two terms are synonymous.

2.3 Definitions relating to the function of controls

Additional definitions:

2.3.101

on-off valve

a valve which is open or closed, without any intermediate positions

2.3.102

normally closed valve

a valve which is closed when not electrically energized

2.3.103

normally open valve

a valve which is open when not electrically energized

2.3.103.1

semi-automatic normally open valve with latch

a valve which is closed when energized. When power is removed the valve will not open automatically and must be manually reset

2.3.103.2

normally open valve, automatic

a valve which is open when not electrically energized and when power is removed the valve will open automatically

2.3.104

modulating valve

a valve which has a variable flow rate between predetermined flow rates

2.3.104.1

multi-stage valve

a valve which permits operation at rated flow rate or at various predetermined flow rates below rated flow rate

2.3.105

closure member

a movable part of the valve which is positioned in the flow path to modify the rate of flow through the valve

2.3.106

closed position

position of the closure member when there is no intended oil flow from the outlet of the valve

2.3.107**open position**

position of the closure member when there is intended oil flow from the outlet of the valve

2.3.107.1**fully open position**

position of the closure member so that the amount of oil flowing through the valve is in accordance with the rated flow rate

2.3.108**flow rate**

volume of oil flowing through the valve in unit time

2.3.109**rated flow rate (capacity)**

flow rate under standard reference conditions of temperature pressure and viscosity declared at a given pressure difference

2.3.110**inlet pressure**

pressure at the inlet of the valve

2.3.111**outlet pressure**

pressure at the outlet of the valve

2.3.112**pressure difference**

difference between the inlet and outlet pressures

2.3.113**maximum operating pressure difference**

the declared maximum pressure difference against which the actuator can operate the closure member

2.3.114**minimum operating pressure difference**

the declared minimum pressure difference at which the valve opens or closes

2.3.115**maximum working pressure**

declared maximum inlet pressure at which the valve may be operated

It may be designated by the letters "PN" (also referred to as the pressure number) followed by a convenient round number, for reference purposes only.

2.3.116**safety shutoff valve**

normally closed valve that prevents delivery of oil when de-energized by the action of a limiter, a cut-out or a burner control system

A safety shutoff valve is considered a protective control and may also be used as an operating control.

A safety shutoff valve may be either of the automatic or semi-automatic opening type.

2.3.117**oil leakage, external**

leakage of oil from the valve body to atmosphere

2.3.118

oil leakage, internal

leakage of oil from the outlet piping connection with the closure member in the closed position

2.3.119

opening time

time interval between the electrical signal to open the valve and the achievement of maximum or other defined flow rate

2.3.120

closing time

time interval between when the electrical signal is removed and the achievement of the closed position

2.3.121

delay time

time interval between the electrical signal to open the valve and start of flow through the valve

2.3.122

proof of closure switch

an electrical switch which monitors the closed position of the valve closure member and which is used as an interlock

2.3.123

switching devices

an electrical switch actuated by the valve actuator and used as an electrical output

2.3.124

valve actuator

an electrically operated mechanism or prime mover used to effect the opening or closing action of a valve

3 General requirements

This clause of part 1 is applicable.

4 General notes on tests

This clause of part 1 is applicable except as follows:

4.1 Conditions of test

4.1.7 Is not applicable.

4.3 Instructions for test

Replacement:

4.3.2.6 For controls marked or declared for more than one rated voltage, the tests of clause 17 are made at the maximum rated voltage.

Additional subclause:

4.3.101 Where a manufacturer builds the same valve body with a number of different end connection sizes declared in 6.103, the tests of 18.101 shall be conducted on the largest end connection.

5 Rating

This clause of part 1 is applicable.

6 Classification

This clause of part 1 is applicable except as follows:

6.3 According to their purpose

6.3.12 *Additional subclauses:*

6.3.12.101 – on-off valve;

6.3.12.102 – normally closed valve;

6.3.12.103 – normally open valve;

6.3.12.103.1 – normally open valve, automatic;

6.3.12.103.2 – normally open valve, semi-automatic with latch;

6.3.12.104 – modulating valve;

6.3.12.105 – multi-stage valve;

6.3.12.106 – safety shutoff valve, automatic;

6.3.12.107 – safety shutoff valve, semi-automatic.

6.7 According to ambient temperature limits of the switch head

Modification:

To read "valve" for "control" and to read "prime mover" for "switch head".

6.12 *Replacement:*

According to the fluid temperature of oil flowing through the valve

6.15 According to construction

Additional subclauses:

6.15.101 According to type of oil

For example:

Number 1, 2, 4, 5, or 6 fuel oil.

6.15.102 According to viscosity of oil in SSU (Seconds Saybolt Universal)

Additional subclauses:

6.101 According to type of end connections

6.101.1 Valves provided with internally threaded end connections with either:

- ISO 7-1 or NPT thread when pressure tight joints are made on the thread, or
- ISO 228-1 thread when pressure tight joints are not made on the thread, but via an additional sealing washer.

6.101.2 Valves provided with externally threaded end connections for:

- a) compression fittings; or
- b) washered union connection; or
- c) cone seated union connection; or
- d) threaded pipe connections either according to ISO 7-1, ISO 228-1 or NPT thread.

6.101.3 Valves provided with flanged end connections suitable for connection to flanges with or without adaptors.

6.101.4 Valves provided with end connections suitable for connection by welding or brazing.

6.102 According to features of electrically operated oil valves

6.102.1 According to rated flow rate

Size to be specified in dimensions of inlet and outlet connections and in rated flow rate.

6.102.2 According to function

Description of function regarding number of oil connections and valve position when de-energized.

6.102.3 According to the type of the prime mover

Examples are:

- electro-magnetic: solenoid;
- electric motor;
- electro thermal: electrically heated wax, bi-metal;
- electro-hydraulic pump;
- pilot operated prime mover.

6.102.4 According to sequence of operation

Multi-stage, etc.

6.103 According to nominal pipe size of end connections


Designation of thread	Nominal size
1/8	DN6
1/4	DN8
3/8	DN10
1/2	DN15
3/4	DN20
1	DN25
1 1/4	DN32
1 1/2	DN40
2	DN50
2 1/2	DN65
3	DN80
4	DN100
5	DN125
6	DN150

Nominal size designation corresponds to the nominal size flanges according to ISO 7005-1 or ISO 7005-2.

7 Information

This clause of part 1 is applicable except as follows:

Modification:



iTech Standards
(<https://standards.iteh.ai>)
Document Preview