



# DRAFT INTERNATIONAL STANDARD ISO/DIS 4126-6

ISO/TC 185

Secretariat: AFNOR

Voting begins on  
2013-02-14

Voting terminates on  
2013-07-14

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

## Safety devices for protection against excessive pressure — Part 6: Application, selection and installation of bursting disc safety devices

*Dispositifs de sécurité pour protection contre les pressions excessives —*

*Partie 6: Application, sélection et installation des dispositifs de sûreté à disque de rupture*

[Revision of first edition (ISO 4126-6:2003)]

ICS 13.240

### ISO/CEN PARALLEL PROCESSING

This draft has been developed within the International Organization for Standardization (ISO), and processed under the **ISO-lead** mode of collaboration as defined in the Vienna Agreement.

This draft is hereby submitted to the ISO member bodies and to the CEN member bodies for a parallel five-month enquiry.

Should this draft be accepted, a final draft, established on the basis of comments received, will be submitted to a parallel two-month approval vote in ISO and formal vote in CEN.

**To expedite distribution, this document is circulated as received from the committee secretariat. ISO Central Secretariat work of editing and text composition will be undertaken at publication stage.**

**Pour accélérer la distribution, le présent document est distribué tel qu'il est parvenu du secrétariat du comité. Le travail de rédaction et de composition de texte sera effectué au Secrétariat central de l'ISO au stade de publication.**

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)  
Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/386490e-7d77-4475-8eaf-36541169ed81/iso-4126-6-2014>

### Copyright notice

This ISO document is a Draft International Standard and is copyright-protected by ISO. Except as permitted under the applicable laws of the user's country, neither this ISO draft nor any extract from it may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, photocopying, recording or otherwise, without prior written permission being secured.

Requests for permission to reproduce should be addressed to either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Reproduction may be subject to royalty payments or a licensing agreement.

Violators may be prosecuted.

## Contents

1	Scope .....	6
2	Normative references .....	6
3	Terms and definitions .....	6
4	Symbols and units .....	11
5	Application .....	12
6	Selection .....	14
6.1	Selection of bursting disc safety devices .....	14
6.2	Selection of the performance tolerance .....	15
7	Installation .....	17
7.1	General .....	17
7.2	Location of bursting disc safety devices .....	17
7.3	Installation of bursting disc safety devices .....	17
Annex A (informative) Information to be supplied by the purchaser .....		19
A.1	General .....	19
A.2	Application details .....	19
A.3	Bursting disc safety device operating details .....	19
A.4	Installation details .....	19
A.5	Special details .....	20
A.6	Language .....	20
A.7	Replacement bursting discs .....	20
Annex B (informative) Guidelines for determining the replacement period of a bursting disc .....		21
B.1	Introduction .....	21
B.2	Bursting disc safety devices .....	21
B.3	Replacement period .....	21
B.4	Methods of determining the replacement period .....	22
Annex C (informative) Pressure relief system discharge capacity .....		23
C.1	General .....	23
Annex D (informative) Deleted .....		26
Annex E (informative) Flow testing of bursting disc safety devices .....		27
E.1	Scope .....	27
E.2	Test requirements .....	27
E.3	Test Procedure .....	30
E.4	Calculation of flow resistance value from flow test data .....	34
Annex F (informative) Type testing of non-reclosing bursting disc safety devices .....		38
F.1	Type Testing .....	38
F.2	Determination of Rated $K_R$ .....	39
Annex G (informative) Performance characteristics of bursting disc safety devices .....		40

## Foreword

ISO 4126 was prepared by Technical Committee ISO/TC 185, *Safety devices for protection against excessive pressure*.

This second edition cancels and replaces the first edition (ISO 4126-6:2003), which has been technically revised.

ISO 4126 consists of the following parts, under the general title *Safety devices for protection against excessive pressure*:

*Part 1 : Safety valves*

*Part 2 : Bursting disc safety devices*

*Part 3 : Safety valves and bursting disc safety devices in combination*

*Part 4 : Pilot operated safety valves*

*Part 5 : Controlled safety pressure relief systems (CSPRS)*

*Part 6 : Application, selection and installation of bursting disc safety devices*

*Part 7 : Common data*

*Part 9 : Application and installation of safety devices excluding stand-alone bursting disc safety devices*

*Part 10 : Sizing of safety valves and connected inlet and outlet lines for gas/liquid two-phase flow*

*Part 11: Performance testing (under development)*

Part 7 contains data, which is common to more than one of the parts of ISO 4126 to avoid unnecessary repetition.

## Introduction

Safety devices for the protection of pressure equipment against excessive pressure include pressure relief devices such as safety valves and bursting disc safety devices which, dependent upon the application, may be used either as the sole pressure relieving devices or in conjunction with each other.

Operating problems frequently arise due to the use of pressure relieving devices not having been properly selected for the intended service or properly selected but whose performance is adversely affected by improper handling, wrong installation or lack of maintenance, any of which may affect the safety of the pressure equipment being protected.

It is important to consider not only the pressure relief devices but also the whole of the pressure relief system so as not to reduce the relieving capacity below that required or adversely affect the proper operation of the pressure relieving devices.

A bursting disc safety device is a non-reclosing pressure relief device which typically comprises a bursting disc, which is a pressure-containing and pressure-sensitive part designed to open by bursting at a predetermined pressure, and a bursting disc holder. There are many different types of bursting disc safety devices manufactured in corrosion resistant materials, both metallic and non-metallic, to cover a wide range of nominal sizes, burst pressures and temperatures. They are used to protect pressure equipment such as vessels, piping, gas cylinders or other enclosures from excessive pressure and/or excessive vacuum.

This standard covers the important considerations necessary in the application, selection and installation of bursting disc safety devices to give the required protection against excessive pressure and/or excessive vacuum.

D  
R  
A  
F  
T

Standard  
Full standard  
https://standards.iteh.ai/catalog/standards/iso/4126-6-2014/4126-6-2014

## 1 Scope

This standard gives guidance on the application, selection and installation of bursting disc safety devices used to protect pressure equipment from excessive pressure and/or excessive vacuum.

Annex A provides a checklist for the information to be supplied by the purchaser to the manufacturer.

Annex B gives guidance on the replacement period of a bursting disc and annex C guidance on determining the mass flow rate, for single phase fluids, of a pressure relief system that contains a bursting disc safety device

Annex E is a non-mandatory procedure for establishing the flow resistance of a burst bursting disc assembly.

Annex F non-mandatory procedure for type testing of bursting disc safety devices

Annex G provides typical performance characteristics for various bursting disc safety device types.

The requirements for the manufacture, inspection, testing, marking, certification and packaging of bursting disc safety devices are given in Part 2 of EN ISO 4126.

## 2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text, and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

ISO 4126-1:2003, *Safety devices for protection against excessive pressure — Part 1 : Safety valves*

ISO 4126-2:2003, *Safety devices for protection against excessive pressure — Part 2 : Bursting disc safety devices*

ISO 4126-3:2006, *Safety devices for protection against excessive pressure — Part 3 : Safety valves and bursting disc safety devices in combination*

ISO 4126-4, *Safety devices for protection against excessive pressure — Part 4 : Pilot operated safety valves*

ISO 4126-5, *Safety devices for protection against excessive pressure — Part 5 : Controlled safety pressure relief systems (CSPRS)*

ISO 4126-7:2003, *Safety devices for protection against excessive pressure — Part 7 : Common data*

## 3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in ISO 4126-2:2003 and the following apply.

### 3.1

#### **bursting disc safety device**

non-reclosing pressure relief device actuated by differential pressure and designed to function by the bursting of the bursting disc(s), and which is the complete assembly of installed components including, where appropriate, the bursting disc holder.

### 3.2

#### **bursting disc assembly**

complete assembly of components, which are installed in the bursting disc holder to perform the desired function

### 3.3

#### **bursting disc**

pressure-containing and pressure-sensitive component of a bursting disc safety device

**3.4****bursting disc holder**

that part of a bursting disc safety device, which retains the bursting disc assembly in position

**3.5****conventional domed bursting disc (also referred to as, forward acting)**

bursting disc which is domed in the direction of the bursting pressure (i.e. where the bursting pressure is applied to the concave side of the bursting disc (see Figure 1 of ISO 4126-2:2003)

**3.6****slotted lined bursting disc**

bursting disc made up of two or more layers, at least one of which is slit or slotted to control the bursting pressure of the bursting disc

**3.7****reverse domed bursting disc (also referred to as, reverse acting)**

bursting disc which is domed against the direction of the bursting pressure (i.e. where the bursting pressure is applied to the convex side of the bursting disc, see Figure 2 of ISO 4126-2:2003)

**3.8****flat bursting disc**

bursting disc having one or more layers which is flat when installed. It may be made of a ductile or brittle material

**3.9****graphite bursting disc**

bursting disc manufactured from graphite, impregnated graphite, flexible graphite or graphite composite and designed to burst due to bending or shearing forces

**3.10****specified bursting pressure**

bursting pressure quoted with a coincident temperature when defining the bursting disc requirements (used in conjunction with a performance tolerance, see 3.13)

**3.11****specified maximum bursting pressure**

maximum bursting pressure quoted with the coincident temperature when defining the bursting disc requirements (used in conjunction with specified minimum bursting pressure, see 3.12)

**3.12****specified minimum bursting pressure**

minimum bursting pressure quoted with the coincident temperature when defining the bursting disc requirements (used in conjunction with specified maximum bursting pressure, see 3.11)

**3.13****coincident temperature**

temperature of the bursting disc associated with a bursting pressure (see 3.10, 3.11 and 3.12) and which is the expected temperature of the bursting disc when it is required to burst

**3.14****performance tolerance**

range of pressure between the specified minimum bursting pressure and the specified maximum bursting pressure or the range of pressure in positive and negative percentages or quantities which is related to the specified bursting pressure

**3.15****operating pressure**

pressure existing at normal operating conditions within the system being protected

**3.16****relieving pressure**

maximum pressure under discharge conditions in the pressurised system

NOTE It can differ from the bursting pressure of the bursting disc.

**3.17**

**relieving temperature**

temperature under discharge conditions in the pressurised system

NOTE It can differ from the coincident temperature specified for the bursting disc.

**3.18**

**differential back pressure**

differential pressure across a bursting disc in the opposite direction to the direction of the bursting pressure, which is the result of pressure in the discharge system from other sources and/or a result of vacuum on the upstream side of the bursting disc

**3.19**

**vent area**

cross-section area available for discharge of fluid as calculated by the manufacturer.

NOTE The calculated vent area should not exceed the cross-sectional area of the upstream piping ( $A_1$ )

**3.20**

**batch**

quantity of bursting discs or bursting disc safety devices made as a single group of the same type, size, materials and specified bursting pressure requirements where the bursting discs are manufactured from the same lot of material

**3.21**

**bursting pressure**

value of the differential pressure between the upstream side and the downstream side of the bursting disc when it bursts

**3.22**

**stiffening ring**

component of a bursting disc assembly used primarily for reinforcing bursting discs

**3.23**

**back pressure support**

component of a bursting disc safety device, which prevents damage to the bursting disc due to differential back pressure

NOTE A back pressure support, which is intended to prevent damage to the bursting disc when the system pressure falls below atmospheric pressure, is sometimes referred to as a vacuum support.

**3.24**

**coating**

layer of metallic or non-metallic material applied to components of a bursting disc safety device by a coating process

**3.25**

**lining**

additional sheet or sheets of metallic or non-metallic material forming part of a bursting disc assembly or bursting disc holder

**3.26**

**plating**

metal layer applied to a bursting disc or bursting disc holder by a plating process

**3.27**

**temperature shield**

device which protects a bursting disc from excessive temperature



**3.28****operating ratio**

ratio between the operating pressure and the minimum limit of bursting pressure (see Figure 1)

NOTE 1 In the case of a pressure system with an operating pressure expressed in bar gauge and atmospheric pressure on the downstream side of the bursting disc :

$$\text{Operating ratio} = \frac{\text{operating pressure (bar)}}{\text{minimum limit of bursting pressure (bar)}}$$

NOTE 2 In the case of a pressure system with a back pressure on the downstream side of the bursting disc, the operating ratio is the value of the differential pressure between the upstream side and the downstream side of the bursting disc divided by the minimum limit of bursting pressure expressed as a differential pressure.

**3.29****bursting disc safety device discharge capacity**

rate at which a bursting disc safety device can discharge fluid after bursting of the bursting disc

**3.30****replacement period**

time period beginning at the installation of a bursting disc assembly and ending at replacement

**3.31****pressure relief system**

system intended for the safe relief of fluids from pressure equipment for prevention of excessive pressure

NOTE It can consist of equipment nozzle, inlet piping, pressure relief device(s) and discharge piping to atmosphere/collecting vessel/header.

**3.32****discharge coefficient**

coefficient which determines reduction of theoretical discharge capacity of a pressure relief system by the simplified approach (see C.2) which incorporates a burst bursting disc, forming part of a bursting disc safety device

NOTE It is denoted by the symbol  $\alpha$ .

**3.33****flow resistance factor,  $K_R$** 

a dimensionless expression of the velocity head loss attributed to the presence of a bursting disc safety device in a piping system

$K_{RG}$  - the flow resistance of a bursting disc safety device when burst with compressible fluid in contact with the upstream side of the bursting disc

$K_{RL}$  - the flow resistance of a bursting disc safety device when burst with incompressible fluid in contact with the upstream side of the bursting disc

$K_{RGL}$  - the flow resistance of a bursting disc safety device when burst with either compressible or incompressible fluid in contact with the upstream side of the bursting disc.

**3.34****base pressure**

pressure recorded at the pipe inlet of the bursting disc flow test system

**3.35****base temperature**

temperature recorded at the pipe inlet of the bursting disc flow test system

**3.36**

**maximum allowable pressure, PS**

maximum pressure for which the equipment is designed, as specified by the manufacturer

**3.37**

**non-fragmenting bursting disc safety device**

a bursting disc safety device that is designed to retain the petals material produced during activation.

DRAFT 2013

iTeh STANDARD PREVIEW  
(standards.itech.ai)  
Full standard:  
<https://standards.itech.ai/catalog/standards/sist/386490e-7d77-4475-8eaf-36541169ed81/iso-4126-6-2014>

## 4 Symbols and units

Table 1 — Symbols and their descriptions

Symbol	Description	Units
$A_0$	Required minimum cross-sectional flow area	mm <sup>2</sup>
$A_1$	Cross-sectional area of upstream piping	mm <sup>2</sup>
$A_B$	Bursting disc safety device vent area	mm <sup>2</sup>
$C$	Function of the isentropic exponent	-
$C_{\text{tap}}$	Sonic velocity at pressure tap	m/s
$D$	Test system pipework inside diameter	mm
$f$	Fanning friction for system, pipe	-
$G$	Mass velocity	kg/(m <sup>2</sup> ·h)
$k$	Isentropic exponent	-
$K_b$	Theoretical capacity correction factor for subcritical flow	-
$K_v$	Viscosity correction factor	-
$K_R$	Flow resistance factor	-
$K_{\text{tap}}$	Total resistance factor from pipe inlet of test system to pressure tap	-
$M$	Molecular mass	kg/kmol
$Ma_{\text{tap}}$	Mach number at pressure tap	-
$Ma_1$	Mach number at pipe inlet of test system	-
$p_1$	Test system pipe inlet pressure	bar abs.
$p_B$	Base pressure	bar abs.
$p_b$	Back pressure	bar abs.
$p_c$	Critical pressure	bar abs.
$p_o$	Relieving pressure	bar abs.
$p_{\text{tap}}$	Pressure at pressure tap	bar abs.
$p_r$	Reduced pressure	-
$Q_m$	Mass flow rate	kg/h
$R$	Universal gas constant	8314 J/kmol/K
Re	Reynolds Number	-
$T_B$	Base temperature	K
$T_o$	Relieving temperature	K
$T_{\text{tap}}$	Temperature recorded at pressure tap	K
$T_1$	Test system pipe inlet temperature	K
$v_o$	Specific volume at actual relieving pressure and temperature	m <sup>3</sup> /kg
$v_{\text{tap}}$	Specific volume at pressure tap	m <sup>3</sup> /kg
$x^a$	Dryness of wet steam	-
$Y_{\text{tap}}$	Expansion factor at pressure tap	-
$Y_1$	Expansion factor at pipe inlet of test system	-
$Z_o$	Compressibility factor at actual relieving pressure and temperature	-
$\rho$	Density	kg/m <sup>3</sup>
$\mu$	Dynamic viscosity	Pa·s
$\Delta p$	Differential pressure on venting across bursting disc safety device	bar abs.
$\alpha$	Discharge coefficient (see C.2.)	-

<sup>a</sup>  $x$  is expressed as 0,xx.

## 5 Application

**5.1** Subject to the requirements of the relevant standard covering the equipment to be protected, bursting disc safety devices may be used either as the sole pressure relieving device, in conjunction with safety valves or as part of a combination device.

**5.2** The discharge capacity of a system including a bursting disc safety device and its maximum limit of bursting pressure (see Figure 1) at the coincident temperature shall be such that the maximum relieving pressure does not exceed the requirements of the protected equipment. Annexes C, D and E give methods for determining discharge capacity of pressure relief systems incorporating bursting disc safety devices.

**5.3** The use of a bursting disc safety device as the sole pressure relieving device may be preferred in the following cases where:

- a) the rate of increase in pressure may be such that the rate of response of a safety valve would make it unsuitable ;
- b) leakage of the fluid cannot be tolerated under operating conditions ;
- c) operating conditions may involve deposition, which would make a safety valve inoperative ;
- d) the effect of low temperature would prevent a safety valve from operating ;
- e) large discharge areas are required.

**NOTE** A bursting disc safety device is a non-reclosing pressure relieving device, which after bursting could result in the total loss of pressure/contents from the protected equipment.

For all applications the pressure relief system shall be such that following the bursting of the bursting disc assembly any fragmentation or release of material does not:

- a) cause an unacceptable flow restriction within the pressure relief system ;
- b) impair the proper functioning of any other safety device ;
- c) affect the certified (discharge) capacity of any other safety device.

**5.4** Bursting disc safety devices may be used in association with safety valves, pilot operated safety valves or CSPRS (according to ISO 4126-1, ISO 4126-4 and ISO 4126-5 respectively) as permitted by the relevant standard. The application of the bursting disc safety devices shall not result in excessive pressure in the protected equipment.

**5.4.1** Bursting disc safety devices in conjunction with safety valve(s) may be used in the following cases :

- a) in series, to protect the safety valve against corrosion, fouling or operating conditions which may affect the safety valve performance ;
- b) in series, to prevent leakage ;
- c) in series, to prevent total loss of contents from the protected equipment following the bursting of the bursting disc ;
- d) in parallel, as an additional safeguard.

**5.4.2** Where a bursting disc safety device is to be installed upstream of a safety valve the following requirements shall be met :

- a) The space between the bursting disc safety device and the safety valve shall be provided with an appropriate means to prevent or detect an unacceptable build up in pressure.
- b) The bursting disc safety device shall be a non-fragmenting design.