

ISO/TC 244

Secretariat: JISC

Voting begins on:
2012-09-19

Voting terminates on:
2012-11-19

Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency —

Part 3: Batch-type aluminium melting furnaces

*Fours industriels et équipements associés — Méthode de mesure du
bilan énergétique et de calcul de l'efficacité —*

Partie 3: Fours dormants de fusion pour l'aluminium

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 13579-3:2012(E)

ITeH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8eb6a73e-a120-419f-9c6c-902f0ba16a5f/iso-13579-3-2013>

Copyright notice

This ISO document is a Draft International Standard and is copyright-protected by ISO. Except as permitted under the applicable laws of the user's country, neither this ISO draft nor any extract from it may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, photocopying, recording or otherwise, without prior written permission being secured.

Requests for permission to reproduce should be addressed to either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Reproduction may be subject to royalty payments or a licensing agreement.

Violators may be prosecuted.

Contents

Page

Foreword	v
Introduction.....	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 Terms related to type of energy used in this part of ISO 13579	2
4 Symbols	5
5 Basic principles	7
5.1 General	7
5.2 Energy flow diagram	9
5.3 Process Heating Assessment Survey Tool	9
6 Basic conditions of measurement and calculation	9
6.1 State of furnace	9
6.2 Duration of measurement	9
6.3 Unit of specific energy intensity	9
6.4 Reference conditions	9
6.5 Unit of amount of gas	9
6.6 Fuel	9
7 Type of energy used in this part of ISO 13579	9
7.1 General	9
7.2 Energy balance	10
7.3 Thermal energy balance	11
7.4 Energy balance of electrical generation	12
7.5 Recycled energy	13
8 Measurement method	13
8.1 General	13
8.2 Fuel	13
8.3 Atomization agent	13
8.4 Combustion air and exhaust gas	14
8.5 Products	14
8.6 Temperature of furnace surface	16
8.7 Furnace inner wall temperature	16
8.8 Inner furnace pressure	16
8.9 Cooling water	16
8.10 Electrical auxiliary equipment	16
8.11 Generation of utilities	16
8.12 Recycled energy	16
9 Calculation	17
9.1 General provisions	17
9.2 Total energy input	17
9.3 Total energy output	18
9.4 Total energy efficiency	20
10 Energy balance evaluation report	21
Annex A (informative) Reference data	22
Annex B (informative) Measurement of energy balance and calculation of efficiency of a batch-type aluminium melting furnace sample report	24

Annex C (informative) **Assessment of uncertainty of the total energy efficiency**.....32
Bibliography.....35

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8eb6a73e-a120-419f-9c6c-902f0ba16a5f/iso-13579-3-2013>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 13579-3 was prepared by Technical Committee ISO/TC 244, *Industrial furnaces and associated thermal processing equipment*.

ISO 13579 consists of the following parts, under the general title *Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency*:

- Part 1: *General methodology*
- Part 3: *Reheating furnaces for steel*
- Part 2: *Batch-type aluminium melting furnaces*
- Part 4: *Furnaces with protective or reactive atmosphere*

Introduction

All calculations within this part of ISO 13579 are based on the location of equipment at reference conditions.

NOTE For equipment intended to be installed above or below sea level, it is expected that the impact of the elevation be calculated for that location.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8eb6a73e-a120-419f-9c6c-902f0ba16a5f/iso-13579-3-2013>

Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency —

Part 3: Batch-type aluminium melting furnaces

1 Scope

This part of ISO 13579 specifies general methodology for measuring energy balance and calculating the efficiency of the process involving batch-type aluminium melting furnaces as designed by furnace manufacturers. This general methodology includes:

- measurement methods;
- calculations (general calculation);
- energy balance and efficiency calculation evaluation report.

This part of ISO 13579 is not applicable to any efficiencies related to the process itself outside of batch-type aluminium melting furnaces.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 13574, *Industrial furnaces and associated processing equipment — Vocabulary*

ISO 13579-1:—, *Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency — Part 1: General methodology*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13574 and the following apply.

3.1 Terms related to type of energy used in this part of ISO 13579

3.1.1 Total energy input

3.1.1.1

total energy input

E_{input}

aggregate of measured energy input brought into the area of energy balance, and which is composed of fuel equivalent energy and other energy input

3.1.2 Fuel equivalent energy

3.1.2.1

fuel equivalent energy

E_{fe}

aggregate of input energy which is composed of calorific value of fuel, calorific value of waste, calorific value of source gas of atmospheric gas and fuel equivalent energy of electricity

3.1.2.2

calorific value of fuel

$E_{h,fuel}$

heat of combustion of fuel which is consumed and used for heating products in the area of energy balance

3.1.2.3

calorific value of waste

$E_{h,waste}$

calorific value of waste which is brought to the area of energy balance with products

EXAMPLE Waste oil on aluminium scrap.

3.1.2.4

fuel equivalent energy of electricity

$E_{fe,el}$

aggregate of fuel equivalent energy of electricity converted from each occurrence of electrical energy consumption in the area of energy balance

3.1.3 Other energy input

3.1.3.1

other energy input

E_{others}

energy that is composed of sensible heat of fuel, sensible heat of combustion air or other oxidant, sensible heat of atomization agent for liquid fuel, heat of reaction and sensible heat of infiltration air

3.1.3.2

heat of reaction

E_{react}

heat generated by the oxidation reaction of products in the area of energy balance measurement

EXAMPLE The formation of scale of steel products during the oxidation reaction.

3.1.3.3

sensible heat of infiltration air

$E_{s,infiltr}$

sensible heat of air that leaks into the furnace through supply/discharge port or gaps in the operating systems of the furnace

Note 1 to entry This term may be replaced with "sensible heat of false air".

3.1.4 Total energy output

3.1.4.1

total energy output

E_{output}

aggregate of measured energy output emitted from or consumed in the area of energy balance which is composed of thermal energy output, energy consumed in electrical auxiliary equipment, energy used for generation of utility and electrical generation loss

3.1.5 Thermal energy output

3.1.5.1

thermal energy output

$E_{\text{therm,out}}$

aggregate of thermal energy which is emitted from the area of energy balance

Note 1 to entry Thermal energy output is composed of energy defined in 3.1.5.2 to 3.1.5.11.

3.1.5.2

effective energy

E_{effect}

enthalpy that products gain in the area of energy balance

3.1.5.3

sensible heat of oxidized substance

$E_{\text{l,oxid}}$

sensible heat of substances which have reacted with oxygen, formed in the thermal process brought out from the area of energy balance measurement

3.1.5.4

sensible heat of exhaust gas

E_{exhaust}

sensible heat of expended gas which is emitted from the area of energy balance measurement

3.1.5.5

heat storage loss by batch-type furnace

$E_{\text{l,storage}}$

sensible heat which a furnace refractory gains within a batch-type furnace operation cycle

3.1.5.6

wall loss

$E_{\text{l,wall}}$

thermal energy emitted from the surface of industrial furnaces by radiation and convection

3.1.5.7

heat loss of discharged blowout from furnace opening

$E_{\text{l,blowout}}$

sensible heat of blowout gas emitted from the furnace opening

3.1.5.8

heat loss of radiation from furnace opening

$E_{\text{l,opening}}$

thermal energy emitted from the furnace opening by radiation

3.1.5.9

heat loss from furnace parts installed through furnace wall

$E_{\text{l,parts}}$

thermal energy emitted through furnace parts which are installed through furnace wall

EXAMPLE As in the case of a roller hearth furnace.

**3.1.5.10
cooling water loss**

$E_{l,cw}$
thermal energy brought out by cooling water from the area of energy balance measurement

**3.1.5.11
other losses**

$E_{l,other}$
unmeasured thermal energy losses from the area of energy balance

3.1.6 Energy consumed in electrical auxiliary equipment

**3.1.6.1
energy consumed in electrical auxiliary equipment**

E_{aux}
energy utilized in electrical auxiliary equipment which is composed of energy consumed in installed electrical auxiliary equipment and energy used for fluid transfer

**3.1.6.2
energy consumed in installed electrical auxiliary equipment**

$E_{aux,installed}$
aggregate of total energy used in installed electrical auxiliary equipment (e.g. fans, pumps) installed in the area of energy balance

**3.1.6.3
energy used for fluid transfer**

$E_{aux,fluid}$
aggregate of energy for fluid transfer calculated from the property of the fluid

EXAMPLE For cooling water, fuel, etc.

3.1.7 Energy used for generation of utility

**3.1.7.1
utility**

service other than fuel and electricity provided to the area of energy balance

EXAMPLE Oxygen, steam and atmospheric gas as specified in ISO 13579-1:—, 3.1.7.1.

**3.1.7.2
energy used for generation of utility**

$E_{utility}$
aggregate of energy for the generation of utilities used in the area of energy balance

3.1.8 Electrical generation loss

**3.1.8.1
electrical generation loss**

$E_{l,eg}$
energy loss in electrical generation which is backcalculated from fuel equivalent energy and total consumed electrical energy

3.1.9 Thermal energy balance

3.1.9.1

thermal energy input from electrical heating source

heat energy entering the process from an electrical heating source, such as an electrical heater emitted to the area of energy balance

3.1.9.2

circulating heat

heat that circulates within equipment or system installed in the area of energy balance

3.1.10 Energy balance of electrical generation

3.1.10.1

total consumed electrical energy

$E_{e,\text{total}}$

aggregate of electrical energy which is consumed in the area of energy balance and equal to the sum of thermal energy input from electrical heating source, energy consumed in electrical auxiliary equipment and electrical energy used for generation of utility

3.1.10.2

electrical energy used for generation of utilities

$E_{e,\text{utility}}$

aggregate of electrical energy consumed for generation of utilities (e.g. generation of oxygen) used in the area of energy balance

3.1.11 Recycled energy

3.1.11.1

recycled energy

E_{re}

energy that is regenerated from the wasted thermal energy from the area of energy balance

EXAMPLE Energy reused in waste gas boiler

4 Symbols

For the purposes of this document, the following symbols apply.

NOTE Tons used are metric tons.

Symbol	Meaning	Unit
$c_{pm,p1}$	mean specific heat of products between T_{p1} and 273,15 K	kJ/(kg·K)
$c_{pm,p2}$	mean specific heat of products between T_{p2} and 273,15 K	kJ/(kg·K)
$c_{pm,ps}$	mean specific heat of products between T_s and 273,15 K	kJ/(kg·K)
$c_{pm,oxid}$	mean specific heat of scale	kJ/(kg·K)
E_{aux}	energy consumed in electrical auxiliary equipment per ton of products	kJ/t
$E_{aux,fluid}$	aggregate of energy used for fluid transfer per ton of products	kJ/t
$E_{aux,installed}$	aggregate of energy used in installed electrical auxiliary equipment per ton of products	kJ/t
E_{effect}	effective energy per ton of products	kJ/t
$E_{exhaust}$	sensible heat of exhaust gas per ton of products	kJ/t
e_{Al}	heat by formation of scale per kilogram of scale	kJ/kg

Symbol	Meaning	Unit
e_{latent}	latent heat of melting per kilogram of aluminium	kJ/kg
E_{fe}	fuel equivalent energy of electricity per ton of products	kJ/t
$E_{\text{fe,el}}$	fuel equivalent energy of electricity per ton of products	kJ/t
$E_{\text{h,fuel}}$	calorific value of fuel per ton of products	kJ/t
$E_{\text{h,waste}}$	calorific value of waste per ton of products	kJ/t
E_{input}	total energy input per ton of products	kJ/t
$E_{\text{l,blowout}}$	heat loss of discharged blowout from furnace opening per ton of products	kJ/t
$E_{\text{l,cw}}$	cooling water loss per ton of products	kJ/t
$E_{\text{l,eg}}$	energy loss in electrical generation	kJ/t
$E_{\text{l,opening}}$	heat loss of radiation from furnace opening per ton of products	kJ/t
$E_{\text{l,other}}$	other losses per ton of products	kJ/t
$E_{\text{l,parts}}$	Heat loss from furnace parts installed through furnace wall	kJ/t
$E_{\text{l,storage}}$	heat storage loss by batch-type furnace per ton of products	kJ/t
$e_{\text{l,storage}}$	heat storage loss by batch-type furnace per square metre of furnace wall	kJ/m ²
$E_{\text{l,wall}}$	wall loss per ton of products	kJ/t
E_{others}	other energy input per ton of products	kJ/t
E_{p1}	sensible heat (or enthalpy) of products at the time when products are loaded in the area of energy balance per ton of products	kJ/t
E_{p2}	sensible heat (or enthalpy) of products at the time when products are extracted from the area of energy balance per ton of products	kJ/t
E_{react}	heat of reaction per ton of products	kJ/t
$E_{\text{s,air}}$	sensible heat of combustion air or other oxydant per ton of products	kJ/t
$E_{\text{s,atomize}}$	sensible heat of atomization agent per ton of products	kJ/t
$E_{\text{s,fuel}}$	sensible heat of fuel per ton of products	kJ/t
$E_{\text{s,infil}}$	sensible heat of infiltration air per ton of products	kJ/t
$E_{\text{s,oxid}}$	sensible heat of oxidized substance per ton of products	kJ/t
$E_{\text{therm,out}}$	thermal (output) energy per ton of products	kJ/t
E_{utility}	energy used for generation of utilities per ton of products	kJ/t
$E_{\text{u,oxy}}$	energy for generation of oxygen per ton of products	kJ/t
$E_{\text{u,steam}}$	energy for generation of steam per ton of products	kJ/t
M_{loss}	loss of mass per ton of products	kg/t
M_{oxid}	mass of oxidized substance per ton of products	kg/t
M_{p}	mass of products	kg or t
T_{p1}	average temperature of products at the time of loading to the area of energy balance	K
T_{p2}	average temperature of products at the time of extracting from the area of the energy balance	K
T_{s}	melting temperature of aluminium	K
η_1	total energy efficiency	—
η_e	regional electrical generation efficiency	—
σ_1	absolute error of thermocouple	°C
σ_2	absolute error of compensation lead wire	°C
σ_3	absolute error of output device of thermocouple	°C