

DRAFT INTERNATIONAL STANDARD

ISO/DIS 14520-1

ISO/TC 21/SC 8

Secretariat: SA

Voting begins on:
2014-12-08

Voting terminates on:
2015-03-08

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 1: General requirements

Systèmes d'extinction d'incendie utilisant des agents gazeux — Propriétés physiques et conception des systèmes —

Partie 1: Exigences générales

ICS: 13.220.10

ITeh STANDARD PREVIEW
(Standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a4d382cl-302a-44c5-9eec-6052264f43b/iso-14520-1-2015>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.



Reference number
ISO/DIS 14520-1:2014(E)

© ISO 2014

iTeh STANDARD PREVIEW
(Standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a4d382cl-302a-44c5-9eec-6052264f43b/iso-14520-1-2015>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

	Page
Foreword	vii
Introduction.....	vii
1 Scope	1
2 Normative references.....	2
3 Terms and definitions	3
4 Use and limitations.....	6
4.1 General	6
4.2 Extinguishants	7
4.2.1 Environmental properties	7
4.3 Electrostatic discharge	7
4.4 Compatibility with other extinguishants	8
4.5 Temperature limitations.....	8
5 Safety	8
5.1 Hazard to personnel	8
5.2 Safety precautions	9
5.2.1 General	9
5.2.2 For normally occupied areas	9
5.2.3 For normally unoccupied areas	9
5.2.4 For unoccupiable areas	12
5.3 Occupiable areas.....	12
5.4 Electrical hazards	13
5.5 Electrical earthing	13
5.6 Electrostatic discharge.....	14
6 System design	14
6.1 General	14
6.2 Extinguishant supply	14
6.2.1 Quantity	14
6.2.2 Quality.....	14
6.2.3 Container arrangement	14
6.2.4 Storage containers	14
6.3 Distribution	15
6.3.1 General	15
6.3.2 Piping.....	16
6.3.3 Fittings.....	16
6.3.4 Pipe and valve supports	17
6.3.5 Valves	17
6.3.6 Nozzles	18
6.3.7 Pressure reducing orifice assembly.....	18
6.4 Detection, actuation and control systems	19
6.4.1 General	19
6.4.2 Automatic detection	19
6.4.3 Operating devices	19
6.4.4 Control equipment.....	20
6.4.5 Operating alarms and indicators	20
6.4.6 Hold switches	20
7 Extinguishant system design.....	20
7.1 General	20
7.2 Specifications, plans and approvals	21

7.2.1	Specifications.....	21
7.2.2	Working documents	21
7.3	System flow calculations	21
7.3.1	General.....	21
7.3.2	Balanced and unbalanced system	21
7.3.3	Friction losses.....	24
7.3.4	Pressure drop.....	24
7.3.5	Valves and fittings	24
7.3.6	Piping length	24
7.3.7	Drawings.....	24
7.3.8	Liquefied gases — Specific requirements	24
7.4	Enclosures.....	24
7.5	Extinguishant concentration requirements	25
7.5.1	Flame extinguishment	25
7.5.2	Inerting	26
7.6	Total flooding quantity	26
7.6.1	General.....	26
7.6.2	Liquefied gases.....	26
7.6.3	Non-liquefied gas.....	27
7.7	Altitude adjustment	27
7.8	Duration of protection	28
7.9	System performance	28
7.9.1	Discharge time	28
7.9.2	Extended discharge.....	29
8	Commissioning and acceptance.....	29
8.1	General.....	29
8.2	Tests.....	29
8.2.1	General.....	29
8.2.2	Enclosure check	29
8.2.3	Review of mechanical components	29
8.2.4	Review of enclosure integrity.....	30
8.2.5	Review of electrical components	30
8.2.6	Preliminary functional tests.....	31
8.2.7	System functional operational test	32
8.2.8	Remote monitoring operations (if applicable)	32
8.2.9	Control panel primary power source	32
8.2.10	Completion of functional tests	32
8.3	Completion certificate and documentation.....	32
9	Inspection, maintenance, testing and training	33
9.1	General.....	33
9.2	Inspection	33
9.2.1	General.....	33
9.2.2	Container	33
9.2.3	Hose	33
9.2.4	Enclosures.....	33
9.3	Maintenance	34
9.3.1	General.....	34
9.3.2	User's programme of inspection	34
9.3.3	Service schedule.....	34
9.4	Training	34
Annex A (normative)	Working documents	35
A.1	General.....	35
A.2	Working documents	35
A.3	Specific details	36
A.3.1	Pre-engineered systems	36
A.3.2	Engineered systems	36
Annex B (normative)	Determination of flame-extinguishing concentration of gaseous extinguishants by the cup burner method	37

B.1	Scope	37
B.2	Principle.....	37
B.3	Requirements for apparatus.....	37
B.3.1	General	37
B.3.2	Cup.....	38
B.3.3	Chimney.....	38
B.3.4	Diffuser	38
B.3.5	Fuel supply.....	39
B.3.6	Manifold.....	39
B.3.7	Air supply	39
B.3.8	Extinguishant supply	39
B.3.9	Delivery system	39
B.4	Requirements for materials.....	39
B.4.1	Air.....	39
B.4.2	Fuel	39
B.4.3	Extinguishant.....	39
B.5	Procedure for inflammable liquids	39
B.6	Procedure for inflammable gases.....	40
B.7	Extinguishant extinguishing concentration	41
B.7.1	Preferred method.....	41
B.7.2	Alternative method	41
B.8	Reporting of results	42
Annex C (normative) Fire extinguishment/area coverage fire test procedure for engineered and pre-engineered extinguishing units 43		
C.1	Requirements.....	43
C.2	Type of test and report of test results.....	43
C.2.1	Type of test	43
C.2.2	Reporting of test results	44
C.3	Extinguishing system	46
C.4	Extinguishing concentration.....	47
C.4.1	Extinguishing agent concentration	47
C.4.2	Cold discharge test	48
C.5	Nozzle distribution verification tests.....	49
C.5.1	Nozzle minimum height/maximum area coverage test.....	49
C.5.2	Nozzle maximum height test	55
C.6	Extinguishing concentration tests	57
C.6.1	Wood crib test.....	57
C.6.2	Heptane pan test.....	63
C.6.3	Polymeric sheet fire test	65
Annex D (normative) Method of evaluating inerting concentration of a fire extinguishant..... 71		
D.1	Scope	71
D.2	Principle.....	71
D.3	Apparatus	71
D.4	Procedure	71
D.5	Inerting concentration.....	72
Annex E (normative) Door fan test for determining of minimum hold time 73		
E.1	Scope	73
E.2	Test for determination of predicted hold time.....	Error! Bookmark not defined.
E.2.1	Principle.....	Error! Bookmark not defined.
E.2.2	Apparatus	Error! Bookmark not defined.
E.2.3	Calibration and accuracy of apparatus	Error! Bookmark not defined.
E.2.4	Preliminary preparation	Error! Bookmark not defined.
E.2.5	Evaluation of enclosure	Error! Bookmark not defined.
E.2.6	Measurement of enclosure	Error! Bookmark not defined.
E.2.7	Test procedure.....	Error! Bookmark not defined.
E.2.8	Calculation	Error! Bookmark not defined.
E.3	Treatment of enclosures with predicted hold times less than the recommended value	Error! Bookmark not defined.
E.3.1	General	Error! Bookmark not defined.

E.3.2	Leakage areas	Error! Bookmark not defined.
E.3.3	Improved sealing of the enclosure	Error! Bookmark not defined.
E.3.4	Quantification and location of leaks	Error! Bookmark not defined.
E.4	Report	Error! Bookmark not defined.
Annex F (informative) System performance verification		89
Annex G (informative) Safe personnel exposure guidelines.....		90
G.1	Scope	90
G.2	Safety	90
G.3	Hazards to personnel — Potential hazards.....	90
G.3.1	Agent itself	90
G.3.2	Noise	90
G.3.3	Turbulence.....	90
G.3.4	Low temperature	90
G.4	Halocarbon agents.....	91
G.4.1	Toxicity of halocarbons (liquefied gases).....	91
G.4.2	PBPK model	92
G.4.3	Safe exposure guidelines for halocarbons	93
G.5	Inert gas (non-liquefied gas).....	95
G.5.1	Physiological effects of inert gas agents	95
G.5.2	Safe exposure guidelines for inert gas agents	95
Annex H (informative) Flow calculation implementation method and flow calculation verification and testing for approvals.....		97
H.1	Scope	97
H.2	Calculation method implementation.....	97
H.3	Minimum accuracy recommendations	98
H.3.1	Recommended design limits to be included inside the flow calculation method (software)	98
H.4	Recommended testing procedure for system flow calculation method (software) validation	98
H.4.1	General.....	98
H.4.2	System design for testing	99
H.5	Pass/fail criteria	100

Teh STANDRD REVIEW
302a-44c5-9ec-09326af4
Full standard
<https://standards.itech.ie/catalogue/standards/iso/iso-14520-1-215>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 14520 1 was prepared by Technical Committee ISO/TC 21, Equipment for fire protection and fire fighting, Subcommittee SC 8, Gaseous media and firefighting systems using gas.

This second edition cancels and replaces the first edition (ISO 14520-1:2000), which has been technically revised.

Annex C has been extensively revised to include polymeric sheet fuel array fire tests [polymethyl methacrylate (PMMA)], [polypropylene (PP)] and [acrylonitrile-butadiene-styrene (ABS)]. These tests are designed to more closely represent plastic fuel hazards such as may be encountered in information technology, telecommunications and process control facilities.

Annex E has been re-structured to accommodate lighter-than-air gases and to provide means for dealing with non-standard (as opposed to geometrically regular) hazard enclosures.

Also incorporated in this revision of ISO 14520-1 are safe personnel exposure guidelines. Annex G, recognizing physiologically based pharmacokinetic (PBPK) modelling and hypoxic guidelines to define safe human exposure limits.

ISO 14520 consists of the following parts, under the general title Gaseous fire-extinguishing systems — Physical properties and system design6:

- Part 1: General requirements
- Part 2: CF3I extinguishant
- Part 5: FK-5-1-12 extinguishant
- Part 6: HCFC Blend A extinguishant
- Part 8: HFC 125 extinguishant
- Part 9: HFC 227ea extinguishant
- Part 10: HFC 23 extinguishant
- Part 11: HFC 236fa extinguishant

- Part 12: IG-01 extinguishant
- Part 13: IG-100 extinguishant
- Part 14: IG-55 extinguishant
- Part 15: IG-541 extinguishant

Parts 3, 4 and 7, which dealt with FC-2-1-8, FC-3-1-10 and HCFC 124 extinguishants, respectively, have been withdrawn, as these types are no longer manufactured.

iTeh STANDARD PREVIEW
(Standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a4d382cl-302a-44c5-9eec-6052264f43b/iso-14520-1-2015>

Introduction

Fire fighting systems covered in this part of ISO 14520 are designed to provide a supply of gaseous extinguishing medium for the extinction of fire.

Several different methods of supplying extinguishant to, and applying it at, the required point of discharge for fire extinction have been developed in recent years, and there is a need for dissemination of information on established systems and methods. This part of ISO 14520 has been prepared to meet this need.

In particular, new requirements to eliminate the need to release extinguishants during testing and commissioning procedures are included. These are linked to the inclusion of enclosure integrity testing.

The requirements of this part of ISO 14520 are made in the light of the best technical data known to the working group at the time of writing but, since a wide field is covered, it has been impracticable to consider every possible factor or circumstance that might affect implementation of the recommendations.

It has been assumed in the preparation of this part of ISO 14520 that the execution of its provisions is entrusted to people appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid unnecessary release of extinguishant.

Attention is drawn to the Montreal Protocol on substances that deplete the ozone layer.

It is important that the fire protection of a building or plant be considered as a whole. Gaseous extinguishant systems form only a part, though an important part, of the available facilities, but it should not be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid or emergency use, or to deal with special hazards.

Gaseous extinguishants have for many years been a recognized effective medium for the extinction of inflammable liquid fires and fires in the presence of electrical and ordinary Class A hazards, but it should not be forgotten, in the planning of comprehensive schemes, that there may be hazards for which these media are not suitable, or that in certain circumstances or situations there may be dangers in their use requiring special precautions.

Advice on these matters can be obtained from the appropriate manufacturer of the extinguishant or the extinguishing system. Information may also be sought from the appropriate fire authority, the health and safety authorities and insurers. In addition, reference should be made as necessary to other national standards and statutory regulations of the particular country.

It is essential that fire-fighting equipment be carefully maintained to ensure instant readiness when required. Routine maintenance is liable to be overlooked or given insufficient attention by the owner of the system. It is, however, neglected at peril to the lives of occupants of the premises and at the risk of crippling financial loss. The importance of maintenance cannot be too highly emphasized. Installation and maintenance should only be done by qualified personnel.

Inspection preferably by a third party, should include an evaluation that the extinguishing system continues to provide adequate protection for the risk (protected zones as well as state of the art can change over time).

The test protocol contained in Annex C of this part of ISO 14520 was developed by a special working group of ISO/TC 21/SC 8. Annex C deals with the tests for determination of the extinguishing concentrations and system performance and they are designed in such a way to allow individual installers to use his/her/system and carry out all of the extinguishing tests. The need for the tests presented in Annex C was established by the fact that the previously used Class A fire test involved wood crib, heptane pan and heptane can test fires in an enclosure of 100 m³, and did not necessarily indicate extinguishing concentrations suitable for the protection of plastic fuel hazards such as may be encountered in information technology, telecommunications and process control facilities.

As a consequence of the above, the current Annex C of this part of ISO 14520 has been revised as described in the Foreword.

Specific parts 3, 4 and 7 have been withdrawn on the basis that the extinguishing media have not been commercialized, and a new agent specific part 5 has been introduced to cover FK-5-1-12 (dodecafluoro-2-methylpentan-3-one) systems.

ITeh STANDARD PREVIEW
(Standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a4d382cl-302a-44c5-9eec-6052264f43b/iso-14520-1-2015>

Physical properties and system design - Part 1: General requirements

1 Scope

This part of ISO 14520 specifies requirements and gives recommendations for the design, installation, testing, maintenance and safety of gaseous fire fighting systems in buildings, plant or other structures, and the characteristics of the various extinguishants and types of fire for which they are a suitable extinguishing medium.

It covers total flooding systems primarily related to buildings, plant and other specific applications, utilizing electrically non-conducting gaseous fire extinguishants that do not leave a residue after discharge and for which there are sufficient data currently available to enable validation of performance and safety characteristics by an appropriate independent authority. This part of ISO 14520 is not applicable to explosion suppression.

This part of ISO 14520 is not intended to indicate approval of the extinguishants listed therein by the appropriate authorities, as other extinguishants may be equally acceptable. CO₂ is not included as it is covered by other International Standards.

This part of ISO 14520 is applicable to the extinguishants listed in Table 1. It is essential that it be used in conjunction with the separate parts of ISO 14520 for specific extinguishants, as cited in Table 1.

TRANSLATED AND PREPARED
<https://standards.iteh.ai/standard/302a-44c5-9eec-605224fb/iso-14520-1-2015>

Table 1 — Listed extinguishant

Extinguishant	Chemical	Formula	CAS No.	International Standard
CF ₃ I	Trifluoriodomethane	CF ₃ I	2314-97-8	ISO 14520-2
FK-5-1-12	Dodecafluoro-2-methylpentan-3-one	CF ₃ CF ₂ C(O)CF(CF ₃) ₂	756-13-8	ISO 14520-5
HCFC Blend A				
HCFC-123	Dichlorotrifluoroethane	CHCl ₂ CF ₃	306-83-2	
HCFC-22	Chlorodifluoromethane	CHClF ₂	75-45-6	ISO 14520-6
HCFC-124	Chlorotetrafluoroethane	CFCIFCF ₃	2837-89-0	
	Isopropenyl-1-methylcyclohexene	C ₁₀ H ₁₆	5989-27-5	
HFC 125	Pentafluoroethane	CHF ₂ CF ₃	354-33-6	ISO 14520-8
HFC 227ea	Heptafluoropropane	CF ₃ CHFCF ₃	2252-84-8	ISO 14520-9
HFC 23	Trifluoromethane	CHF ₃	75-46-7	ISO 14520-10
HFC 236fa	Hexafluoropropane	CF ₃ CH ₂ CF ₃	27070-61-7	ISO 14520-11
IG-01	Argon	Ar	74040-37-1	ISO 14520-12
IG-100	Nitrogen	N ₂	7727-37-9	ISO 14520-13
	Nitrogen (50 %)	N ₂	7727-37-9	
IG-55	Argon (50 %)	Ar	74040-37-1	ISO 14520-14
	Nitrogen (52 %)	N ₂	7727-37-9	
IG-541	Argon (40 %)	Ar	74040-37-1	ISO 14520-15
	Carbon dioxide (8 %)	CO ₂	124-38-9	

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3941, Classification of fires

ISO 5660-1, Reaction-to-fire tests — Heat release, smoke production and mass loss rate — Part 1: Heat release rate (cone calorimeter method)

ISO 14520-2, Gaseous fire-extinguishing systems — Physical properties and system design — Part 2: CF₃I extinguishant

ISO 14520-5, Gaseous fire-extinguishing systems — Physical properties and system design — Part 5: FK-5-1-12 extinguishant

ISO 14520-6, Gaseous fire-extinguishing systems — Physical properties and system design — Part 6: HCFC Blend A extinguishant

ISO 14520-8, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 8: HFC 125 extinguishant*

ISO 14520-9, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 9: HFC 227ea extinguishant*

ISO 14520-10, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 10: HFC 23 extinguishant*

ISO 14520-11, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 11: HFC 236fa extinguishant*

ISO 14520-12, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 12: IG-01 extinguishant*

ISO 14520-13, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 13: IG-100 extinguishant*

ISO 14520-14, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 14: IG-55 extinguishant*

ISO 14520-15, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 15: IG-541 extinguishant*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE For the purposes of this document, the term "bar" shall be taken as "gauge", unless otherwise indicated. Concentrations or quantities expressed in percentages (%) shall be taken as by volume, unless otherwise indicated.

3.1

approved

acceptable to a relevant authority (see 3.2)

NOTE In determining the acceptability of installations or procedures, equipment or materials, the authority can base acceptance on compliance with the appropriate standards.

3.2

authority

organization, office or individual responsible for approving equipment, installations or procedures

3.3

automatic/manual switch

means of converting the system from automatic to manual actuation

NOTE This can be in the form of a manual switch on the control panel or other units, or a personnel door interlock. In all cases, this changes the actuation mode of the system from automatic and manual to manual only or vice versa.

3.4

extinguishant

electrically non-conducting gaseous fire extinguishing agent that, upon evaporation, does not leave a residue (see Table 1)

NOTE The terms "extinguishant" and "agent" are used interchangeably throughout this Standard.