

# DRAFT INTERNATIONAL STANDARD

## ISO/DIS 14520-6

ISO/TC 21/SC 8

Secretariat: SA

Voting begins on:  
2014-11-24

Voting terminates on:  
2015-02-24

---

---

## Gaseous fire-extinguishing systems — Physical properties and system design —

### Part 6: HCFC Blend A extinguishant

*Systèmes d'extinction d'incendie utilisant des agents gazeux — Propriétés physiques et conception des systèmes —*

*Partie 6: Agent extincteur HCFC, mélange A*

ICS: 13.220.10

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)  
Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/74a279f0-b68c-4dad-8ff8-98f574445334/iso-14520-6-2016>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.



Reference number  
ISO/DIS 14520-6:2014(E)

© ISO 2014

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)  
Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/74a279f0-b68c-4dad-8ff8-98f574445334/iso-14520-6-2016>

### Copyright notice

This ISO document is a Draft International Standard and is copyright-protected by ISO. Except as permitted under the applicable laws of the user's country, neither this ISO draft nor any extract from it may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, photocopying, recording or otherwise, without prior written permission being secured.

Requests for permission to reproduce should be addressed to either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Reproduction may be subject to royalty payments or a licensing agreement.

Violators may be prosecuted.

## Contents

Page

|                                       |    |
|---------------------------------------|----|
| Foreword .....                        | iv |
| 1 Scope .....                         | 1  |
| 2 Normative reference .....           | 1  |
| 3 Terms and definitions .....         | 1  |
| 4 Characteristics and uses .....      | 1  |
| 4.1 General .....                     | 1  |
| 4.2 Use of HCFC Blend A systems ..... | 2  |
| 5 Safety of personnel .....           | 3  |
| 6 System design .....                 | 3  |
| 6.1 Fill density .....                | 3  |
| 6.2 Superpressurization .....         | 3  |
| 6.3 Extinguishant quantity .....      | 3  |
| 7.0 Environmental properties .....    | 7  |

**iTeh STANDARD PREVIEW**  
 (standards.iteh.ai)

Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/74427918-b68c-4dad-8ff8-98f574445334/iso-14520-6-2016>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 14520-6 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media fire fighting systems using gas*.

This second/third/... edition cancels and replaces the first/second/... edition (), [clause(s) / subclause(s) / table(s) / figure(s) / annex(es)] of which [has / have] been technically revised.

ISO 14520 consists of the following parts, under the general title *Gaseous fire-extinguishing systems — Physical properties and system design*:

- Part 1: General requirements
- Part 2: CF<sub>3</sub>I extinguishant
- Part 3: Withdrawn
- Part 4: Withdrawn
- Part 5: FK-5-1-12 extinguishant
- Part 6: HCFC Blend A extinguishant
- Part 7: Withdrawn
- Part 8: HFC 125 extinguishant
- Part 9: HFC 227ea extinguishant
- Part 10: HFC 23 extinguishant
- Part 11: HFC 236fa extinguishant
- Part 12: IG-01 extinguishant
- Part 13: IG-100 extinguishant
- Part 14: IG-55 extinguishant
- Part 15: IG-541 extinguishant

# Gaseous fire-extinguishing systems — Physical properties and system design — Part 6: HCFC Blend A extinguishant

## 1 Scope

1.1 This part of ISO 14520 contains specific requirements for gaseous fire-extinguishing systems, with respect to the HCFC Blend A extinguishant. It includes details of physical properties, specification, usage and safety aspects.

1.2 This part of ISO 14520 covers systems operating at nominal pressures of 25 bar or 42 bar, superpressurized with nitrogen. This does not preclude the use of other systems.

## 2 Normative reference

The following normative document contains provisions which, through reference in this text, constitute provisions of this part of ISO 14520. For dated references, subsequent amendments to, or revisions of, this publication do not apply. However, parties to agreements based on this part of ISO 14520 are encouraged to investigate the possibility of applying the most recent edition of the normative document indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 14520-1, *Gaseous fire-extinguishing systems—Physical properties and system design—Part 1: General requirements*.

## 3 Terms and definitions

For the purposes of this part of ISO 14520, the terms and definitions given in ISO 14520-1 apply.

## 4 Characteristics and uses

### 4.1 General

Extinguishant HCFC Blend A shall comply with the specification shown in Table 1, and its components with the tolerances specified in Table 2.

HCFC Blend A is a colourless, electrically non-conductive gas with a citrus-like odour, with a density approximately three times that of air.

The physical properties are shown in Table 3.

HCFC Blend A extinguishes fires mainly by physical means but also by some chemical means.

Table 1 — Specification for HCFC Blend A

| Property                     | Requirement                                 |
|------------------------------|---|
| Purity                       | 99,6 % by mass, min.                        |
| Acidity                      | $3 \times 10^{-4}$ % by mass (3ppm), max.   |
| Water content                | $10 \times 10^{-4}$ % by mass (10ppm), max. |
| Non-volatile residue         | 0,01 % by mass, max.                        |
| Suspended matter or sediment | None visible                                |

Table 2 — HCFC Blend A component specification

| Component                    | Tolerance (by mass) |
|------------------------------|---------------------|
| $\text{CHCl}_2\text{CF}_3$   | $\pm 0,5$ %         |
| $\text{CHClCF}_2$            | $\pm 0,8$ %         |
| $\text{CHClFCF}_3$           | $\pm 0,9$ %         |
| $\text{C}_{10}\text{H}_{16}$ | $\pm 0,5$ %         |

Table 3 — Physical properties of HCFC Blend A

| Property   | Units                        | Value             |
|--|------------------------------|-------------------|
| Molecular mass   | —                            | 92,9              |
| Boiling point at 1,013 bar (absolute)                        | °C                           | -38,3             |
| Freezing point   | °C                           | < -107,2          |
| Critical temperature   | °C                           | 125               |
| Critical pressure  | bar abs                      | 66,50             |
| Critical volume  | $\text{cm}^3/\text{mol}$     | 170               |
| Critical density   | $\text{kg}/\text{m}^3$       | 580               |
| Vapour pressure 20 °C  | bar abs                      | 8,25              |
| Liquid density 20 °C   | $\text{kg}/\text{m}^3$       | 1 200             |
| Saturated vapour density 20 °C                               | $\text{kg}/\text{m}^3$       | 31                |
| Specific volume of superheated vapour at 1,013 bar and 20 °C | $\text{m}^3/\text{kg}$       | 0,259             |
| Chemical formulae  | <b>Component</b>             | <b>Percentage</b> |
|  | $\text{CHCl}_2\text{CF}_3$   | 4,75 %            |
|  | $\text{CHClCF}_2$            | 82 %              |
|  | $\text{CHClFCF}_3$           | 9,5 %             |
|  | $\text{C}_{10}\text{H}_{16}$ | 3,75 %            |

## 4.2 Use of HCFC Blend A systems

HCFC Blend A total flooding systems may be used for extinguishing fires of all classes within the limits specified in clause 4 of ISO 14520-1.

The extinguishant requirements per volume of protected space are shown in Table 4 for various levels of concentration. These are based on methods shown in 7.6 of ISO 14520-1.

The extinguishing concentrations and design concentrations for heptane and surface class A hazards are shown in Table 5. Inerting concentrations are shown in Table 6.

## 5 Safety of personnel

Any hazard to personnel created by the discharge of HCFC Blend shall be considered in the design of the system.

Potential hazards can arise from the following:

- a) the extinguishant itself;
- b) the combustion products of the fire; and
- c) breakdown products of the extinguishant resulting from exposure to fire.

When the design concentration exceeds the LOAEL, HCFC Blend A shall be used only for total flooding in normally unoccupied areas. For minimum safety requirements, see ISO 14520-1, clause 5.

Toxicological information for HCFC Blend A is shown in Table 7.

## 6 System design

### 6.1 Fill density

The fill density of the container shall not exceed the values given in Table 8 for 25 bar systems and Table 9 for 42 bar systems.

Exceeding the maximum fill density may result in the container becoming "liquid full", with the effect that an extremely high rise in pressure occurs with small increases in temperature, which could adversely affect the integrity of the container assembly.

The relationships between pressure and temperature are shown in Figures 1 and 2 for maximum fill density.

### 6.2 Superpressurization

Containers shall be superpressurized with nitrogen with a moisture content of not more than  $60 \times 10^{-4}$  % (60ppm) by mass to an equilibrium pressure of  $(25 \pm 1,25)$  bar and  $(42 \pm 1,25)$  bar at a temperature of 20 °C.

### 6.3 Extinguishant quantity

The quantity of extinguishant shall be the minimum required to achieve the design concentration within the hazard volume at the minimum expected temperature, determined using Table 4 and the method specified in 7.6 of ISO 14520-1.

The design concentrations shall be that specified for relevant hazards shown in Table 5. This includes at least a 1,3 safety factor on the extinguishing concentration.

Consideration should be given to increasing this for particular hazards, and seeking advice from the relevant authority.

Table 4 — HCFC Blend A total flooding quantity

| Temperature<br><i>T</i><br>°C | Specific vapour volume<br><i>S</i><br>m <sup>3</sup> /kg | HCFC Blend A mass requirements per unit volume of protected space, <i>m/V</i> (kg/m <sup>3</sup> ) |       |       |       |       |       |       |       |       |       |
|-------------------------------|--|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|                               |  | Design concentration (by volume)   |       |       |       |       |       |       |       |       |       |
|                               |  | 7 %  | 8 %   | 9 %   | 10 %  | 11 %  | 12 %  | 13 %  | 14 %  | 15 %  | 16 %  |
| -35                           | 0,210  | 0,358  | 0,413 | 0,470 | 0,528 | 0,588 | 0,648 | 0,710 | 0,774 | 0,839 | 0,906 |
| -30                           | 0,215  | 0,351  | 0,405 | 0,461 | 0,517 | 0,576 | 0,635 | 0,696 | 0,758 | 0,822 | 0,887 |
| -25                           | 0,219  | 0,343  | 0,397 | 0,451 | 0,507 | 0,564 | 0,622 | 0,682 | 0,743 | 0,805 | 0,869 |
| -20                           | 0,224  | 0,337  | 0,389 | 0,442 | 0,497 | 0,553 | 0,610 | 0,668 | 0,728 | 0,790 | 0,852 |
| -15                           | 0,228  | 0,330  | 0,381 | 0,434 | 0,487 | 0,542 | 0,598 | 0,655 | 0,714 | 0,774 | 0,835 |
| -10                           | 0,232  | 0,324  | 0,374 | 0,426 | 0,478 | 0,532 | 0,587 | 0,643 | 0,700 | 0,760 | 0,819 |
| -5                            | 0,237  | 0,318  | 0,367 | 0,418 | 0,469 | 0,522 | 0,576 | 0,631 | 0,687 | 0,745 | 0,804 |
| 0                             | 0,241  | 0,312  | 0,360 | 0,410 | 0,461 | 0,512 | 0,565 | 0,619 | 0,675 | 0,731 | 0,789 |
| 5                             | 0,246  | 0,306  | 0,354 | 0,403 | 0,452 | 0,503 | 0,555 | 0,608 | 0,663 | 0,718 | 0,775 |
| 10                            | 0,250  | 0,301  | 0,348 | 0,396 | 0,444 | 0,494 | 0,545 | 0,598 | 0,651 | 0,706 | 0,762 |
| 15                            | 0,254  | 0,296  | 0,342 | 0,389 | 0,437 | 0,486 | 0,536 | 0,587 | 0,640 | 0,693 | 0,748 |
| 20                            | 0,259  | 0,291  | 0,336 | 0,382 | 0,429 | 0,477 | 0,527 | 0,577 | 0,629 | 0,682 | 0,736 |
| 25                            | 0,263  | 0,286  | 0,330 | 0,376 | 0,422 | 0,469 | 0,518 | 0,568 | 0,618 | 0,670 | 0,723 |
| 30                            | 0,268  | 0,281  | 0,325 | 0,369 | 0,415 | 0,462 | 0,509 | 0,558 | 0,608 | 0,659 | 0,711 |
| 35                            | 0,272  | 0,277  | 0,320 | 0,363 | 0,408 | 0,454 | 0,501 | 0,549 | 0,598 | 0,648 | 0,700 |
| 40                            | 0,277  | 0,272  | 0,314 | 0,358 | 0,402 | 0,447 | 0,493 | 0,540 | 0,589 | 0,638 | 0,689 |
| 45                            | 0,281  | 0,268  | 0,310 | 0,352 | 0,395 | 0,440 | 0,485 | 0,532 | 0,579 | 0,628 | 0,678 |
| 50                            | 0,285  | 0,264  | 0,305 | 0,347 | 0,389 | 0,433 | 0,478 | 0,524 | 0,570 | 0,618 | 0,667 |
| 55                            | 0,290  | 0,260  | 0,300 | 0,341 | 0,383 | 0,427 | 0,471 | 0,516 | 0,562 | 0,609 | 0,657 |
| 60                            | 0,294  | 0,256  | 0,296 | 0,336 | 0,378 | 0,420 | 0,463 | 0,508 | 0,553 | 0,600 | 0,647 |
| 65                            | 0,299  | 0,252  | 0,291 | 0,331 | 0,372 | 0,414 | 0,457 | 0,500 | 0,545 | 0,591 | 0,638 |
| 70                            | 0,303  | 0,248  | 0,287 | 0,326 | 0,367 | 0,408 | 0,450 | 0,593 | 0,537 | 0,582 | 0,628 |
| 75                            | 0,307  | 0,245  | 0,283 | 0,322 | 0,361 | 0,402 | 0,444 | 0,486 | 0,529 | 0,573 | 0,620 |
| 80                            | 0,312  | 0,241  | 0,279 | 0,317 | 0,356 | 0,396 | 0,437 | 0,479 | 0,522 | 0,566 | 0,611 |
| 85                            | 0,317  | 0,238  | 0,275 | 0,313 | 0,351 | 0,391 | 0,432 | 0,472 | 0,515 | 0,558 | 0,602 |
| 90                            | 0,321  | 0,235  | 0,271 | 0,308 | 0,346 | 0,385 | 0,425 | 0,466 | 0,508 | 0,550 | 0,594 |
| 95                            | 0,325  | 0,232  | 0,267 | 0,304 | 0,342 | 0,380 | 0,419 | 0,460 | 0,501 | 0,543 | 0,586 |

NOTE This information refers only to the product HCFC Blend A, and does not represent any other products containing dichlorotrifluoroethane, chlorodifluoromethane, chlorotetrafluoroethane or isopropenyl-1-methylcyclohexane as components.

Symbols:

*m/V* is the agent mass requirements (kg/m<sup>3</sup>); i.e. mass, *m*, in kilograms of agent required per cubic metre of protected volume *V* to produce the indicated concentration at the temperature specified;

*V* is the net volume of hazard (m<sup>3</sup>); i.e the enclosed volume minus the fixed structures impervious to extinguishant

$$m = \left( \frac{c}{100 - c} \right) \frac{V}{S}$$

*T* is the temperature (°C); i.e. the design temperature in the hazard area;

*S* is the specific volume (m<sup>3</sup>/kg); the specific volume of superheated HCFC Blend A vapour at a pressure of 1,013 bar may be approximated by the formula:

$$S = k_1 + k_2 T$$

where

$$k_1 = 0,241 \text{ 3}$$

$$k_2 = 0,000 \text{ 88}$$

*c* is the concentration (%); i.e. the volumetric concentration of HCFC Blend A in air at the temperature indicated, and a pressure of 1,013 bar absolute.



Table 5 — HCFC Blend A reference extinguishing and design concentrations

| Fuel  | Extinguishment<br>% by volume | Minimum design<br>% by volume |
|---|-------------------------------|-------------------------------|
| <b>Class B</b>  |                               |                               |
| Heptane (cup burner)  | 10,0                          | 13,0                          |
| Heptane (room test)   | 9,9                           |                               |
| <b>Surface Class A</b>  |                               | See Note 3                    |
| Wood Crib   | 6,0                           |                               |
| PMMA  | -                             |                               |
| PP  | -                             |                               |
| ABS   | -                             |                               |
| <b>Higher Hazard Class A</b>  | See Note 4                    | 12,4                          |
| <p>NOTE 1 The extinguishment values for the Class B and the Surface Class A fuels are determined by testing in accordance with Annexes B and C of ISO 14520-1.</p> <p>NOTE 2 The minimum design concentration for the Class B fuel is the higher value of the heptane cup burner or room test heptane extinguishment concentration multiplied by 1,3.</p> <p>NOTE 3 The minimum design concentration for Surface Class A fuel is the highest value of the wood crib, PMMA, PP or ABS extinguishment concentrations multiplied by 1,3. In the absence of any of the 4 extinguishment values, the minimum design concentration for Surface Class A shall be that of Higher Hazard Class A.</p> <p>NOTE 4 The minimum design concentration for Higher Hazard Class A fuels shall be the higher of the Surface Class A or 95% of the Class B minimum design concentration.</p> <p>NOTE 5 See 7.5.1.3 of ISO 14520-1 for guidance on Class A fuels.</p> <p>NOTE 6 The extinguishing and design concentrations for room-scale test fires are for informational purposes only. Lower and higher extinguishing concentrations than those shown for room-scale test fires may be achieved and allowed when validated by test reports from internationally recognized laboratories.</p> |                               |                               |

Table 6 — HCFC Blend A inerting and design concentrations

| Fuel  | Inertion<br>% by volume | Minimum design<br>% by volume |
|---|-------------------------|-------------------------------|
| Methane   | 18,6                    | 20,5                          |
| Propane   | 18,3                    | 20,1                          |
| 1,1-Difluoroethane (HFC-152a)   | 13,6                    | 15,0                          |
| Difluoromethane (HFC-32)  | 8,6                     | 9,5                           |
| Isobutane   | 18,4                    | 20,2                          |
| <p>NOTE Inerting concentrations were derived in accordance with the requirements of ISO/14520-1, Section 7.5.2 and Annex D.</p> |                         |                               |