
**Naprave za gašenje s plinom - Fizikalne lastnosti in projektiranje - 11. del: Gasilo
HFC 236fa**

Gaseous fire-extinguishing systems -- Physical properties and system design -- Part 11:
HFC 236fa extinguishant

iTeh STANDARD PREVIEW

(standards.iteh.ai)
Systèmes d'extinction d'incendie utilisant des agents gazeux -- Propriétés physiques et
conception des systèmes -- Partie 11: Agent extincteur HFC 236fa

[SIST ISO 14520-11:2018](https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-6126c6cd7d6e/sist-iso-14520-11-2018)

Ta slovenski standard je istoveten z:

ISO 14520-11:2016

ICS:

13.220.10

Gašenje požara

Fire-fighting

SIST ISO 14520-11:2018

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 14520-11:2018

<https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018>

INTERNATIONAL STANDARD

ISO
14520-11

Third edition
2016-10-01

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 11: HFC 236fa extinguishant

iTeh STANDARD PREVIEW
(standards.iteh.ai)
*Systèmes d'extinction d'incendie utilisant des agents gazeux —
Propriétés physiques et conception des systèmes —
Partie 11: Agent extincteur HFC 236fa*

SIST ISO 14520-11:2018

<https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018>



Reference number
ISO 14520-11:2016(E)

© ISO 2016

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 14520-11:2018

<https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Characteristics and uses	1
4.1 General.....	1
4.2 Use of HFC 236fa systems.....	2
5 Safety of personnel	5
6 System design	6
6.1 Fill density.....	6
6.2 Superpressurization.....	7
6.3 Extinguishant quantity.....	7
7 Environmental properties	8

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 14520-11:2018](https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018)

<https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018>

ISO 14520-11:2016(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media and fire fighting systems using gas*.

This third edition cancels and replaces the second edition (ISO 14520-11:2005), which has been technically revised with the following changes:

- in [Table 5](#), minimum design data was corrected from previous edition; all but values for ethanol and methanol were incorrect;
- added [Clause 7](#).

A list of all parts in the ISO 14520 series can be found on the ISO website.

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 11: HFC 236fa extinguishant

1 Scope

This document contains specific requirements for gaseous fire-extinguishing systems, with respect to the HFC 236fa extinguishant. It includes details of physical properties, specification, usage and safety aspects.

This document covers systems operating at nominal pressures of 25 bar and 42 bar superpressurized with nitrogen. This does not preclude the use of other systems.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14520-1:2015, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 1: General requirements*.

SIST ISO 14520-11:2018

<https://standards.iteh.ai/catalog/standards/sist/971475e5-fa47-44f4-91fc-b12be8ed7d6e/sist-iso-14520-11-2018>

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 14520-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Characteristics and uses

4.1 General

Extinguishant HFC 236fa shall comply with the specification shown in [Table 1](#).

HFC 236fa is a colourless, almost odourless, electrically non-conductive gas with a density approximately five times that of air.

The physical properties are shown in [Table 2](#).

HFC 236fa extinguishes fires mainly by physical means, but also by some chemical means.

Table 1 — Specification for HFC 236fa

Property	Requirement
Purity	99,6% by mass, min.
Acidity	3×10^{-6} by mass, max.
Water content	10×10^{-6} by mass, max.
Non-volatile residue	0,01 % by mass, max.
Suspended matter or sediment	None visible

Table 2 — Physical properties of HFC 236fa

Property	Units	Value
Molecular mass	—	152
Boiling point at 1,013 bar (absolute)	°C	-1,4
Freezing point	°C	-103
Critical temperature	°C	124,9
Critical pressure	bar abs	32,00
Critical volume	cm ³ /mol	274,0
Critical density	kg/m ³	551,3
Vapour pressure 20 °C	bar abs	2,296
Liquid density 20 °C	kg/m ³	1 377
Saturated vapour density 20 °C	kg/m ³	15,58
Specific volume of superheated vapour at 1,013 bar and 20 °C	m ³ /kg	0,1529
Chemical formula	CF ₃ CH ₂ CF ₃	
Chemical name	Hexafluoropropane	

4.2 Use of HFC 236fa systems

HFC 236fa total flooding systems may be used for extinguishing fires of all classes within the limits specified in ISO 14520-1:2015, Clause 4.

The extinguishant requirements per volume of protected space are shown in [Table 3](#) for various levels of concentration. These are based on methods shown in ISO 14520-1:2015, 7.6.

The extinguishing concentrations and design concentrations for various types of hazard are shown in [Table 4](#). Concentrations for other fuels are shown in [Table 5](#).

Table 3 — HFC 236fa total flooding quantity

Temperature T °C	Specific vapour volume S m ³ /kg	HFC 236fa mass requirements per unit volume of protected space, m/V (kg/m ³)										
		Design concentration (by volume)										
		5 %	6 %	7 %	8 %	9 %	10 %	11 %	12 %	13 %	14 %	15 %
0	0,141 3	0,372 5	0,451 7	0,532 7	0,615 4	0,699 9	0,786 3	0,874 7	0,965 1	1,057 5	1,152 1	1,248 9
5	0,144 2	0,365 0	0,442 7	0,522 0	0,603 1	0,686 0	0,770 6	0,857 2	0,945 8	1,036 4	1,129 1	1,224 0
10	0,147 1	0,357 9	0,434 0	0,511 8	0,591 3	0,672 5	0,755 5	0,840 4	0,927 3	1,016 1	1,107 0	1,200 0
15	0,149 9	0,351 0	0,425 7	0,502 0	0,579 9	0,659 6	0,741 0	0,824 3	0,909 5	0,996 6	1,085 7	1,176 9
20	0,152 8	0,344 4	0,417 7	0,492 5	0,569 0	0,647 2	0,727 1	0,808 8	0,892 3	0,977 8	1,065 2	1,154 8
25	0,155 7	0,338 0	0,410 0	0,483 4	0,558 5	0,635 2	0,713 6	0,793 8	0,875 8	0,959 7	1,045 5	1,133 4
30	0,158 6	0,331 9	0,402 5	0,474 6	0,548 3	0,623 7	0,700 7	0,779 4	0,859 9	0,942 3	1,026 6	1,112 8
35	0,161 5	0,326 0	0,395 3	0,466 2	0,538 6	0,612 5	0,688 2	0,765 5	0,844 6	0,925 5	1,008 2	1,093 0
40	0,164 3	0,320 3	0,388 4	0,458 0	0,529 1	0,601 8	0,676 1	0,752 1	0,829 8	0,909 2	0,990 6	1,073 8
45	0,167 2	0,314 7	0,381 7	0,450 1	0,520 0	0,591 4	0,664 5	0,739 1	0,815 5	0,893 6	0,973 5	1,055 3
50	0,170 1	0,309 4	0,375 2	0,442 5	0,511 2	0,581 4	0,653 2	0,726 6	0,801 7	0,878 5	0,957 0	1,037 5
55	0,173 0	0,304 3	0,369 0	0,435 1	0,502 7	0,571 7	0,642 3	0,714 5	0,788 3	0,863 8	0,941 1	1,020 2
60	0,175 9	0,299 3	0,363 0	0,428 0	0,494 5	0,562 4	0,631 8	0,702 8	0,775 4	0,849 7	0,925 7	1,003 5

This information refers only to the product HFC-236fa and may not represent any other products containing 1,1,1,3,3,3-hexafluoropropane as a component.

Symbols:

m/V is the agent mass requirements (kg/m³); i.e. mass, m , in kilograms of agent required per cubic metre of protected volume, V , to produce the indicated concentration at the temperature specified;

V is the net volume of hazard (m³); i.e the enclosed volume minus the fixed structures impervious to extinguishant

$$m = \left(\frac{c}{100 - c} \right) \frac{V}{S}$$

T is the temperature (°C); i.e. the design temperature in the hazard area;

S is the specific volume (m³/kg); the specific volume of superheated HFC 236fa vapour at a pressure of 1,013 bar may be approximated by the formula

$$S = k_1 + k_2 T$$

where

$$k_1 = 0,141\ 3$$

$$k_2 = 0,000\ 6$$

c is the concentration (%); i.e. the volumetric concentration of HFC 236fa in air at the temperature indicated and a pressure of 1,013 bar absolute.