
Vplivi električnega toka na ljudi in živali – 2. del: Posebnosti

Effects of current on human beings and livestock - Part 2: Special aspects

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z:

[SIST IEC 60479-2:2020](https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-3f4fb24bcf96/sist-iec-60479-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-3f4fb24bcf96/sist-iec-60479-2-2020>

ICS:

13.200	Preprečevanje nesreč in katastrof	Accident and disaster control
29.020	Elektrotehnika na splošno	Electrical engineering in general

SIST IEC 60479-2:2020

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST IEC 60479-2:2020

<https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-3f4fb24bcf96/sist-iec-60479-2-2020>



IEC 60479-2

Edition 1.0 2019-05

INTERNATIONAL STANDARD



BASIC SAFETY PUBLICATION

**Effects of current on human beings and livestock –
Part 2: Special aspects**

STANDARD PREVIEW
(standards.iteh.ai)

SIST IEC 60479-2:2020

<https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-3f4fb24bcf96/sist-iec-60479-2-2020>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 13.200; 29.020

ISBN 978-2-8322-6689-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	5
INTRODUCTION	7
1 Scope	8
2 Normative references	8
3 Terms and definitions	9
4 Effects of alternating currents with frequencies above 100 Hz	11
4.1 General	11
4.2 Effects of alternating current in the frequency range above 100 Hz up to and including 1 000 Hz	12
4.2.1 Threshold of perception	12
4.2.2 Threshold of let-go	12
4.2.3 Threshold of ventricular fibrillation	13
4.3 Effects of alternating current in the frequency range above 1 000 Hz up to and including 10 000 Hz	14
4.3.1 Threshold of perception	14
4.3.2 Threshold of let-go	14
4.3.3 Threshold of ventricular fibrillation	15
4.4 Effects of alternating current in the frequency range above 10 000 Hz	15
4.4.1 General	15
4.4.2 Threshold of perception	15
4.4.3 Threshold of let-go	15
4.4.4 Threshold of ventricular fibrillation	15
4.4.5 Other effects	16
5 Effects of special waveforms of current	16
5.1 General	16
5.2 Equivalent magnitude, frequency and threshold	16
5.3 Effects of alternating current with DC components	17
5.3.1 Waveforms and frequencies and current thresholds	17
5.3.2 Threshold of startle reaction	18
5.3.3 Threshold of let-go	19
5.3.4 Threshold of ventricular fibrillation	20
6 Effects of alternating current with phase control	24
6.1 Waveforms and frequencies and current thresholds	24
6.2 Threshold of startle reaction and threshold of let-go	25
6.3 Threshold of ventricular fibrillation	25
6.3.1 General	25
6.3.2 Symmetrical control	26
6.3.3 Asymmetrical control	26
7 Effects of alternating current with multicyle control	26
7.1 Waveforms and frequencies	26
7.2 Threshold of startle reaction and threshold of let-go	27
7.3 Threshold of ventricular fibrillation	27
7.3.1 General	27
7.3.2 Shock durations longer than 1,5 times the period of the cardiac cycle	28
7.3.3 Shock durations less than 0,75 times the period of the cardiac cycle	28

8	Estimation of the equivalent current threshold for mixed frequencies	28
8.1	Threshold of perception and let-go	28
8.2	Threshold of ventricular fibrillation	29
9	Effects of current pulse bursts and random complex irregular waveforms	29
9.1	Ventricular fibrillation threshold of multiple pulses of current separated by 300 ms or more	29
9.2	Ventricular fibrillation threshold of multiple pulses of current separated by less than 300 ms	29
9.2.1	General	29
9.2.2	Examples	30
9.2.3	Random complex irregular waveforms	32
10	Effects of electric current through the immersed human body	34
10.1	General	34
10.2	Resistivity of water solutions and of the human body	34
10.3	Conducted current through immersed body	36
10.4	Physiological effects of current through the immersed body	37
10.5	Threshold values of current	38
10.6	Intrinsically “safe” voltage values	38
11	Effects of unidirectional single impulse currents of short duration	38
11.1	General	38
11.2	Effects of unidirectional impulse currents of short duration	39
11.2.1	Waveforms	39
11.2.2	Determination of specific fibrillating energy F_e	40
11.3	Threshold of perception and threshold of pain for capacitor discharge	41
11.4	Threshold of ventricular fibrillation	43
11.4.1	General	43
11.4.2	Examples	44
Annex A	(informative) Random complex irregular waveform analysis	47
A.1	General	47
A.2	Formal theoretical statement of the method	47
A.3	Demonstration of the calculation	48
A.3.1	General	48
A.3.2	Choice of justified current	50
A.3.3	Choice of sampling step size	50
A.4	Examples 1 and 2	51
Bibliography	54
Figure 1	– Variation of the threshold of perception within the frequency range 50/60 Hz to 1 000 Hz	12
Figure 2	– Variation of the threshold of let-go within the frequency range 50/60 Hz to 1 000 Hz	13
Figure 3	– Variation of the threshold of ventricular fibrillation within the frequency range 50/60 Hz to 1 000 Hz, shock durations longer than one heart period and longitudinal current paths through the trunk of the body	13
Figure 4	– Variation of the threshold of perception within the frequency range 1 000 Hz to 10 000 Hz	14
Figure 5	– Variation of the threshold of let-go within the frequency range 1 000 Hz to 10 000 Hz	14

Figure 6 – Variation of the threshold of ventricular fibrillation for continuous sinusoidal current (1 000 Hz to 150 kHz)	16
Figure 7 – Waveforms of currents	18
Figure 8 – Let-go thresholds for men, women and children	19
Figure 9 – 99,5-percentile let-go threshold for combinations of 50/60 Hz sinusoidal alternating current and direct current	20
Figure 10 – Composite alternating and direct current with equivalent likelihood of ventricular fibrillation.....	22
Figure 11 – Waveforms of rectified alternating currents	23
Figure 12 – Waveforms of alternating currents with phase control.....	25
Figure 13 – Waveforms of alternating currents calculated with multicycle control factor	27
Figure 14 – Threshold of ventricular fibrillation (average value) for alternating current with multicycle control for various degrees of controls (results of experiments with young pigs).....	28
Figure 15 – Series of four rectangular pulses of unidirectional current	31
Figure 16 – Series of four rectangular pulses of unidirectional current	31
Figure 17 – Series of four rectangular pulses of unidirectional current	32
Figure 18 – Example of current versus elapsed time over a contaminated insulator	33
Figure 19 – PC plotted on the AC time current curves (IEC 60479-1:2018, Figure 20).....	34
Figure 20 – Forms of current for rectangular impulses, sinusoidal impulses and for capacitor discharges	40
Figure 21 – Rectangular impulse, sinusoidal impulse and capacitor discharge having the same specific fibrillating energy and the same shock duration.....	41
Figure 22 – Threshold of perception and threshold of pain for the current resulting from the discharge of a capacitor (dry hands, large contact area)	42
Figure 23 – Probability of fibrillation risks for current flowing in the path left hand to feet	44
Figure A.1 – Definition of a segment of a random complex waveform	47
Figure A.2 – Definition of a duration within a sample.....	47
Figure A.3 – PC for demonstration example of the random complex waveform method plotted against time-current curves for RMS AC	50
Figure A.4 – Random complex waveform typical of those used in Example 1	51
Figure A.5 – Random complex waveform typical of those used in Example 2	52
Figure A.6 – PC for Examples 1 and 2 of the random complex waveform method plotted against time-current curves for RMS AC.....	53
Table 1 – Estimate for ventricular fibrillation threshold after each pulse of current in a series of pulses each of which excited the heart tissue in such a manner as to trigger ventricular responses.....	30
Table 2 – Resistivity of water solutions [24], [25]	35
Table 3 – Resistivity of human body tissues.....	36
Table 4 – Relative interaction between the resistivity of water solution and the impedance characteristic of the electrical source	37
Table 5 – Effects of shocks.....	45
Table 6 – Effects of shocks.....	46

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –**Part 2: Special aspects****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60479-2 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This first edition cancels and replaces IEC TS 60479-2:2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TS 60479-2:2017:

- a) change in status from Technical Specification to International Standard.

It has the status of a basic safety publication in accordance with IEC Guide 104.

The text of this International Standard is based on the following documents:

CDV	Report on voting
64/2300/CDV	64/2362/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60479 series, published under the general title *Effects of current on human beings and livestock*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW
(standards.iten.ai)

A bilingual version of this publication may be issued at a later date.

SIST IEC 60479-2:2020

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

In order to avoid errors in the interpretation of this document, it should be emphasized that the data given herein is mainly based on experiments with animals as well as on information available from clinical observations. Only a few experiments with shock currents of short duration have been carried out on living human beings.

The effects of current passing through the human body for

- alternating sinusoidal current with DC components,
- alternating sinusoidal current with phase control,
- alternating sinusoidal current with multicycle control,
- equivalent current threshold for mixed frequencies,
- current pulse bursts and random complex irregular waveforms,
- electric current through the immersed human body, and
- unidirectional single impulse currents of short duration

are described.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST IEC 60479-2:2020

<https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-3f4fb24bcf96/sist-iec-60479-2-2020>

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –

Part 2: Special aspects

1 Scope

This part of IEC 60479 describes the effects on the human body when a sinusoidal alternating current in the frequency range above 100 Hz passes through it.

The effects of current passing through the human body for:

- alternating sinusoidal current with DC components,
- alternating sinusoidal current with phase control, and
- alternating sinusoidal current with multicycle control

are given but are only deemed applicable for alternating current frequencies from 15 Hz up to 100 Hz.

Means of extending the frequency of applicability of pure sinusoids to a frequency of 150 kHz are given, supplementing the data in IEC 60479-1.

Means of examining random complex irregular waveforms are given.

This document describes the effects of current passing through the human body in the form of single and multiple successive unidirectional rectangular impulses, sinusoidal impulses and impulses resulting from capacitor discharges.

The values specified are deemed to be applicable for impulse durations from 0,1 ms up to and including 10 ms.

This document only considers conducted current resulting from the direct application of a source of current to the body, as does IEC 60479-1. It does not consider current induced within the body caused by its exposure to an external electromagnetic field.

This basic safety publication is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this basic safety publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60479-1:2018, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60990, *Methods of measurement of touch-current and protective conductor current*

IEC Guide 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO/IEC Guide 51, *Safety aspects – Guidelines for their inclusion in standards*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60479-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

frequency factor

F_f

ratio of the threshold current for the relevant physiological effects at the frequency f to the threshold current at 50/60 Hz.

Note 1 to entry: The frequency factor differs for perception, let-go and ventricular fibrillation.

3.2

phase control

process of varying the instant within the cycle at which current conduction in an electronic valve device or a valve arm begins

[SOURCE: IEC 60050-551:1998, 551-16-23]

3.3

phase control angle

current delay angle

time expressed in angular measure by which the starting instant of current conduction is delayed by phase control

[SOURCE: IEC 60050-551:1998, 551-16-32, modified — The term "phase control angle" has been added.]

3.4

multicycle control

process of varying the ratio of the number of cycles which include current conduction to the number of cycles in which no current conduction occurs

[SOURCE: IEC 60050-551:1998, 551-16-31]

3.5

multicycle control factor

p

ratio between the number of conducting cycles and the sum of conducting and non-conducting cycles in the case of multicycle control

SEE Figure 13.

[SOURCE: IEC 60050-551:1998, 551-16-37, modified — The symbol and reference to Figure 13 have been added.]

3.6

specific fibrillating energy

F_e
minimum $I^2 \cdot t$ value of a unidirectional impulse of short duration which under given conditions (current-path, heart-phase) causes ventricular fibrillation with a certain probability

Note 1 to entry: F_e is determined by the form of the impulse as the integral

$$\int_0^{t_i} i^2 dt$$

where t_i is defined in Figure 20 and Figure 21. F_e multiplied by the body resistance gives the energy dissipated in the human body during the impulse.

Note 2 to entry: F_e is expressed in Ws/Ω or A^2s .

3.7

specific fibrillating charge

F_q
minimum $I \cdot t$ value of unidirectional impulse of short duration which under given conditions (current-path, heart-phase) causes ventricular fibrillation with a certain probability

Note 1 to entry: F_q is determined by the form of the impulse as the integral

$$\int_0^{t_i} i dt$$

where t_i is defined in Figure 20 and Figure 21.

Note 2 to entry: F_q is expressed in C or As.
<https://standards.iteh.ai/catalog/standards/sist/fbcc73c0-b518-4b4b-b7a0-34fb24bc96/sist-iec-60479-2-2020>

3.8

time constant

time required for the amplitude of an exponentially decaying quantity to decrease to

$$\frac{1}{e} = 0,367\ 9$$

times an initial amplitude

[SOURCE: IEC 60050-801:1994, 801-21-45, modified — The definition has been revised.]

3.9

shock duration

t_i
<of a capacitor discharge> time interval from the beginning of the discharge to the time when the discharge current has fallen to 5 % of its peak value

Note 1 to entry: When the time constant of the capacitor discharge is given by T the shock duration of the capacitor discharge is equal to $3T$. During the shock duration of the capacitor discharge practically all the energy of the impulse is dissipated.

Note 2 to entry: See Figure 20 and Figure 21.

3.10

shock duration

t_i
<for complex asymptotic waveform> shortest duration of that part of the impulse that contains 95 % of the energy over the total impulse

3.11**threshold of perception**

minimum value for the charge of electricity, which, under given conditions, causes any sensation to the person through whom it is flowing

3.12**threshold of pain**

minimum value for the charge ($I \cdot t$) or specific energy ($I^2 \cdot t$) that can be applied as an impulse to a person holding a large electrode in the hand without causing pain

3.13**pain**

unpleasant experience such that it is not readily accepted a second time by the subject submitted to it

EXAMPLE: Electric shock above the threshold of pain described in 11.3, the sting of a bee or the burn of a cigarette.

4 Effects of alternating currents with frequencies above 100 Hz

NOTE Values for 50/60 Hz are given in IEC 60479-1. For frequencies up to 100 Hz the provisions of IEC 60479-1 are used.

4.1 General

Electric energy in the form of alternating current at frequencies higher than 50/60 Hz is increasingly used in modern electrical equipment, for example aircraft (400 Hz), power tools and electric welding (mostly up to 450 Hz), electrotherapy (using mostly 4 000 Hz to 5 000 Hz) and switching mode power supplies (20 kHz to 1 MHz).

Little experimental data is available for Clause 4, therefore the information given herein should be considered as provisional only but may be used for the evaluation of risks in the frequency ranges concerned (see Bibliography).

Recent experiments in government-funded projects are ongoing to exploit and investigate the effects of higher frequencies using the latest technologies and methods to justify existing extrapolation of the frequency factor for ventricular fibrillation (VF) threshold.

Attention is also drawn to the fact that the impedance of human skin decreases approximately inversely proportional to the frequency for touch voltages in the order of some tens of volts, so that the skin impedance at 500 Hz is only about one-tenth of the skin impedance at 50 Hz and may be neglected in many cases. This impedance of the human body at such frequencies is therefore reduced to its internal impedance Z_i (see IEC 60479-1).

NOTE Use of peak measurements: at current levels that produce physiological responses of perception, startle reaction and inability of let-go, the physiological response from non-sinusoidal and mixed-frequency periodic current is best indicated by the peak value of an output signal from measuring circuits containing a frequency-weighting network such as those described in IEC 60990.

These frequency-weighting networks attenuate the signal according to the frequency factors given in IEC 60479-1:2018, Clause 4 so that the output signal corresponds to a constant level of physiological response. Attenuation is provided for narrow impulses of current that would produce less physiological response because of the short duration of their peak value. The network output allows a fixed value to be read independently of waveshape or mix of frequencies to be provided for ease of determination of the leakage current and evaluation of the level of hazard present.

Comparable physiological effects are produced by non-sinusoidal and sinusoidal currents producing the same peak values by this measurement method.

A representative network can be found in IEC 60990 and in [16]¹.

4.2 Effects of alternating current in the frequency range above 100 Hz up to and including 1 000 Hz

4.2.1 Threshold of perception

For the threshold of perception, the frequency factor is given in Figure 1.




Figure 1 – Variation of the threshold of perception within the frequency range 50/60 Hz to 1 000 Hz

4.2.2 Threshold of let-go

For the threshold of let-go, the frequency factor is given in Figure 2.

¹ Numbers in square brackets refer to the Bibliography.




Figure 2 – Variation of the threshold of let-go within the frequency range 50/60 Hz to 1 000 Hz

4.2.3 Threshold of ventricular fibrillation

For shock durations longer than the cardiac cycle, the frequency factor for the threshold of fibrillation for longitudinal current paths through the trunk of the body is given in Figure 3.

For shock durations shorter than the cardiac cycle, no experimental data is available on the effects of frequency.




Figure 3 – Variation of the threshold of ventricular fibrillation within the frequency range 50/60 Hz to 1 000 Hz, shock durations longer than one heart period and longitudinal current paths through the trunk of the body