

SLOVENSKI STANDARD

SIST EN 60953-2:2001

01-marec-2001

Rules for steam turbine thermal acceptance tests - Part 2: Method B - Wide range of accuracy for various types and sizes of turbines

Rules for steam turbine thermal acceptance tests -- Part 2: Method B - Wide range of accuracy for various types and sizes of turbines

Regeln für wärmetechnische Abnahmemessung an Dampfturbinen -- Teil 2: Methode B - Weiter Genauigkeitsbereich für unterschiedliche Bauarten und Baugrößen von Dampfturbinen

Règles pour les essais thermiques de réception des turbines à vapeur -- Partie 2: Méthode B - Précision de divers degrés pour multiples modèles et tailles de turbines

Ta slovenski standard je istoveten z: EN 60953-2:1995

ICS:

27.040

Plinske in parne turbine.
Parni stroji

Gas and steam turbines.
Steam engines

SIST EN 60953-2:2001

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60953-2:2001

<https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-21d141959be7/sist-en-60953-2-2001>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60953-2

December 1995

ICS 27.040

Descriptors: Turbine, steam apparatus, thermal test, acceptance test, accuracy, measurement technology, thermal efficiency

English version

Rules for steam turbine thermal acceptance tests
Part 2: Method B
Wide range of accuracy for various types and sizes of turbines
(IEC 953-2:1990)

Règles pour les essais thermiques
de réception des turbines à vapeur
Partie 2: Méthode B
Précision de divers degrés pour
multiples modèles et tailles de turbines
(CEI 953-2:1990)

Regeln für wärmetechnische
Abnahmemessung an Dampfturbinen
Teil 2: Methode B
Weiter Genauigkeitsbereich für
unterschiedliche Bauarten und
Baugrößen von Dampfturbinen
(IEC 953-2:1990)

SIST EN 60953-2:2001

<https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-21d141959be7/sist-en-60953-2-2001>

This European Standard was approved by CENELEC on 1995-05-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of the International Standard IEC 953-2:1990, prepared by IEC TC 5, Steam turbines, was submitted to the formal vote and was approved by CENELEC as EN 60953-2 on 1995-05-15 without any modification.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 1996-07-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 1996-07-01

Annexes designated "normative" are part of the body of the standard.

Annexes designated "informative" are given for information only.

In this standard, appendices B, F, G and annex ZA are normative and appendices A, C, D and E are informative.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 953-2:1990 was approved by CENELEC as a European Standard without any modification.

SIST EN 60953-2:2001

<https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-21d141959be7/sist-en-60953-2-2001>

Annex ZA (normative)

Normative references to international publications
with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE: When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 34-2	1972	Rotating electrical machines Part 2: Methods for determining losses and efficiency of rotating electrical machinery from tests (excluding machines for traction vehicles)	HD 53.2 S1 ¹⁾	1974
IEC 41	1963 ²⁾	International code for the field acceptance tests of hydraulic turbines	-	-
ISO 31-3	1978	Quantities and units Quantities and units of mechanics	-	-
ISO 5167	1980	Measurement of fluid flow by means of orifice plates, nozzles and Venturi tubes inserted in circular cross-section conduits running full	-	-

1) HD 53.2 S1 is based on IEC 34-2:1972 + IEC 34-2A:1974.

2) IEC 41:1994, mod. is harmonized as EN 60041:1994.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60953-2:2001

<https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-21d141959be7/sist-en-60953-2-2001>

NORME INTERNATIONALE INTERNATIONAL STANDARD

**CEI
IEC**

953-2

Première édition
First edition
1990-12

Règles pour les essais thermiques de réception des turbines à vapeur –

Partie 2:

Méthode B – Précision de divers degrés pour multiples modèles et tailles de turbines

iTeh STANDARD PREVIEW

(standards.iteh.ai)

Rules for steam turbine thermal acceptance tests –

<https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-21d141959be7/sist-en-60953-2-2001>

Part 2:

Method B – Wide range of accuracy for various types and sizes of turbines

© CEI 1990 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher

Bureau central de la Commission Electrotechnique Internationale 3, rue de Varembe Genève, Suisse



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

XE

Pour prix, voir catalogue en vigueur
For price, see current catalogue

CONTENTS

	Page
FOREWORD	9
PREFACE	9
INTRODUCTION	11
Clause	
1. Scope and object	17
1.1 Scope	17
1.2 Object	17
1.3 Matters to be considered in the contract	17
2. Units, symbols, terms and definitions	17
2.1 General	17
2.2 Symbols, units	19
2.3 Subscripts, superscripts and definitions	21
2.4 Definition of guarantee values and test results	25
2.4.1 Thermal efficiency	25
2.4.2 Heat rate	29
2.4.3 Thermodynamic efficiency	29
2.4.4 Steam rate	31
2.4.5 Main steam flow capacity	31
2.4.6 Maximum power output	31
2.4.7 Guarantee values for extraction and mixed-pressure turbines	31
3. Guiding principles	33
3.1 Advance planning for test	33
3.2 Preparatory agreements and arrangements for tests	35
3.3 Planning of the test	35
3.3.1 Time for acceptance tests	35
3.3.2 Direction of acceptance tests	37
3.3.3 Cost of acceptance tests	37
3.4 Preparation of the tests	37
3.4.1 Condition of the plant	37
3.4.2 Condition of the steam turbine	39
3.4.3 Condition of the condenser	39
3.4.4 Isolation of the cycle	39
3.4.5 Checks for leakage of condenser and feedwater heaters	45
3.4.6 Cleanliness of the steam strainers	45
3.4.7 Checking of the test measuring equipment	45
3.5 Comparison measurements	45
3.6 Settings for tests	47
3.6.1 Load settings	47
3.6.2 Special settings	47
3.7 Preliminary tests	47
3.8 Acceptance tests	49
3.8.1 Constancy of test conditions	49
3.8.2 Maximum deviation and fluctuation in test conditions	49
3.8.3 Duration of test runs and frequency of readings	49
3.8.4 Reading of integrating measuring instruments	51
3.8.5 Alternative methods	51
3.8.6 Recording of tests	53
3.8.7 Additional measurement	53
3.8.8 Preliminary calculations	53
3.8.9 Consistency of tests	53
3.9 Repetition of acceptance tests	53
4. Measuring techniques and measuring instruments	53
4.1 General	53
4.1.1 Measuring instruments	53
4.1.2 Measuring uncertainty	55
4.1.3 Calibration of instruments	55
4.1.4 Alternative instrumentation	55
4.1.5 Mercury in instrumentation	55
4.2 Measurement of power	63
4.2.1 Determination of mechanical turbine output	63
4.2.2 Measurement of boiler feed pump power	63
4.2.3 Determination of electrical power of a turbine generator	65

Clause	Page
4.2.4 Measurement of electrical power	67
4.2.5 Electrical instrument connections	67
4.2.6 Electrical instruments	67
4.2.7 Instrument transformers	67
4.3 Flow measurement	69
4.3.1 Determination of flows to be measured	69
4.3.2 Measurement of primary water flow	71
4.3.3 Installation and location of differential pressure devices	73
4.3.4 Differential pressure measurements	75
4.3.5 Water flow fluctuation	75
4.3.6 Secondary flow measurements	81
4.3.7 Occasional secondary flows	83
4.3.8 Density of water and steam	83
4.3.9 Determination of cooling water flow of condenser	83
4.4 Pressure measurement (excluding condensing turbine exhaust pressure)	83
4.4.1 Pressures to be measured	85
4.4.2 Instruments	87
4.4.3 Pressure tapping holes and connecting lines	89
4.4.4 Shut-off valves	89
4.4.5 Calibration of pressure measuring devices	89
4.4.6 Atmospheric pressure	91
4.4.7 Correction of readings	93
4.5 Condensing turbine exhaust pressure measurement	93
4.5.1 General	93
4.5.2 Plane of measurement	93
4.5.3 Pressure taps	95
4.5.4 Manifolds	95
4.5.5 Connecting lines	95
4.5.6 Instruments	95
4.5.7 Tightness of measuring system	95
4.5.8 Calibration	97
4.5.9 Correction of readings	97
4.6 Temperature measurement	97
4.6.1 Points of temperature measurement	97
4.6.2 Instruments	99
4.6.3 Main temperature measurements	99
4.6.4 Feed train temperature measurements (including bled steam)	99
4.6.5 Condenser cooling water temperature measurement	101
4.6.6 Accuracy of temperature measuring equipment	101
4.6.7 Thermometer wells	101
4.6.8 Precautions to be observed in the measurement of temperature	103
4.7 Steam quality measurement	103
4.7.1 General	103
4.7.2 Tracer technique	105
4.7.3 Condensing method	113
4.7.4 Constant rate injection method	113
4.7.5 Extraction enthalpy determined by constant rate injection method	117
4.7.6 Tracers and their use	119
4.8 Time measurement	119
4.9 Speed measurement	119
5. Evaluation of tests	119
5.1 Preparation of evaluation	121
5.2 Computation of results	121
5.2.1 Calculation of average values of instrument readings	121
5.2.2 Correction and conversion of averaged readings	121
5.2.3 Checking of measured data	123
5.2.4 Thermodynamic properties of steam and water	125
5.2.5 Calculation of test results	125
6. Correction of test results and comparison with guarantee	125
6.1 Guarantee values and guarantee conditions	125
6.2 Correction of initial steam flow capacity	125
6.3 Correction of maximum output	127
6.4 Correction of thermal and thermodynamic efficiency	127
6.5 Definition and application of correction values	129
6.6 Correction methods	129
6.6.1 Correction by heat balance calculation	131
6.6.2 Correction by use of correction curves prepared by the manufacturer	133

Clause	Page
6.6.3 Tests to determine correction values	135
6.6.4 Correction by use of generalized correction curves	135
6.7 Variables to be considered in the correction	135
6.7.1 Turbines with regenerative feed-water heating	135
6.7.2 Turbines which have no provision for the addition or extraction of steam after partial expansion	137
6.7.3 Turbines with steam extraction for purposes other than feed-water heating (extraction turbines)	139
6.7.4 Other types of turbine	139
6.8 Guarantee comparison	141
6.8.1 Guarantee comparison with locus curve	141
6.8.2 Guarantee comparison with guarantee point	143
6.8.3 Guarantee comparison for turbines with throttle governing	143
6.8.4 Guarantee comparison for extraction turbines	143
6.9 Deterioration of turbine performance (ageing)	145
7. Measuring uncertainty	145
7.1 General	145
7.2 Determination of measuring uncertainty of steam and water properties	147
7.2.1 Pressure	147
7.2.2 Temperature	147
7.2.3 Enthalpy and enthalpy difference	149
7.3 Calculation of measuring uncertainty of output	151
7.3.1 Electrical measurement	151
7.3.2 Mechanical measurement	151
7.3.3 Additional uncertainty allowance because of unsteady load conditions	153
7.4 Determination of measuring uncertainty of mass flow	153
7.4.1 Measuring uncertainty of mass flow measurements	153
7.4.2 Measuring uncertainty of multiple measurements of primary flow	153
7.4.3 Uncertainty allowance for cycle imperfections	155
7.5 Calculation of measuring uncertainty of results	155
7.5.1 General	155
7.5.2 Measuring uncertainty of thermal efficiency	155
7.5.3 Measuring uncertainty of thermodynamic efficiency	157
7.5.4 Uncertainty of corrections	157
7.5.5 Guiding values for the measuring uncertainty of results	157
APPENDIX A – Feedwater heater leakage and condenser leakage tests	161
APPENDIX B – Throat tap nozzle	161
APPENDIX C – Evaluation of multiple measurements, compatibility	171
APPENDIX D – Mass flow balances	173
APPENDIX E – Typical generalized correction curves for correction of test results according to guarantee conditions	177
APPENDIX F – Short statistical definition of measuring uncertainty and error propagation in acceptance tests	215
APPENDIX G – Calculation of measuring uncertainty of output – Electrical measurement	221

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS

Part 2: Method B – Wide range of accuracy for various types and sizes of turbines

FOREWORD

- 1) The formal decisions or agreements of the IEC on technical matters, prepared by Technical Committees on which all the National Committees having a special interest therein are represented, express, as nearly as possible, an international consensus of opinion on the subjects dealt with.
- 2) They have the form of recommendations for international use and they are accepted by the National Committees in that sense.
- 3) In order to promote international unification, the IEC expresses the wish that all National Committees should adopt the text of the IEC recommendation for their national rules in so far as national conditions will permit. Any divergence between the IEC recommendation and the corresponding national rules should, as far as possible, be clearly indicated in the latter.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
 PREFACE

This standard has been prepared by IEC Technical Committee No. 5: Steam turbines.
 The text of this standard is based upon the following documents:

Six Months' Rule	Report on Voting
5(CO)24	5(CO)27

Full information on the voting for the approval of this standard can be found in the Voting Report indicated in the above table.

The following IEC publications are quoted in this standard:

Publications Nos. 34-2 (1972): Rotating electrical machines, Part 2: Methods for determining losses and efficiency of rotating electrical machinery from tests (excluding machines for traction vehicles).

41 (1963): International code for the field acceptance tests of hydraulic turbines.

Other publications quoted:

ISO Standard 5167 (1980): Measurement of fluid flow by means of orifice plates, nozzles and Venturi tubes inserted in circular cross-section conduits running full.

ISO 31-3 (1978): Quantities and units – Quantities and units of mechanics.

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS

Part 2: Method B – Wide range of accuracy for various types and sizes of turbines

INTRODUCTION

The rapid development of measuring techniques, the increasing capacity of steam turbines and the introduction of nuclear power plants necessitated a revision of IEC Publication 46 (1962) regarding acceptance tests.

Since all the needs of the power industry in the different parts of the world could not be satisfied by one single publication, the complete standard is divided into two parts, describing two different approaches for conducting and evaluating thermal acceptance tests of steam turbines and which can be used separately:

- a) Method A, which is Part 1 of the standard (IEC 953-1), deals with thermal acceptance tests with high accuracy for large condensing steam turbines.
- b) Method B, which is Part 2 of the standard (IEC 953-2), deals with thermal acceptance tests with a wide range of accuracy for various types and sizes of steam turbines.

SIST EN 60953-2:2001

[https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-](https://standards.iteh.ai/catalog/standards/sist/db4e5184-36cf-4353-aaa6-31db4e5184-36cf-4353-aaa6-sist-en-60953-2-2001)

1) *Basic philosophy and figures on uncertainty*

Part 1 provides for very accurate testing of steam turbines to obtain the level of performance with minimum measuring uncertainty. The operating conditions during the test are stringent and compulsory.

Method A is based on the exclusive use of the most accurate calibrated instrumentation and the best measuring procedures currently available. The uncertainty of the test result is always sufficiently small that it normally need not be taken into account in the comparison between test result and guarantee value. This uncertainty will not be larger than about 0.3% for a fossil fired unit and 0.4% for a nuclear unit.

The cost for instrumentation and the efforts for preparing and conducting the tests will generally be justified economically for large and/or prototype units.

Method B provides for acceptance tests of steam turbines of various types and capacities with appropriate measuring uncertainty. Instrumentation and measuring procedures have to be chosen accordingly from a scope specified in the standard which is centred mainly on standardized instrumentation and procedures, but may extend eventually up to very high accuracy provisions requiring calibration. The resulting measuring uncertainty of the test result is then determined by calculating methods presented in the standard and normally, if not stated otherwise in the contract, taken into account in the comparison between test result and guarantee value. The total cost of an acceptance test can therefore be maintained in relationship with the economic value of the guarantee values to be ascertained.

The specifications of the operating conditions during the test are somewhat more flexible in this method; furthermore, procedures are recommended for treating cases where these specifications cannot be met.

When good-standardized instrumentation and procedures are applied in a test, the measuring uncertainty of the result will usually amount to 0.9% to 1.2% for a large fossil fuel fired condensing unit, to 1.1% to 1.4% for a nuclear unit and to 1.5% to 2.5% for back pressure, extraction and small condensing turbines. It is possible to reduce these values by additional improvement in instrumentation, primarily by additional measurements of primary mass flows and/or calibration of measuring devices for primary mass flow.

2) *Main differences between Methods A and B*

In Method A, much more detailed information concerning the preparation and conduct of the tests and the measuring techniques are contained for guidance of the parties to the test than in Method B. In Method B, the detailed treatment of the objectives is left somewhat more to the discretion and decisions of the participants and necessitates sufficient experience and expertise on their part.

3) *Guiding principles*

The requirements concerning the preparation and conditions of the test and especially such conditions of the test as duration, deviations and constancy of test conditions and acceptable differences between double measurements are more stringent in Method A.

The test should be conducted preferably within eight weeks after the beginning of the operation. It is the intent during this period to minimize performance deterioration and risk of damage to the turbine.

Preliminary tests including enthalpy drop tests should be made during this period to monitor HP and IP turbine section performance. However, these tests do not provide LP section performance and for this reason it is imperative to conduct the acceptance tests as soon as practicable.

Whatever the case, when using Method A, if an enthalpy drop test indicates a possible deterioration of the HP or IP section, or if the plant conditions require that the tests be postponed more than four months after the initial start, then the acceptance tests should be delayed.

An adjustment of the heat rate test results to start-up enthalpy drop efficiencies or for the effects of aging is not permitted when using Method A.

If the test has to be postponed, Method A proposes that the test be carried out after the first major internal inspection; several methods are proposed for establishing the approximate condition of the turbine prior to the tests.

4) *Instruments and methods of measurement*

a) *Measurement of electrical power*

In addition to the conditions required for the measurement of electric power, which are similar in both methods, Method A requires a check of the instruments by a comparison measurement after each test run; the permissible difference between double measurements is limited to 0.15%.

b) *Flow measurement*

For the measurement of main flows the use of calibrated pressure difference devices is required in Method A. The application of a device not covered by international standardization, the throat-tap nozzle, is recommended therein and details of design and application are given.

The calibration of these devices shall be conducted with the upstream and downstream piping and flow-straightener. Methods for the necessary extrapolation of the discharge coefficient from the calibration values are given.

In Method B standardized pressure-difference devices are normally applied for flow measurement. Calibration is recommended where a reduction of overall measuring uncertainty is desirable. Double or multiple measurement of primary flow is recommended for the reduction of measuring uncertainty and a method for checking the compatibility is described.

c) Pressure measurement

The requirements and recommendations for pressure measurements are essentially similar. Only the methods for the measurement of exhaust-pressure of condensing turbines differ to some extent.

d) Temperature measurement

The requirements are essentially similar in both methods. However detail requirements are more stringent in Method A:

- calibration before and after the test,
- double measurement of the main temperature with with 0.5 K maximum difference,
- thermocouples with continuous leads,
- required overall accuracy.

e) Steam quality measurements

Methods A and B are identical.

5) *Evaluation of tests*

The preparatory work for the evaluation and calculation of the test results is covered in a very similar manner in Methods A and B. However, quantitative requirements are more stringent in Method A.

Method B contains some proposals for handling cases where some requirements have not been met to avoid rejection of the test. (standards.iteh.ai)

In addition, Method B contains detailed methods for calculation of measuring uncertainty values of measured variables and tests results. [SIST EN 60953-2:2001](https://standards.iteh.ai/catalog/standards/sist/en-60953-2-2001)

Method B recommends other methods for conducting and evaluating of the tests after the specified period and without a previous inspection. <https://standards.iteh.ai/catalog/standards/sist/en-60953-2-2001>

6) *Correction of test results and comparison with guarantees*

The correction of test results to guarantee conditions is covered in both Methods A and B.

Method A provides for the comparison of test results to guarantee without consideration of measuring uncertainty.

Method B gives a broader spectrum of correction procedures. Furthermore, the measuring uncertainty of the result is taken into account in the guarantee comparison.

7) *Proposals for application*

Since the acceptance test method to be applied has to be considered in the details of the plant design, it should be stated as early as possible, preferably in the turbine contract, which method will be used.

Method B can be applied to steam turbines of any type and any power. The desired measuring uncertainty should be decided upon sufficiently early, so that the necessary provisions can be included in the plant.

If the guarantee includes the complete power plant or large parts thereof, the relevant parts of either method can be applied for an acceptance test in accordance with the definition of the guarantee value.

1. Scope and object

1.1 Scope

The rules given in this standard are applicable to thermal acceptance tests covering a wide range of accuracy on steam turbines of every type, rating and application. Only the relevant portion of these rules will apply to any individual case.

The rules provide for the testing of turbines, whether operating with either superheated or saturated steam. They include measurements and procedures required to determine specific enthalpy within the moisture region and describe precautions necessary to permit testing while respecting radiological safety rules in nuclear plants.

Uniform rules for the preparation, carrying out, evaluation, comparison with guarantee and calculation of measuring uncertainty of acceptance tests are defined in this standard. Details of the conditions under which the acceptance test shall take place are included.

Should any complex or special case arise which is not covered by these rules, appropriate agreement shall be reached by manufacturer and purchaser before the contract is signed.

1.2 Object

The purpose of the thermal acceptance tests of steam turbines and turbine plants described in this standard is to verify guarantees given by the manufacturer of the plant concerning:

- a) turbine plant thermal efficiency or heat rate;
- b) turbine thermodynamic efficiency or steam rate or power output at specified steam flow conditions;
- c) main steam flow capacity and/or maximum power output.

The guarantees with their provisions shall be formulated completely and without contradictions (see 2.4). The acceptance tests may also include such measurements as are necessary for corrections according to the conditions of the guarantee and checking of the results.

1.3 Matters to be considered in the contract

Some matters in these rules have to be considered at an early stage. Such matters are dealt with in the following sub-clauses:

Sub-clause

- 1.1 (paragraph 4)
- 1.2 (paragraph 2)
- 3.1 (paragraph 3 and 4)
- 3.3.3 (paragraph 1)
- 6.6
- 6.8
- 6.9 (paragraph 1)

2. Units, symbols, terms and definitions

2.1 General

The International System of Units (SI) is used in these rules; all conversion factors can therefore be avoided.