



Designation: ~~B 869-04~~ Designation: B 869 - 07

Standard Specification for Copper-Clad Steel Electrical Conductor for CATV Drop Wire¹

This standard is issued under the fixed designation B 869; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers 21 % conductivity hard-drawn round copper-clad steel wire for coaxial cable center conductors (Note 1).

NOTE 1—Wire ordered to this specification is not intended for redrawing since it is furnished in the hard-drawn temper. If wire is desired for the purpose, the manufacturer should be consulted.

1.2 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only.

2. Referenced Documents

2.1 The following documents, of the issue in effect on the date of material purchase, form a part of this specification to the extent referenced herein.

2.2 *ASTM Standards*:²

B 193 Test Method for Resistivity of Electrical Conductor Materials

B 258 Specification for ~~Standard~~ Nominal Diameters and Cross-Sectional Areas of AWG Sizes of Solid Round Wires Used as Electrical Conductors

2.3 *NIST Document*:³

NBS *Handbook 100—Copper Wire Tables*

3. Ordering Information

3.1 Orders for material under this specification shall include the following information:

3.1.1 Quantity of each size;

3.1.2 Wire size: diameter in inches (see 5.1 and Table 1);

3.1.3 Package size (see 15.1);

3.1.4 Special package marking, if required (Section 15); and

3.1.5 Place of inspection (13.2).

4. Material

4.1 The wire shall be composed of a steel core with a substantially uniform and continuous copper cladding thoroughly bonded to it throughout.

4.2 The finished copper-clad steel wire shall conform to the requirements in this specification.

5. Dimensions and Permissible Variations

5.1 The size shall be expressed as the diameter of the wire in decimal fractions of an inch, using four places of decimals, that is, in tenths of a mil (Note 2).

NOTE 2—The values of wire diameters in Table 1 and Table 2 are given to the nearest 0.0001 in. (0.0025 mm) and correspond to the standard sizes given in Specification B 258. In specifying diameters of wire or inspecting wire, the diameter should also be expressed to the fourth decimal place. An excellent discussion of wire gages and related subjects is contained in *NBS Handbook 100*.

¹ This specification is under the jurisdiction of ASTM Committee B01 on Electrical Conductors and is the direct responsibility of Subcommittee B01.06 on Composite Conductors.

Current edition approved April-Oct. 1, 2004-2007. Published April-2004-November 2007. Originally approved in 1996. Last previous edition approved in 2002-2004 as B869-02-B 869 - 04.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from National Institute of Standards and Technology (NIST), 100 Bureau Dr., Stop 3460,1070, Gaithersburg, MD 20899-3460,20899-1070, <http://www.nist.gov>.

TABLE 1 Properties of Hard-Drawn 21 % Conductivity Copper-Clad Steel Wire

Nominal Diameter, in. ^A	Permissible Variations ^A	Maximum Resistance /1000 ft at 20°C	Minimum Copper Thickness, in. ^A
0.0641	±0.0006 in.	12.249	0.00096
0.0571	±0.0006 in.	15.472	0.00086
0.0508	±0.0005 in.	19.521	0.00076
0.0453	±0.0005 in.	24.608	0.00068
0.0403	±0.0004 in.	31.024	0.00060
0.0320	±0.0003 in.	49.150	0.00048
0.0285	±0.0003 in.	62.107	0.00043

^A Metric equivalents: 1 in. = 25.4 mm.

TABLE 2 Approximate Properties (Information Only)

Nominal Diameter, in. ^A	Area		Rated Breaking Strength, min, lb	Mass (lb/1000 ft)	Mass (lb/mile)
	cmil	in. ^{2A}			
0.0641	4108	0.003227	387	11.10	58.60
0.0571	3260	0.002560	307	9.05	47.78
0.0508	2580	0.002026	243	6.99	36.90
0.0453	2052	0.001611	193	5.56	29.36
0.0403	1624	0.001276	153	4.51	23.81
0.0320	1024	0.000804	96	2.77	14.65
0.0285	812	0.000637	75	2.25	11.88

^A Metric equivalents: 1 in. = 25.4 mm; 1 in.² = 645.16 mm² (round to four significant figures); 1 mil = 0.0254 mm (round to two decimal places).

5.2 Within the range of diameters included in Table 1, the wire shall not vary from the specified diameter by more than ±1 %, expressed to the nearest 0.0001 in. (0.0025 mm).

5.3 Ten percent, but not less than five reels (or all, if the lot is less than five), from any lot of wire shall be gaged. All reels shall be gaged if any of the selected reels fail to conform to the requirements for diameter.

6. Workmanship, Finish, and Appearance

6.1 The surface of the wire shall be free from imperfections and be consistent with good commercial practice.

7. Tensile and Elongation Properties

7.1 The wire shall conform to a minimum tensile requirement of 120 000 psi (827 MPa) and a minimum elongation requirement of 1.0 %.

7.2 Tension tests shall be made on representative samples. Unless otherwise agreed upon between the manufacturer and the purchaser, the elongation shall be determined by measurements made between the jaws of the testing machine. The zero length shall be the distance between the jaws when a load equal to 10 % of the specified tensile strength has been applied, and the final length shall be the distance between the jaws at the time of rupture. The zero length shall be as near 10 in. (254 mm) as practicable. The fracture shall be between the jaws of the testing machine and not closer than 1 in. (25.4 mm) to either jaw. The elongation as thus determined shall not be less than 1.0 %. See Table 2 for related breaking strengths.

7.3 When agreed upon between the manufacturer and the purchaser, the elongation may be measured by means of an extensometer suitable for measuring elongation in 10 in. (250 mm) and having a vernier reading to 0.01 in. (0.25 mm) attached to the test specimen at a tension load of approximately 10 % of rated strength. The elongation as thus determined shall not be less than 1.0 %. If the fracture occurs before the 1.0 % elongation requirement and outside the two attachments of the extensometer to the specimen, this sample shall be disregarded and a retest shall be performed.

7.4 *Retest*—If, upon testing a sample from any coil or spool of wire, the results do not conform to the tensile requirements prescribed in 7.1 and the elongation requirements of 7.4, two additional samples shall be tested, and the average of the three tests shall determine the acceptance or rejection of the coil or spool.

NOTE 3—The approximate properties of 21 % conductivity hard drawn copper-clad steel wire are shown in Table 1 for the information of the user of this specification.

8. Torsion Test

8.1 The wire shall withstand, without fracture, not less than 20 torsions in a length equivalent to 100 times the nominal diameter of the specimen. In the twist test, the rate of applying the twists shall be approximately 15/min.

8.2 Specimens shall be twisted to destruction and shall not reveal under testing any seams, pits, slivers, or surface imperfections of sufficient magnitude to indicate inherent defects or imperfections in the wire.