

SLOVENSKI STANDARD

SIST EN 1568-1:2018

01-maj-2018

Nadomešča:

SIST EN 1568-1:2008

SIST EN 1568-1:2008/AC:2010

Gasila - Penila - 1. del: Specifikacija za penila za srednjo peno za površinsko uporabo pri tekočinah, netopnih v vodi

Fire extinguishing media - Foam concentrates - Part 1: Specification for medium expansion foam concentrates for surface application to water-immiscible liquids

iTeh STANDARD PREVIEW

Feuerlöschmittel - Schaummittel - Teil 1: Anforderungen an Schaummittel zur Erzeugung von Mittelschaum zum Aufgeben auf mit Wasser nicht mischbaren Flüssigkeiten

[SIST EN 1568-1:2018](https://standards.itel.si/catalog/standards/sist/15-2014cc-2973-4a5c-99dc-c9c499d6d13d/sist-en-1568-1-2018)

Agents extincteurs - Émulseurs - Partie 1: Spécifications pour les émulseurs moyen foisonnement destinés à une application à la surface de liquides n'ayant pas d'affinité pour l'eau

Ta slovenski standard je istoveten z: EN 1568-1:2018

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 1568-1:2018 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 1568-1:2018](#)

<https://standards.iteh.ai/catalog/standards/sist/fb2014cc-2973-4a5c-99dc-cac499d6d1dd/sist-en-1568-1-2018>

EUROPEAN STANDARD

EN 1568-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2018

ICS 13.220.10

Supersedes EN 1568-1:2008

English Version

Fire extinguishing media - Foam concentrates - Part 1: Specification for medium expansion foam concentrates for surface application to water-immiscible liquids

Agents extincteurs - Émulseurs - Partie 1 :
Spécifications pour les émulseurs moyen foisonnement
destinés à une application à la surface de liquides
n'ayant pas d'affinité pour l'eau

Feuerlöschmittel - Schaummittel - Teil 1:
Anforderungen an Schaummittel zur Erzeugung von
Mittelschaum zum Aufgeben auf mit Wasser nicht
mischbaren Flüssigkeiten

This European Standard was approved by CEN on 1 October 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	5
Introduction	7
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Sediment in the foam concentrate	10
4.1 Sediment before ageing	10
4.2 Sediment after ageing.....	10
5 Freezing point.....	10
6 Viscosity of the foam concentrate	11
6.1 Newtonian foam concentrates.....	11
6.2 Pseudo-plastic foam concentrates.....	11
7 pH of the foam concentrate	11
8 Surface tension of the foam solution.....	11
9 Stability/separation test of foam concentrate.....	11
10 Determination of expansion and drainage time.....	11
10.1 Before temperature conditioning.....	11
10.2 After temperature conditioning.....	11
11 Test fire performance.....	12
12 Occupational health and ecotoxicological information	12
13 Technical data sheet	12
14 Container marking.....	12
Annex A (informative) Grades of foam concentrate	14
Annex B (normative) Sampling of foam concentrates	15
Annex C (normative) Determination of percentage sediment.....	16
C.1 Sampling.....	16
C.2 Apparatus.....	16
C.3 Procedure.....	16
Annex D (normative) Determination of viscosity for pseudo-plastic foam concentrates	17
D.1 Pseudo-plastic foam concentrates	17
D.2 Viscosity determination.....	17
D.2.1 Apparatus.....	17
D.2.2 Test temperatures	17
D.2.3 Viscosity measurement.....	17
D.2.4 Results.....	18

Annex E (normative) Temperature conditioning of foam concentrates	19
E.1 General	19
E.2 Low temperature conditioning	19
E.2.1 Apparatus	19
E.2.2 Procedure	19
E.3 High temperature conditioning	19
E.3.1 Apparatus	19
E.3.2 Procedure	19
E.4 Division into top and bottom half-samples	20
E.4.1 Apparatus	20
E.4.2 Procedure	21
Annex F (normative) Determination of surface tension	22
F.1 Solution of foam concentrate	22
F.2 Procedure — Surface tension	22
Annex G (normative) Determination of expansion and drainage time	23
G.1 Apparatus	23
G.2 Temperature conditions	23
G.3 Procedure	23
G.4 Simulated fresh and sea water	24
Annex H (normative) Determination of test fire performance	28
H.1 General	28
H.2 General conditions	28
H.2.1 Test series and criteria for success	28
H.2.1.1 Foam concentrates not compatible with sea water	28
H.2.1.2 Foam concentrates compatible with sea water	28
H.2.2 Temperature and wind speed	28
H.2.3 Records	29
H.2.4 Foam solution	29
H.2.5 Fuel	29
H.3 Fire test	30
H.3.1 Apparatus	30
H.3.2 Test procedure	30
Annex I (informative) Description of a radiation measurement method	32
I.1 Evaluation	32
I.2 General arrangement of test	32
I.3 Technical data for radiometers)	33

EN 1568-1:2018 (E)

I.4	Procedure.....	34
Annex J (normative) Freezing point determination		36
J.1	General.....	36
J.2	Equipment required.....	36
J.3	Procedure.....	36
J.4	Example of a temperature against time curve for evaluation	37
Annex K (normative) Stability/Separation test of foam concentrate.....		38
K.1	General.....	38
K.2	Apparatus.....	38
K.3	Procedure.....	38
Annex L (normative) Occupational health and ecotoxicological testing.....		39
Annex M (informative) Example for a technical data sheet.....		40
Annex N (informative) A-deviations.....		42
Bibliography.....		44

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 1568-1:2018

<https://standards.iteh.ai/catalog/standards/sist/fb2014cc-2973-4a5c-99dc-cac499d6d1dd/sist-en-1568-1-2018>

European foreword

This document (EN 1568-1:2018) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2018 and conflicting national standards shall be withdrawn at the latest by November 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1568-1:2008.

In comparison with the previous edition, the following significant changes have been made:

- Interfacial tension and spreading coefficient test removed;
- Freezing point test introduced;
- Stability/Separation test of foam concentrate introduced;
- Occupational health and ecotoxicological testing introduced;
- Example of technical data sheet included.

This document is Part 1 of EN 1568 which has the general title *Fire extinguishing media — Foam concentrates*. The other parts are:

- *Part 2: Specification for high expansion foam concentrates for surface application to water-immiscible liquids;*
- *Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids;*
- *Part 4: Specification for low expansion foam concentrates for surface application to water-miscible liquids.*

This European Standard is one of a series of standards specifying requirements for fire extinguishing media in common use. This series includes the following standards:

- EN ISO 5923, *Equipment for fire protection and fire fighting — Fire extinguishing media — Carbon dioxide (ISO 5923);*
- EN 27201-1, *Fire protection — Fire extinguishing media — Halogenated hydrocarbons — Part 1: Specifications for halon 1211 and halon 1301 (ISO 7201-1);*
- EN 27201-2, *Fire protection — Fire extinguishing media — Halogenated hydrocarbons — Part 2: Code of practice for safe handling and transfer procedures (ISO 7201-2);*
- EN 615, *Fire protection — Fire extinguishing media — Specifications for powders (other than class D powders).*

EN 1568-1:2018 (E)

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN 1568-1:2018](https://standards.iteh.ai/catalog/standards/sist/fb2014cc-2973-4a5c-99dc-cac499d6d1dd/sist-en-1568-1-2018)

<https://standards.iteh.ai/catalog/standards/sist/fb2014cc-2973-4a5c-99dc-cac499d6d1dd/sist-en-1568-1-2018>

Introduction

As fire fighting foams are chemical agents or chemical preparations Commission Directive 2000/60/CE and Regulations (EC) No 1272/2008 (CLP) and No 1907/2006 (REACH) apply and should be taken into account.

Classes of fire are defined in EN 2 as follows:

- a) Class A: fires involving solid materials, usually of an organic nature, in which combustion normally takes place with the formation of glowing embers;
- b) Class B: fires involving liquids or liquefiable solids;
- c) Class C: fires involving gases;
- d) Class D: fires involving metals;
- e) Class F: fires involving cooking media (vegetable or animal oils and fats) in cooking appliances.

Fire fighting foams are widely used to control and extinguish Class B fires and to inhibit re-ignition. These foams can also be used for prevention of ignition of flammable liquids and, in certain conditions, to extinguish Class A fires.

Foams can be used in combination with other extinguishing media, particularly gaseous media and powders, which are the subject of other European Standards (see Foreword).

These specifications have been designed to ensure that fire extinguishing media have the minimum useful fire fighting capability. The user should ensure that the foam concentrates are used accurately at the concentration recommended by the manufacturer. Fire performances indicated by this standard cannot replicate practical fire situations.

Foam concentrates of different types and manufacturers should not be mixed.

It should be noted that some combinations of extinguishing powder and foam can lead to unacceptable loss of efficiency, caused by unfavourable interaction of the chosen media when applied simultaneously or successively to the fire.

It is extremely important that the foam concentrate after dilution with water to the recommended concentration should not in normal usage present a significant toxic hazard to life in relation to the environment. The current version of Commission Directive 2000/60/CE, Regulations (EC) No 1272/2008 (CLP) and No 1907/2006 (REACH) apply when considering the testing of ecotoxicological properties and safety in the work environment.

A special quality characteristic is the type test conducted by an independent testing laboratory accredited to EN ISO/IEC 17025.

EN 1568-1:2018 (E)

1 Scope

This European Standard specifies requirements for chemical and physical properties, and minimum performance requirements of medium expansion foams suitable for surface application to water-immiscible liquids. Requirements are also given for marking.

WARNING — Any type approval according to this standard is invalidated by any change in composition of the approved product.

Some concentrates conforming to this part of EN 1568 can also conform to other parts and therefore can also be suitable for application as low and/or high expansion foams.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1568-2, *Fire extinguishing media - Foam concentrates - Part 2: Specification for high expansion foam concentrates for surface application to water-immiscible liquids*

EN 1568-3, *Fire extinguishing media - Foam concentrates - Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids*

EN 1568-4, *Fire extinguishing media - Foam concentrates - Part 4: Specification for low expansion foam concentrates for surface application to water-miscible liquids*

EN ISO 3104, *Petroleum products - Transparent and opaque liquids - Determination of kinematic viscosity and calculation of dynamic viscosity (ISO 3104)*

EN ISO 3219, *Plastics - Polymers/resins in the liquid state or as emulsions or dispersions - Determination of viscosity using a rotational viscometer with defined shear rate (ISO 3219)*

EN ISO 3696, *Water for analytical laboratory use - Specification and test methods (ISO 3696)*

EN ISO 11348-2, *Water quality - Determination of the inhibitory effect of water samples on the light emission of *Vibrio fischeri* (Luminescent bacteria test) - Part 2: Method using liquid-dried bacteria (ISO 11348-2)*

EN ISO 23753-1, *Soil Quality - Determination of dehydrogenase activity in soil - Part 1: Method using triphenyltetrazolium chloride (TTC) (ISO 23753-1)*

ISO 304, *Surface active agents - Determination of surface tension by drawing up liquid films*

ISO 3310-1, *Test sieves - Technical requirements and testing - Part 1: Test sieves of metal wire cloth*

OECD 201, *Test No. 201: Freshwater Alga and Cyanobacteria, Growth Inhibition Test*

OECD 202, *Test No. 202: Daphnia sp. Acute Immobilisation Test*

OECD 203, *Test No. 203: Fish, Acute Toxicity Test*

OECD 301, *Test No. 301: Ready Biodegradability*

OECD 404, *Test No. 404: Acute Dermal Irritation/Corrosion*

OECD 405, *Test No. 405: Acute Eye Irritation/Corrosion*

OECD 420, *Test No. 420: Acute Oral Toxicity - Fixed Dose Procedure*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

25 %/50 % drainage time

time taken for 25 %/50 % of the volume of the original foam solution to drain out of the generated foam

3.2

expansion (E)

expansion value

expansion ratio

ratio of the volume of foam to the volume of the foam solution from which it was made

3.3

low expansion foam

foam which has an expansion ratio less than 20

3.4

medium expansion foam

foam which has an expansion ratio greater than or equal to 20 but less than 200

3.5

high expansion foam

foam which has an expansion ratio greater than or equal to 200

3.6

fire-fighting foam

aggregate of air filled bubbles formed from a foam solution used for fire-fighting

3.7

foam concentrate

liquid which is diluted with water to produce foam solution

Note 1 to entry: Annex A gives information on grades of foam concentrate.

3.8

foam solution

solution of foam concentrate in water

EN 1568-1:2018 (E)**3.9****sediment**

insoluble particles in the foam concentrate

3.10**Newtonian foam concentrate**

foam concentrate which has a viscosity which is independent of the shear rate

3.11**pseudo-plastic foam concentrate**

foam concentrate which has a viscosity which decreases with increasing shear rate

3.12**surface tension**

tension within the interface between a liquid and air

3.13**freezing point**

temperature at which the first ingredient of a mixture starts to solidify or freeze out

3.14**designation****identifying name**

name that corresponds to a chemical formulation and a specific production process

Note 1 to entry: It guarantees consistency of the characteristics, performance and conditions of use of the foam concentrate.

[SIST EN 1568-1:2018](https://standards.iteh.ai/catalog/standards/sist/fb2014cc-2973-4a5c-99dc-cac499d6d1dd/sist-en-1568-1-2018)

3.15**demineralized water**

water conforming to EN ISO 3696 (Grade 3), the water having a surface tension greater than 70 mN m⁻¹ when tested in accordance with F.2 and a conductivity of < 5 μ S cm⁻¹

4 Sediment in the foam concentrate**4.1 Sediment before ageing**

Any sediment in the foam concentrate sampled in accordance with Annex B, but not aged in accordance with C.1, shall be dispersible through a 180 μm sieve, and the percentage volume of sediment shall be not more than 0,25 % when tested in accordance with Annex C.

4.2 Sediment after ageing

Any sediment in the foam concentrate sampled in accordance with Annex B, and aged in accordance with C.1, shall be dispersible through a 180 μm sieve and the percentage volume of sediment shall be not more than 1,0 % when tested in accordance with Annex C.

5 Freezing point

The freezing point of the foam concentrate sampled in accordance with Annex B shall be determined in accordance with Annex J.

6 Viscosity of the foam concentrate

6.1 Newtonian foam concentrates

The viscosity of the foam concentrate at the lowest temperature for use claimed by the manufacturer shall be determined in accordance with EN ISO 3104. If the viscosity is $> 200 \text{ mm}^2 \text{ s}^{-1}$, the container shall be marked in accordance with Clause 14 j).

6.2 Pseudo-plastic foam concentrates

The viscosity of the foam concentrate shall be determined in accordance with Annex D. If the viscosity at the lowest temperature for use is greater than or equal to $120 \text{ mPa}\cdot\text{s}$ at 375 s^{-1} , the container shall be marked in accordance with Clause 14 k).

7 pH of the foam concentrate

The pH of the foam concentrate sampled in accordance with Annex B shall be not less than 6,0 and not more than 9,5 at $(20 \pm 1) ^\circ\text{C}$.

8 Surface tension of the foam solution

The surface tension (determined in accordance with F.2) of the foam solutions prepared using top and bottom half-samples (see E.4) of the foam concentrate, sampled in accordance with Annex B and conditioned in accordance with Annex E, shall be not less than 0,95 times and not more than 1,05 times the surface tension of the foam solution prepared using the sampled foam concentrate.

9 Stability/separation test of foam concentrate

The foam concentrate shall not separate, stratify or precipitate as indicated by two or more distinct layers or the presence of solid deposits when tested in accordance with Annex K.

10 Determination of expansion and drainage time

10.1 Before temperature conditioning

The foam produced from the foam solution, prepared from the foam concentrate sampled in accordance with Annex B at the supplier's recommended concentration with simulated fresh water in accordance with G.4, shall be tested in accordance with Annex G. If appropriate, a further sample of the same concentration made with simulated sea water in accordance with G.4 shall also be tested.

NOTE Expansion is dependent on the foam concentrate and the equipment used to make the foam.

10.2 After temperature conditioning

The foams produced from the solutions prepared with simulated fresh water by using top and bottom half-samples (see E.4) of foam concentrate, sampled in accordance with Annex B, at the supplier's recommended concentration, when tested in accordance with Annex G, shall have the following:

- a) expansions which do not differ from each other or from the value obtained in 10.1 using simulated fresh water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using simulated fresh water; and
- b) 25 % drainage times which do not differ from each other or from the value obtained in 10.1 using simulated fresh water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using simulated fresh water.