
Gasila - Penila - 3. del: Specifikacija za penila za težko peno za površinsko uporabo pri tekočinah, netopnih v vodi

Fire extinguishing media - Foam concentrates - Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids

Feuerlöschmittel - Schaummittel - Teil 3: Anforderungen an Schaummittel zur Erzeugung von Schwertschaum zum Aufgeben auf nicht-polare (mit Wasser nicht mischbare) Flüssigkeiten

Agents extincteurs - Émulseurs - Partie 3: Spécifications pour les émulseurs bas foisonnement destinés à une application à la surface de liquides n'ayant pas d'affinité pour l'eau

Ta slovenski standard je istoveten z: prEN 1568-3

ICS:

13.220.10 Gašenje požara Fire-fighting

oSIST prEN 1568-3:2016 **en,fr,de**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 1568-3

July 2016

ICS 13.220.10

Will supersede EN 1568-3:2008

English Version

Fire extinguishing media - Foam concentrates - Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids

Agents extincteurs - Émulseurs - Partie 3:
Spécifications pour les émulseurs bas foisonnement
destinés à une application à la surface de liquides
n'ayant pas d'affinité pour l'eau

Feuerlöschmittel - Schaummittel - Teil 3:
Anforderungen an Schaummittel zur Erzeugung von
Schwerschaum zum Aufgeben auf nicht-polare (mit
Wasser nicht mischbare) Flüssigkeiten

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 191.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
European foreword.....	5
Introduction	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Sediment in the foam concentrate	9
4.1 Sediment before ageing	9
4.2 Sediment after ageing.....	9
5 Freezing point.....	10
6 Viscosity of the foam concentrate	10
6.1 Newtonian foam concentrates.....	10
6.2 Pseudo-plastic foam concentrates.....	10
7 pH of the foam concentrate	10
8 Surface tension of the foam solution.....	10
9 Evaluation of aqueous film formation.....	10
10 Expansion and drainage of foam	10
10.1 Before temperature conditioning.....	10
10.2 After temperature conditioning	10
11 Test fire performance.....	11
12 Stability/Separation test	12
13 Occupational health and ecotoxicological evaluation	12
14 Technical data sheet	12
15 Container marking.....	12
Annex A (informative) Grades of foam concentrate and performance.....	14
A.1 Grades.....	14
A.2 Typical performance.....	14
Annex B (normative) Preliminary sampling of foam concentrates	16
Annex C (normative) Determination of percentage sediment.....	17
C.1 Sampling.....	17
C.2 Apparatus.....	17
C.3 Procedure.....	17
Annex D (normative) Determination of Viscosity for pseudo-plastic foam concentrates.....	18
D.1 Pseudo-plastic foam concentrates.....	18
D.2 Viscosity determination.....	18
D.2.1 Apparatus.....	18
D.2.2 Test temperatures	18
D.2.3 Viscosity measurement.....	18
D.2.4 Results.....	19

Annex E (normative) Temperature conditioning of foam concentrates	20
E.1 General	20
E.2 Low temperature conditioning.....	20
E.2.1 Apparatus	20
E.2.2 Procedure	20
E.3 High temperature conditioning.....	20
E.3.1 Apparatus	20
E.3.2 Procedure	20
E.4 Division into top and bottom half-samples.....	21
E.4.1 Apparatus	21
E.4.2 Procedure	22
Annex F (normative) Determination of surface tension.....	23
F.1 Materials	23
F.2 Procedure — Surface tension.....	23
Annex G (normative) Determination of expansion and drainage time.....	24
G.1 Apparatus	24
G.2 Temperature conditions	24
G.3 Procedure	24
G.4 Simulated fresh and sea water.....	25
Annex H (normative) Determination of test fire performance.....	30
H.1 General	30
H.2 General conditions	30
H.2.1 Test series and criteria for success	30
H.2.2 Temperature and wind speed.....	30
H.2.3 Records.....	30
H.2.4 Foam solution.....	31
H.2.5 Fuel	31
H.3 Gentle application fire test.....	32
H.3.1 Apparatus	32
H.3.2 Test procedure	32
H.4 Forceful application fire test	33
H.4.1 Apparatus	33
H.4.2 Procedure	33
Annex I (informative) Small scale fire test	35
I.1 Apparatus.....	35
I.1.1 Circular fire tray of brass as shown in Figure I.1 with dimensions as follows:	35
I.1.2 Fuel	35
I.2 Test procedure	35
I.2.1 Test conditions	35
I.2.2 Set up.....	36
I.2.3 Fire test.....	36
Annex J (informative) Description of a radiation measurement method	46
J.1 Evaluation.....	46
J.2 General arrangement of test.....	46
J.3 Technical data for radiometers	47
J.4 Procedure	47
Annex K (normative) Freezing Point Determination	50
K.1 Equipment required	50
K.2 Procedure:.....	50
K.3 Example for Evaluation	51

prEN 1568-3:2016 (E)

Annex L (normative) Evaluation of film formation.....	52
L.1 Sampling.....	52
L.2 Apparatus.....	52
L.3 Materials.....	52
L.4 Procedure.....	52
Annex M (normative) Stability/Separation test of foam concentrate.....	53
M.1 General.....	53
M.2 Apparatus.....	53
M.3 Procedure.....	53
Annex N (normative) Occupational Health and Ecotoxicological Testing.....	54
Annex O (informative) Technical data sheet.....	55
Annex P (informative) A-Deviations.....	58
Bibliography.....	60

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 1568-3:2018

<https://standards.iteh.ai/catalog/standards/sist/c936fe6f-b0ec-4346-bca2-ba04d0b3a51f/sist-en-1568-3-2018>

European foreword

This document (prEN 1568-3:2016) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 1568-3:2008.

This document is Part 3 of EN 1568 which has the general title *Fire extinguishing media — Foam concentrates*. The other parts are:

- *Part 1: Specification for medium expansion foam concentrates for surface application to water-immiscible liquids;*
- *Part 2: Specification for high expansion foam concentrates for surface application to water-immiscible liquids;*
- *Part 4: Specification for low expansion foam concentrates for surface application to water-miscible liquids.*

This European Standard is one of a series of standards specifying requirements for fire extinguishing media in common use. This series includes the following standards:

- EN ISO 5923, *Equipment for fire protection and fire fighting — Fire extinguishing media — Carbon dioxide (ISO 5923);*
- EN 27201-1, *Fire protection — Fire extinguishing media - Halogenated hydrocarbons — Part 1: Specifications for halon 1211 and halon 1301 (ISO 7201-1:1989);*
- EN 27201-2, *Fire protection — Fire extinguishing media — Halogenated hydrocarbons — Part 2: Code of practice for safe handling and transfer procedures (ISO 7201-2:1991);*
- EN 615, *Fire protection — Fire extinguishing media — Specifications for powders (other than class D powders).*

prEN 1568-3:2016 (E)**Introduction**

As fire fighting foams are chemical agents or chemical preparations Commission Directive 2006/60/CE and Regulations (EC) No 1272/2008 and No 1907/2006 (REACH) apply and should be taken into account.

Classes of fire are defined in EN 2 as follows:

- Class A: fires involving solid materials, usually of an organic nature, in which combustion normally takes place with the formation of glowing embers;
- Class B: fires involving liquids or liquefiable solids;
- Class C: fires involving gases;
- Class D: fires involving metals;
- Class F: fires involving cooking media (vegetable or animal oils and fats) in cooking appliances.

Fire-fighting foams are widely used to control and extinguish Class B fires and to inhibit re-ignition. These foams can also be used for prevention of ignition of flammable liquids and, in certain conditions, to extinguish Class A fires.

Foams can be used in combination with other extinguishing media, particularly gaseous media and powders, which are the subject of other European Standards (see Foreword).

These specifications have been designed to ensure that fire extinguishing media have the minimum useful fire fighting capability. The user should ensure that the foam concentrates are used accurately at the concentration recommended by the manufacturer. Fire performances indicated by this standard cannot replicate practical fire situations.

Foam concentrates of different types and manufacture should not be mixed.

It should be noted that some combinations of extinguishing powder and foam can lead to unacceptable loss of efficiency, caused by unfavourable interaction of the chosen media when applied simultaneously or successively to the fire.

It is extremely important that the foam concentrate after dilution with water to the recommended concentration should not in normal usage present a significant toxic hazard to life in relation to the environment. The current version of Commission Directive 2006/60/CE, Regulations (EC) No 1272/2008 and No 1907/2006 apply when considering the testing of ecotoxicological properties and safety in the work environment.

1 Scope

This draft European Standard specifies requirements for chemical and physical properties, and minimum performance requirements of low expansion foams suitable for surface application to water-immiscible liquids. Requirements are also given for marking.

Type approval needs to be executed by independent third party laboratories.

WARNING: Any type approval according to this standard is invalidated by any change in composition of the approved product.

NOTE Some concentrates conforming to this part of EN 1568 can also conform to other parts and therefore can also be suitable for application as medium and/or high expansion foams, and for application at low expansion to water-miscible liquids.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1568-1, *Fire extinguishing media — Foam concentrates — Part 1: Specification for medium expansion foam concentrates for surface application to water-immiscible liquids*

EN 1568-2, *Fire extinguishing media — Foam concentrates — Part 2: Specification for high expansion foam concentrates for surface application to water-immiscible liquids*

EN 1568-4, *Fire extinguishing media — Foam concentrates — Part 4: Specification for low expansion foam concentrates for surface application to water-miscible liquids*

EN ISO 3104, *Petroleum products — Transparent and opaque liquids — Determination of kinematic viscosity and calculation of dynamic viscosity (ISO 3104)*

EN ISO 3219, *Plastics — Polymers/resins in the liquid state or as emulsions or dispersions — Determination of viscosity using a rotational viscometer with defined shear rate (ISO 3219)*

EN ISO 11348-2, *Water quality — Determination of the inhibitory effect of water samples on the light emission of *Vibrio fischeri* (Luminescent bacteria test) — Part 2: Method using liquid-dried bacteria (ISO 11348-2)*

EN ISO 23753-1, *Soil Quality — Determination of dehydrogenase activity in soil — Part 1: Method using triphenyltetrazolium chloride (TTC) (ISO 23753-1)*

ISO 304, *Surface active agents — Determination of surface tension by drawing up liquid films*

ISO 3310-1, *Test sieves — Technical requirements and testing — Part 1: Test sieves of metal wire cloth*

OECD 201, *Test No. 201: Freshwater Alga and Cyanobacteria, Growth Inhibition Test*

OECD 202, *Test No. 202: Daphnia sp. Acute Immobilisation Test*

OECD 203, *Test No. 203: Fish, Acute Toxicity Test*

OECD 301, *Test No. 301: Ready Biodegradability*

OECD 404, *Test No. 404: Acute Dermal Irritation/Corrosion*

prEN 1568-3:2016 (E)

OECD 405, *Test No. 405: Acute Eye Irritation/Corrosion*

OECD 420, *Test No. 420: Acute Oral Toxicity - Fixed Dose Procedure*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1**25 %/50 % drainage time**

time taken for 25/50 % of the volume of the original foam solution to drain out of the generated foam

3.2**expansion****expansion value****expansion ratio**

ratio of the volume of foam to the volume of the foam solution from which it was made

3.3**low expansion foam**

foam which has an expansion ratio less than 20

3.4**medium expansion foam**

foam which has an expansion ratio greater than or equal to 20 but less than 200 even after temperature conditioning

3.5**high expansion foam**

foam which has an expansion ratio greater than or equal to 200 even after temperature conditioning

3.6**fire-fighting foam**

aggregate of air filled bubbles formed from a foam solution used for fire-fighting

3.7**foam concentrate**

liquid which is diluted with water to produce foam solution

Note 1 to entry: Annex A gives information on grades of foam concentrate.

3.8**foam solution**

solution of foam concentrate in water

3.9**gentle application**

application (of foam from the test nozzle) indirectly to the surface of the fuel from a backboard

Note 1 to entry: This definition of gentle application relates to the fire test procedures used in EN 1568-3 and -4. In practice fire-fighting systems foam can also be applied gently by fixed foam pourers or by indirect application via a tank wall or other surface.

3.10**forceful application**

application (of foam from the test nozzle) directly onto the surface of the fuel

3.11**sediment**

insoluble particles in the foam concentrate

3.12**Newtonian foam concentrates**

foam concentrates which have a viscosity which is independent of the shear rate

3.13**pseudo-plastic foam concentrates**

foam concentrates which have a viscosity which decreases with increasing shear rate

3.14**surface tension**

tension within the interface between a liquid and air

3.15**interfacial tension**

tension within the interface between two immiscible liquids

3.16**freezing point**

temperature at which the first ingredient of a mixture starts to solidify or freeze

3.17**designation****identifying name**

name that corresponds to a chemical formulation and a specific production process

Note 1 to entry: It guarantees consistency of the characteristics, performance and conditions of use of the foam concentrate.

4 Sediment in the foam concentrate**4.1 Sediment before ageing**

Any sediment in the foam concentrate sampled in accordance with Annex B, but not aged in accordance with C.1, shall be dispersible through a 180 μm sieve, and the percentage volume of sediment shall be not more than 0,25 % when tested in accordance with Annex C.

4.2 Sediment after ageing

Any sediment in the foam concentrate sampled in accordance with Annex B, and aged in accordance with C.1, shall be dispersible through a 180 μm sieve and the percentage volume of sediment shall be not more than 1,0 % when tested in accordance with Annex C.

prEN 1568-3:2016 (E)**5 Freezing point**

The freezing point of the foam concentrate sampled in accordance with Annex B shall be determined in accordance with Annex K.

6 Viscosity of the foam concentrate**6.1 Newtonian foam concentrates**

The viscosity of the foam concentrate at the lowest temperature for use claimed by the manufacturer shall be determined in accordance with EN ISO 3104. If the viscosity is $> 200 \text{ mm}^2 \text{ s}^{-1}$, the container shall be marked in accordance with Clause 15 l).

6.2 Pseudo-plastic foam concentrates

The viscosity of the foam concentrate shall be determined in accordance with Annex D. If the viscosity at the lowest temperature for use is greater than or equal to $120 \text{ mPa}\cdot\text{s}$ at 375 s^{-1} , the container shall be marked in accordance with Clause 15 m).

7 pH of the foam concentrate

The pH of the foam concentrate sampled in accordance with Annex B shall be not less than 6,0 and not more than 9,5 at $(20 \pm 1) ^\circ\text{C}$.

8 Surface tension of the foam solution

The surface tension (determined in accordance with F.2) of the foam solutions prepared using top and bottom half-samples (see E.4) of the foam concentrate sampled in accordance with Annex B and conditioned in accordance with Annex E shall be not less than 0,95 times and not more than 1,05 times the surface tension of the foam solution prepared using the sampled foam concentrate.

9 Evaluation of aqueous film formation

For any foam concentrate claimed to be film forming or aqueous film forming (e.g. AFFF, FFFP) cyclohexane shall not catch fire when tested in accordance with Annex L before and after conditioning to Annex E

10 Expansion and drainage of foam**10.1 Before temperature conditioning**

The foam produced from the foam solution prepared from the foam concentrate sampled in accordance with Annex B, at the supplier's recommended concentration with simulated fresh water shall be tested in accordance with Annex G. If appropriate, a further sample for the same concentration made with the simulated sea water in accordance with G.4 shall also be tested.

10.2 After temperature conditioning

The foams produced from the solutions prepared with simulated fresh water by using top and bottom half-samples, see E.4, of foam concentrate, sampled in accordance with Annex B, at the supplier's recommended concentration, when tested in accordance with Annex G, shall have the following;

- a) expansions which do not differ from each other or from the value obtained in 10.1 using simulated fresh water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using simulated fresh water; and
- b) 25 % drainage times which do not differ from each other or from the value obtained in 10.1 using simulated fresh water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using simulated fresh water.

If appropriate repeat the tests using top and bottom half-samples, see E.4, of foam concentrate, sampled in accordance with Annex B, at the supplier's recommended concentration, using foam solutions prepared with the simulated sea water in accordance with G.4. These foam solutions shall have the following:

- c) expansions which do not differ from each other or from the value obtained in 10.1 using the simulated sea water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using the simulated sea water in accordance with G.4; and,
- d) 25 % drainage times which do not differ from each other or from the value obtained in 10.1 using the simulated sea water (i.e. before temperature conditioning) by more than 20 % of the value obtained in 10.1 using the simulated sea water in accordance with G.4.

11 Test fire performance

The foam produced from the foam solutions, prepared using the foam concentrate sampled in accordance with Annex B at the supplier's recommended concentration with simulated fresh water and if appropriate at the same concentration with the simulated sea water in accordance with G.4, shall have an extinguishing performance class and burn-back resistance level as specified in Table 1 when tested in accordance with H.2 and H.3 and/or H.4 as appropriate.

NOTE 1 The values obtained with sea water can differ from those obtained with simulated fresh water.

NOTE 2 Annex I describes a small scale fire test which can be suitable for quality control purposes.

Table 1 — Maximum extinction times and minimum burn-back times

Times in minutes

Extinguishing performance class	Burn-back resistance level	Gentle application test (see H.3)		Forceful application test (see H.4)	
		Extinction time not more than min	25 % Burn-back time not less than min	Extinction time not more than min	25 % Burn-back time not less than min
I+	A			1,5	10
	B		15	1,5	
	C		10	1,5	
	D		5	1,5	
I	A			3	10
	B		15	3	
	C		10	3	
	D		5	3	
II	A			4	10
	B		15	4	
	C		10	4	
	D		5	4	
III	B	5	15		
	C	5	10		
	D	5	5		

NOTE 1 There is no burn-back resistance level A for class III.

NOTE 2 Typical extinguishing performance classes and burn-back resistance levels for different types of foam concentrate are given in Annex A.

12 Stability/Separation test

The foam concentrate tested in accordance with Annex M shall not separate stratify or precipitate.

13 Occupational health and ecotoxicological evaluation

Foam concentrate shall be tested for their occupational health and toxicological properties in accordance with Annex N.

14 Technical data sheet

The manufacturer should use the template as given in Annex O to provide information for the foam concentrate.

15 Container marking

Markings on shipping containers should be permanent and legible. The following information shall be marked on the packaging or transport container:

- the designation (identifying name) of the concentrate;

- b) the words “low expansion fire-fighting foam concentrate” and the number and date of this draft European Standard (i.e. prEN 1568-3:2016);

NOTE For low expansion concentrates which also conform to other parts of EN 1568 additional markings can be used as given in those parts.

- c) if the concentrate conforms to Clause 9 the words “aqueous film-forming”;
- d) recommended usage concentration (most commonly 1 %, 3 % or 6 %);
- e) any tendency of the foam concentrate to cause harmful physiological effects, the methods needed to avoid them and the first aid treatment if they should occur;
- f) recommended maximum storage temperature and lowest temperature for use;
- g) if the manufacturer advises that the foam concentrate is adversely affected by low temperature storage according to Annex E the words 'Do not freeze';
- h) the nominal quantity in the container;
- i) the supplier's name and address;
- j) the batch number and the date of manufacture;
- k) the words “Not suitable for use with sea water” or “Suitable for use with sea water” as appropriate;
- l) if the foam concentrate is Newtonian and the viscosity at the lowest temperature for use is more than 200 mm² s⁻¹ when measured in accordance with EN ISO 3104 the words “This concentrate can require special proportioning equipment”;
- m) if the foam concentrate is pseudo-plastic and the viscosity at the lowest temperature for use is greater than or equal to 120 mPa.s at 375 s⁻¹ the words “Pseudo-plastic foam concentrate. This concentrate can require special proportioning equipment”; and
- n) the lowest extinguishing performance class and the lowest burn-back resistance level obtained during testing to each part of EN 1568 (if tested to more than one part) with all fuels in potable water and sea water.