



SLOVENSKI STANDARD

SIST EN 1287:2017

01-oktober-2017

Nadomešča:
SIST EN 1287:2000

Sanitarne armature - Nizkotlačni termostatski mešalni ventili - Splošne tehnične zahteve

Sanitary tapware - Low pressure thermostatic mixing valves - General technical specification

Sanitärarmaturen - Thermostatische Mischer für die Anwendung im Niederdruckbereich - Allgemeine technische Spezifikation

Robinetterie sanitaire - Mitigeurs thermostatiques basse pression - Spécifications techniques générales

Ta slovenski standard je istoveten z: EN 1287:2017

ICS:

91.140.70 Sanitarne naprave Sanitary installations

SIST EN 1287:2017 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 1287:2017](https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017)

<https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017>

EUROPEAN STANDARD

EN 1287

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2017

ICS 91.140.70

Supersedes EN 1287:1999

English Version

Sanitary tapware - Low pressure thermostatic mixing valves - General technical specification

Robinetterie sanitaire - Mitigeurs thermostatiques
basse pression - Spécifications techniques générales

Sanitärarmaturen - Thermostatische Mischer für die
Anwendung im Niederdruckbereich - Allgemeine
technische Spezifikation

This European Standard was approved by CEN on 24 April 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European Foreword.....	6
Introduction	7
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Symbols and units	10
5 Classification.....	11
6 Designation.....	11
7 Marking/identification	12
7.1 Marking.....	12
7.2 Identification	12
8 Materials.....	12
8.1 Chemical and hygiene requirements	12
8.2 Exposed surface condition and quality of coating.....	12
9 Dimensional characteristics.....	12
9.1 General remarks.....	12
9.2 Inlet dimensions.....	12
9.3 Outlet dimensions.....	15
9.4 Mounting dimensions.....	17
9.5 Special cases.....	20
9.6 Flexible hoses for outlet 2	20
9.7 Outlet 2.....	20
10 Backflow protection.....	20
11 Test sequence	21
12 Leaktightness.....	21
12.1 General.....	21
12.1.1 Principle	21
12.1.2 Apparatus.....	21
12.2 Leaktightness of the obturator and upstream.....	21
12.2.1 General.....	21
12.2.2 Procedure.....	21
12.2.3 Requirements	21
12.3 Cross-flow between inlets.....	22
12.3.1 General.....	22
12.3.2 Procedure.....	22
12.3.3 Requirements	22
12.4 Leaktightness downstream of the obturator	22
12.4.1 Procedure.....	22
12.4.2 Requirements	22
12.5 Leaktightness of manually operated diverter	22
12.5.1 Procedure.....	22
12.5.2 Requirement.....	23

12.6	Leaktightness of diverter with automatic return	23
12.6.1	Procedure	23
12.6.2	Requirement.....	23
13	Performance	23
13.1	General	23
13.1.1	Initial settings	23
13.1.2	Apparatus	24
13.1.3	Procedure	24
13.2	Determination of flow rate.....	25
13.2.1	Principle.....	25
13.2.2	Procedure	25
13.2.3	Evaluation of the results	25
13.2.4	Requirements.....	25
13.3	Sensitivity	26
13.3.1	General	26
13.3.2	Principle.....	26
13.3.3	Procedure	26
13.3.4	Evaluation of results.....	26
13.3.5	Requirements.....	27
13.4	Fidelity.....	28
13.4.1	General	28
13.4.2	Principle.....	28
13.4.3	Procedure	28
13.4.4	Evaluation of results.....	28
13.4.5	Requirements.....	28
13.5	Temperature stability.....	29
13.5.1	Temperature control operation.....	29
13.5.2	Flow rate reduction.....	29
13.5.3	Cold supply failure and restoration.....	30
13.5.4	Supply pressure variation	31
13.5.5	Supply temperature variation	32
13.5.6	Temperature override stops	32
14	Pressure resistance.....	33
14.1	General	33
14.2	Apparatus	33
14.3	Testing of mechanical performance of the thermostatic mixing valve upstream of the obturator in the closed position.....	33
14.3.1	Procedure	33
14.3.2	Requirement.....	33
14.4	Mechanical behaviour downstream of the obturator – Obturator in the open position	34
14.4.1	Procedure	34
14.4.2	Requirement.....	34
15	Torsional resistance of the operating controls.....	34
15.1	General	34
15.2	Test method.....	34
15.2.1	Principle.....	34
15.2.2	Apparatus	34
15.2.3	Procedure	34
15.2.4	Requirements.....	35
16	Mechanical endurance characteristics	35
16.1	General	35

EN 1287:2017 (E)

16.2	Endurance test for single sequential control device	35
16.2.1	Principle	35
16.2.2	Apparatus.....	35
16.2.3	Procedure.....	36
16.2.4	Requirement.....	36
16.3	Endurance test for on/off flow control device operated by rotating the control handle.....	36
16.3.1	Principle	36
16.3.2	General.....	36
16.4	Endurance test for on/off flow control device, combined with diverter mechanism	36
16.4.1	Principle	36
16.4.2	Apparatus.....	36
16.4.3	Procedure.....	37
16.4.4	Requirement.....	37
16.5	Endurance test for other on-off flow control device	37
16.5.1	Principle	37
16.5.2	Apparatus.....	37
16.5.3	Procedure.....	37
16.5.4	Requirement.....	38
16.6	Mechanical endurance of diverters of thermostatic mixing valves	38
16.6.1	General.....	38
16.6.2	Test method	38
16.6.3	Requirements.....	39
16.7	Mechanical endurance of swivel of spouts.....	40
16.7.1	General.....	40
16.7.2	Test method	40
16.7.3	Requirements.....	40
16.8	Thermal element.....	40
16.8.1	Principle	40
16.8.2	Temperature adjustable valves, (Type 1, 2, 4).....	41
16.8.3	Temperature set valves (Type 5)	41
16.8.4	Other valves with special control devices (Type 6).....	42
Annex A	(normative) Test set-up descriptions.....	43
A.1	General.....	43
A.2	Inlet pipework.....	43
A.2.1	Thermostat endurance.....	43
A.2.2	Performance	44
A.3	Outlet pipework.....	44
A.3.1	General.....	44
A.3.2	Outlet for valves except without integral atmospheric discharge spouts.....	44
Annex B	(normative) Measurements	48
B.1	Pressure.....	48
B.2	Flow	48
B.3	Temperature.....	48
B.3.1	Mounting	48
B.3.2	Accuracy	48

B.3.3	Response time.....	48
B.4	Angular position.....	48
B.5	Duration of transients.....	48
Annex C (informative)	Temperature transit.....	51
C.1	Positive temperature transient.....	51
C.2	Negative temperature transient.....	52
Annex D (normative)	Hydraulic resistance for low pressure diverters with automatic return.....	53
Bibliography	55

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 1287:2017](https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017)

<https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017>

EN 1287:2017 (E)**European Foreword**

This document (EN 1287:2017) has been prepared by Technical Committee CEN/TC 164 “Water supply”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2018, and conflicting national standards shall be withdrawn at the latest by February 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1287:1999.

The main technical changes compared to the previous version are the following:

- a) the introduction of Clause 10 on backflow protection;
- b) the introduction of Clause 11 on test sequence;
- c) the introduction of Clause 13 on performance;
- d) the update of clauses on pressure resistance, torsional resistance and mechanical resistance;
- e) new Annexes A, B, C and D.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this standard, the following should be noted:

This standard provides no information as to whether the product can be used without restriction in any of the Member state of the EU or EFTA.

It should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 1287:2017](https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017)

<https://standards.iteh.ai/catalog/standards/sist/27c07787-aaf4-4ef6-94cb-e31ea24ab863/sist-en-1287-2017>

EN 1287:2017 (E)

1 Scope

This European Standard specifies general construction, performance and material requirements for PN 10 thermostatic mixing valves (TMV) and includes test methods for the verification of mixed water temperature performance at the point of use below 45 °C. This does not exclude the selection of higher temperatures where available. When these devices are used to provide anti-scald protection for children, elderly and disabled persons the mixed water temperature needs to be set at a suitable bathing temperature (body temperature - 38 °C) as children are at risk to scalding at lower temperatures than adults. This does not obviate the need for supervision of young children during bathing.

It applies to valves intended for use on sanitary appliances in kitchens, washrooms (incl. all rooms with sanitary tapware, e.g. toilet and cloakrooms) and bathrooms operating under the conditions specified in Table 1.

This standard allows TMVs to supply a single outlet or a small number of outlets in a “domestic” application (e.g. one valve, controlling a shower, bath, basin and/or, bidet), excluding valves specifically designed for supplying a large number of outlets (i.e. for institutional use).

The tests described are type tests (laboratory tests) and not quality control tests carried out during manufacture.

Table 1 — Conditions of use

Supply	Operating range ^a	
Pressure	limits	recommended
Static	≤ 1 MPa [≤10 bar]	
Dynamic	≥ 0,01 MPa [≥0,1 bar]	(0,02 to 0,1) MPa [(0,2 to 1,0) bar]
Temperature		
Hot	≤ 90 °C	(55 to 65) °C
Cold	≤ 25 °C	(5 to 20) °C
^a For low pressure thermostatic mixing valves complying with this table there are no acoustical requirements. Low pressure thermostatic mixing valves complying with this standard may also be used with inlet supply pressures in the range from 0,1 MPa to 0,2 MPa (1,0 bar to 2,0 bar) on condition that acoustical performance is not a requirement of the installation.		
NOTE Low pressure thermostatic mixing valves are designed to provide sufficient mechanical strength for operation at 1 MPa (10 bar) static pressure.		

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 200, *Sanitary tapware - Single taps and combination taps for water supply systems of type 1 and type 2 - General technical specification*

EN 246, *Sanitary tapware - General specifications for flow rate regulators*

EN 248, *Sanitary tapware - General specification for electrodeposited coatings of Ni-Cr*

EN 1057, *Copper and copper alloys — Seamless, round copper tubes for water and gas in sanitary and heating applications*

EN 1112, *Sanitary tapware - Shower outlets for sanitary tapware for water supply systems of type 1 and type 2 - General technical specification*

EN 1113, *Sanitary tapware - Shower hoses for sanitary tapware for water supply systems of type 1 and type 2 - General technical specification*

EN 1717, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow*

EN 13618, *Flexible hose assemblies in drinking water installations - Functional requirements and test methods*

EN 13959, *Anti-pollution check valves - DN 6 to DN 250 inclusive family E, type A, B, C and D*

EN 14506, *Devices to prevent pollution by backflow of potable water - Automatic diverter - Family H, type C*

EN 16145, *Sanitary tapware - Extractable outlets for sink and basin mixers - General technical specification*

EN 60584 (all parts), *Thermocouples (IEC 60584)*

EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads - Part 1: Dimensions, tolerances and designation (ISO 228-1)*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 1: General principles and requirements (ISO 5167-1)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

thermostatic mixing valve

TMV

valve, with one or more outlets, which mixes hot and cold water and automatically controls the mixed water to a selected temperature

3.2

fidelity

reproduceability and accuracy of temperature selection

3.3

obturator

movable component of the valve whose position in the fluid flow path permits, restricts or obstructs the fluid flow

Note 1 to entry: The flow rate between no flow and maximum flow conditions can be affected either by the same control device or a separate flow control device, where fitted.

EN 1287:2017 (E)

3.4

outlet 1

default position of the diverter

3.5

outlet 2

outlet(s) other than outlet 1

4 Symbols and units

For the purposes of this document, the symbols and units given in Table 2 apply.

Table 2 — Symbols and units

Symbol	Characteristic	Unit
D	internal diameter of tube or casing	mm
f	thickness of the annular slit of Type C pressure take-off tees	mm
i	width of the annular slit of Type C pressure take-off tees	mm
ϑ_{PP}	temperature peak to peak	°C
p_c	pressure of cold water supply	MPa (bar)
p_h	pressure of hot water supply	MPa (bar)
Q_c	flow rate of cold water	l/s (l/min)
Q_h	flow rate of hot water	l/s (l/min)
$Q_c + Q_h$	flow rate of mixed water	l/s (l/min)
t_0	time when equilibrium is disturbed	s
t_1	time when $\vartheta_{mix} = \vartheta_0 + \vartheta_x$	s
t_2	$= t_1 + 1$ s	s
t_3	$= 5$ s	s
T_c	temperature of cold water supply	°C
T_h	temperature of hot water supply	°C
T_m	temperature of mixed water	°C
x_1	distance	mm
x_2	distance	mm
ϑ_0	set temperature	°C
ϑ_x	temperature amplitude	°C
ϑ_c	cold water temperature (Outlet temperature)	°C
ϑ_h	hot water temperature (Outlet temperature)	°C
ϑ_{mix}	mixed water temperature	°C

5 Classification

The classification covers the following types of TMVs:

- a) Type 1 - Single control: valves with a single control device regulating flow and temperature; (actuator movement in two planes);
- b) Type 2 - Dual control: valves with separate control devices regulating flow and temperature;
- c) Type 3 - Single sequential control: valves with a single control operating through a predetermined sequence of flow and temperature. These shall have a shut-off device; (actuator movement in one plane);
- d) Type 4 - TMVs without flow control device;
- e) Type 5 - Pre-set: valves not adjustable by the user of a sanitary appliance;
- f) Type 6 - Other: valves with special control devices.

6 Designation

TMVs covered by this standard are designated as follows:

- a) its nominal inlet size, with or without diverter (see Table 3);
- b) type of body (see Table 3);
- c) type of outlet (see Table 3);
- d) the sanitary appliance on which it shall be used (Table 3);
- e) the method of mounting (see Table 3);
- f) its acoustic group and flow rate classes (Clause 13);
- g) the reference to this standard (prEN 1287).

EXAMPLE TMV 1/2 with diverter, visible body, fixed nozzle outlet bath/shower, horizontal mounting, EN 1287.

Table 3 — Designation

Type of tap	TMV with or without diverter and type of diverter (if applicable)
Type of body	Single or multi-hole, exposed, or concealed
Type of outlet	Fixed, moveable, divided outlet spout, with or without flow rate regulator
Intended use	Basin, bidet, sink, bath or shower
Mounting method	Horizontal or vertical surfaces
Reference to this standard	EN 1287

7 Marking/identification

7.1 Marking

TMVs shall be permanently and legibly marked with:

- the manufacturer's or agent's name or identification on the body or handle.

7.2 Identification

The temperature control device for the valve shall be identified by means of a scale or symbols or colours or any combination thereof.

TMVs shall be legibly marked to indicate cold / hot inlets.

NOTE Exposed valves need only one identification of cold or hot inlet.

8 Materials

8.1 Chemical and hygiene requirements

All materials coming into contact with water intended for human consumption shall present no health risk nor cause any change of the drinking water in terms of quality, appearances, smell or taste.

8.2 Exposed surface condition and quality of coating

Visible chromium plated surfaces and Ni-Cr coatings shall comply with the requirements of EN 248.

9 Dimensional characteristics

9.1 General remarks

The design and construction of components without defined dimensions permits various design solutions to be adopted by the manufacturer.

Special cases are covered in 9.5.

9.2 Inlet dimensions

Inlet dimensions shall be as specified in Table 4, Figure 1, Figure 2 and Figure 3.

Table 4 — Inlet dimensions (Single- and multi-hole combination taps)

Inlet dimensions			Comments
Shank, Union, Captive nut			
<i>A</i>	G 1/2 B	Shank, Union	In accordance with EN ISO 228-1
<i>A 1</i>	G 3/4 B		
<i>A 2</i>	9 mm min	Captive nut	Useful thread length
<i>A 3</i>	15 mm min	Shank, Union (straight or eccentric)	
Connecting centres			
<i>G a</i>	(150 ± 1) mm	2 - hole wall mounted	Supply connection, Straight unions
<i>G 1</i>	(140 to 160) mm		— with eccentric unions (extension of this range is permitted)
<i>G a</i>	(150 ± 1) mm	Multi-hole combination tap	
<i>G 2</i>	(200 ± 3,5) mm		
<i>G 3</i>	(180 ± 5) mm		
Inlet connections			
<i>N 1</i>	(12,3 + 0,2) mm	Type A size 1/2	
<i>N 2</i>	5 mm min		
<i>N 1</i>	(15,2 ± 0,05) mm	Type B size 1/2 30° chamfer/flat 0,3	
<i>N 2</i>	13 mm min		
<i>N 1</i>	(14,7 + 0,3) mm	Type C size 1/2	
<i>N 2</i>	6,4 mm min		
<i>N 1</i>	(19,9 + 0,3) mm	Type C size 3/4	
<i>N 2</i>	6,4 mm min		