



SLOVENSKI STANDARD
oSIST prEN 16866:2015

01-september-2015

Kovinske in druge anorganske prevleke - Istočasno določevanje debeline in potenciala elektrode posameznih plasti v večplastnih nikljevih depozitih (preskus STEP)

Metallic and other inorganic coatings - Simultaneous thickness and electrode potential determination of individual layers in multilayer nickel deposits (STEP test)

Metallische und andere anorganische Überzüge - Schichtpotentialmessung von galvanischen Mehrfach-Nickelschichtsystemen (STEP-Test)

Revêtements métalliques et autres revêtements inorganiques - Détermination simultanée de l'épaisseur et du potentiel d'électrode de couches individuelles dans des dépôts de nickel multicouches (essai STEP)

Ta slovenski standard je istoveten z: prEN 16866

ICS:

25.220.40 Kovinske prevleke Metallic coatings

oSIST prEN 16866:2015

en,fr,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 16866

May 2015

ICS 25.220.40

English Version

**Metallic and other inorganic coatings - Simultaneous thickness
and electrode potential determination of individual layers in
multilayer nickel deposits (STEP test)**

Revêtements métalliques et autres revêtements
inorganiques - Détermination simultanée de l'épaisseur et
du potentiel d'électrode de couches individuelles dans des
dépôts de nickel multicouches (essai STEP)

Metallische und andere anorganische Überzüge -
Schichtpotentialmessung von galvanischen Mehrfach-
Nickelschichtsystemen (STEP-Test)

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 262.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents		Page
Foreword.....		3
Introduction		4
1 Scope		5
2 Normative references		5
3 Test equipment		5
3.1 Construction of the measuring cell		5
3.2 Composition of the test solution.....		6
4 Requirements		7
5 Sampling.....		7
6 Factors influencing measurement accuracy		7
6.1 Electrolyte.....		7
6.2 Conditioning.....		7
6.3 Ni deposits.....		7
6.4 Surface cleanliness		7
6.5 Contact pressure		7
6.6 Electrical contact		8
6.7 Complete dissolution		8
7 Procedure		8
7.1 General.....		8
7.2 Measurement.....		8
7.3 Evaluation.....		8
8 Measurement uncertainty		12
9 Test report		12
Bibliography		14

Foreword

This document (prEN 16866:2015) has been prepared by Technical Committee CEN/TC 262 “Metallic and other inorganic coatings”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

Introduction

STEP test is an abbreviation for the term “Simultaneous Thickness and Electrode Potential determination”.

The STEP test can be used to measure, in one single operating step, the parameters (thickness of the individual nickel layers and the potential differences among them) relevant for the course of corrosion in a multilayer nickel system and, provided the suitable instruments be applied, to document them as well.

The test is a modification of the well-known coulometric method for the measurement of the coating thickness. This method takes advantage of the fact that, following the anodic dissolution of a nickel coating, a potential jump takes place whose magnitude can be measured against a reference electrode.

Although, nowadays, the STEP test has been incorporated into a number of company standards, particularly in the automobile industry, so far no uniform and generally acknowledged potential difference values are available. At present, values between 80 mV and 150 mV are assumed for double nickel layers, with the semi-bright nickel layer always being nobler than the bright one.

Likewise no obligatory numerical values are available, so far, regarding the potential difference between bright nickel layers and existing special nickel layers (e.g. in the case of micro-porous chromium plating). According to the current practical experience, the potential difference is larger than approximately 20 mV, with the bright nickel layer always having to be less noble than the special nickel layer.

1 Scope

This European Standard applies to the measurement of the thickness of the individual nickel layers in electroplated multilayer nickel coatings and to the measurement of the potential differences between the individual nickel layers in electroplated multilayer nickel coatings.

The measurement of coatings or layer systems other than electroplated multilayer nickel coatings is outside the scope of this European Standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 2177, *Metallic coatings - Measurement of coating thickness - Coulometric method by anodic dissolution (ISO 2177)*

EN ISO 3696, *Water for analytical laboratory use - Specification and test methods (ISO 3696)*

3 Test equipment


3.1 Construction of the measuring cell

Figure 1 shows two examples of the typical schematic construction of a measuring cell used for the simultaneous determination of layer thicknesses and potential differences in multilayer nickel systems. The cells differ with regard to the implementation of the reference electrode. In Figure 1 a), the reference electrode is a silver wire coated with silver chloride and positioned at the edge of the cell; in Figure 1 b), it is a silver ring coated with silver chloride and positioned at the bottom of the cell. With regard to measurement uncertainty, both variants provide the same result for the measurement of the potential difference and (following calibration) the measurement of the layer thickness, independent of the concrete implementation of the reference electrode.

NOTE 1 The silver ring used as the reference electrode in Figure 1 b) is of advantage insofar as the adjustment of the silver wire, which would otherwise be required, becomes unnecessary, leading to results that are more exact and more reproducible.

NOTE 2 The circulated volume of electrolyte solution is typically some 0,1 ml per second.

prEN 16866:2015 (E)



a) Measuring cell with silver wire, coated with AgCl, used as the reference electrode

b) Measuring cell with silver ring, coated with AgCl in the electrolyte-wetted area, used as the reference electrode

Key

- 1 pump
- 2 measuring instrument (with constant-current source and voltmeter)
- 3 reference electrode
- 4 electrode surface wetted with electrolyte
- 5 dissolving electrolyte
- 6 counter electrode (cathode)
- 7 gasket
- 8 working electrode (anode, measurement object with nickel layer system)

Figure 1 — Typical schematic constructions of the measuring cell

3.2 Composition of the test solution

Nickel(II)-chloride hexahydrate ($\text{NiCl}_2 \cdot 6 \text{H}_2\text{O}$)	300 g/l
Sodium chloride (NaCl)	50 g/l
Boric acid (H_3BO_3)	25 g/l
pH value	3,0

Water of grade 3 in accordance with EN ISO 3696

The pH value should be complied with as closely as possible. If required it is adjusted by means of diluted hydrochloric acid or sodium hydroxide solution.