



SLOVENSKI STANDARD

SIST EN 61158-4-3:2015

01-marec-2015

Nadomešča:

SIST EN 61158-4-3:2012

**Industrijska komunikacijska omrežja - Specifikacije za procesna vodila - 4-3. del:
Specifikacija protokola na ravni podatkovnih povezav - Elementi tipa 3 (IEC 61158-
4-3:2014)**

Industrial communication networks - Fieldbus specifications - Part 4-3: Data-link layer
protocol specification - Type 3 elements (IEC 61158-4-3:2014)

iTeh STANDARD PREVIEW

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-3: Protokollspezifikation des Data
Link Layer (Sicherungsschicht) Typ 3-Elemente (IEC 61158-4-3:2014)

[SIST EN 61158-4-3:2015](#)

Réseaux de communication industriels des Spécifications des bus de terrain – Partie 4-3:
Spécification du protocole de la couche liaison de données - Éléments de type 3 (CEI
61158-4-3:2014)

Ta slovenski standard je istoveten z: EN 61158-4-3:2014

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.20	Podatkovni povezovalni sloj	Data link layer
35.110	Omreževanje	Networking

SIST EN 61158-4-3:2015

en,fr,de

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61158-4-3:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 61158-4-3

October 2014

ICS 25.040.40; 35.100.20; 35.110

Supersedes EN 61158-4-3:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 4-3: Data-link layer protocol specification - Type 3 elements
(IEC 61158-4-3:2014)**

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 4-3: Spécification du protocole de la couche liaison de données - Éléments de type 3
(CEI 61158-4-3:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-3:
Protokollspezifikation des Data Link Layer
(Sicherungsschicht) - Typ 3-Elemente
(IEC 61158-4-3:2014)

This European Standard was approved by CENELEC on 2014-09-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

THIS STANDARD PREVIEW

(standards.itech.ai)

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

SIST EN 61158-4-3:2015

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/762/FDIS, future edition 3 of IEC 61158-4-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-4-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-19

This document supersedes EN 61158-4-3:2012

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

THE STANDARD PREVIEW (standards.iteh.ai)

Endorsement notice

The text of the International Standard [IEC 61158-4-3:2014](#) was approved by CENELEC as a European Standard [without any modification](#) [dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015](#)

In the official version, for bibliography, the following notes have to be added for the standards indicated:

IEC 60870-5-1	NOTE	Harmonised as EN 60870-5-1
IEC 61158-1	NOTE	Harmonised as EN 61158-1
IEC 61158-5-3	NOTE	Harmonised as EN 61158-5-3
IEC 61158-6-3	NOTE	Harmonised as EN 61158-6-3
IEC 61784-1	NOTE	Harmonised as EN 61784-1
IEC 61784-2	NOTE	Harmonised as EN 61784-2

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-3	-	Programmable controllers Part 3: Programming languages	EN 61131-3	-
IEC 61158-2	2014	Industrial communication networks - Fieldbus specifications Part 2: Physical layer specification and service definition	EN 61158-2	2014
IEC 61158-3-3	-	Industrial communication networks - Fieldbus specifications Part 3-3: Data-link layer service definition - Type 3 elements	EN 61158-3-3	-
ISO/IEC 2022	-	Information technology - Character code structure and extension techniques	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic reference model: Naming and addressing	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO 1177	-	Information processing - Character structure for start/stop and synchronous character- oriented transmission	-	-

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN 61158-4-3:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015>



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 4-3: Data-link layer protocol specification – Type 3 elements
(standards.iteh.ai)**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 4-3: Spécification du protocole de la couche liaison de données – Éléments
de type 3**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX
XH

ICS 25.04€40; 35.100.20; 35.110

ISBN 978-2-8322-1721-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	6	
INTRODUCTION	8	
1 Scope	9	
1.1 General	9	
1.2 Specifications	9	
1.3 Procedures	9	
1.4 Applicability	9	
1.5 Conformance	10	
2 Normative references	10	
3 Terms, definitions, symbols and abbreviations	10	
3.1 Reference model terms and definitions	10	
3.2 Service convention terms and definitions	12	
3.3 Common terms and definitions	13	
3.4 Additional Type 3 definitions	15	
3.5 Common symbols and abbreviations	17	
3.6 Type 3 symbols and abbreviations	18	
4 Common DL-protocol elements	22	
4.1 Frame check sequence	22	
5 Overview of the DL-protocol	25	
5.1 General	25	
5.2 Overview of the medium access control and transmission protocol	25	
5.3 Transmission modes and DL-entity	26	
5.4 Service assumed from the PnL	https://standards.iteh.ai/catalog/standards/sist-en-61158-4-3:2015-1ca68589c178/sist-en-61158-4-3-2015	31
5.5 Operational elements	35	
5.6 Cycle and system reaction times	50	
6 General structure and encoding of DLPDUs, and related elements of procedure	53	
6.1 DLPDU granularity	53	
6.2 Length octet (LE, LEr)	54	
6.3 Address octet	54	
6.4 Control octet (FC)	57	
6.5 DLPDU content error detection	61	
6.6 DATA_UNIT	61	
6.7 Error control procedures	62	
7 DLPDU-specific structure, encoding and elements of procedure	63	
7.1 DLPDUs of fixed length with no data field	63	
7.2 DLPDUs of fixed length with data field	65	
7.3 DLPDUs with variable data field length	67	
7.4 Token DLPDU	68	
7.5 ASP DLPDU	69	
7.6 SYNCH DLPDU	69	
7.7 Time Event (TE) DLPDU	69	
7.8 Clock Value (CV) DLPDU	70	
7.9 Transmission procedures	70	
8 Other DLE elements of procedure	73	
8.1 DL-entity initialization	73	
8.2 States of the media access control of the DL-entity	74	

8.3 Clock synchronization protocol	80
Annex A (normative) DL-Protocol state machines	85
A.1 Overall structure.....	85
A.2 Variation of state machines in different devices	86
A.3 DL Data Resource	87
A.4 FLC / DLM.....	91
A.4.1 Primitive definitions	91
A.4.2 State machine description	96
A.5 MAC.....	115
A.5.1 Primitive definitions	115
A.5.2 State machine description	115
A.6 SRU	141
A.6.1 Overview	141
A.6.2 Character send SM(CTX).....	142
A.6.3 Character receive SM (CRX)	143
A.6.4 Timer-SM (TIM)	143
A.6.5 Primitive definition of SRC	144
A.6.6 State machine description	145
Annex B (informative) Type 3 (synchronous): exemplary FCS implementations.....	160
Annex C (informative) Type 3: Exemplary token procedure and message transfer periods	162
C.1 Procedure of token passing	162
C.2 Examples for token passing procedure	163
C.3 Examples for message transfer periods – asynchronous transmission	168
Bibliography.....	170
Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses	14
Figure 2 – Logical token-passing ring	28
Figure 3 – PhL data service for asynchronous transmission	32
Figure 4 – Idle time TID1	37
Figure 5 – Idle time TID2 (SDN, CS)	38
Figure 6 – Idle time TID2 (MSRD)	38
Figure 7 – Slot time TSL1	39
Figure 8 – Slot time TSL2	39
Figure 9 – Slot time TSL1	44
Figure 10 – Slot time TSL2	44
Figure 11 – Token transfer period	50
Figure 12 – Message transfer period.....	51
Figure 13 – UART character	53
Figure 14 – Octet structure	54
Figure 15 – Length octet coding.....	54
Figure 16 – Address octet coding.....	55
Figure 17 – DAE/SAE octet in the DLPDU.....	56
Figure 18 – Address extension octet	56
Figure 19 – FC octet coding for send/request DLPDUs	58
Figure 20 – FC octet coding for acknowledgement or response DLPDUs	58

Figure 21 – FCS octet coding	61
Figure 22 – Data field	62
Figure 23 – Ident user data	62
Figure 24 – DLPDUs of fixed length with no data field	64
Figure 25 – DLPDUs of fixed length with no data field	65
Figure 26 – DLPDUs of fixed length with data field	66
Figure 27 – DLPDUs of fixed length with data field	66
Figure 28 – DLPDUs with variable data field length	67
Figure 29 – DLPDUs with variable data field length	68
Figure 30 – Token DLPDU	68
Figure 31 – Token DLPDU	69
Figure 32 – Send/request DLPDU of fixed length with no data	70
Figure 33 – Token DLPDU and send/request DLPDU of fixed length with data	71
Figure 34 – Send/request DLPDU with variable data field length	71
Figure 35 – Send/request DLPDU of fixed length with no data	72
Figure 36 – Token DLPDU and send/request DLPDU of fixed length with data	72
Figure 37 – Send/request DLPDU with variable data field length	73
Figure 38 – DL-state-diagram	75
Figure 39 – Overview of clock synchronization	81
Figure 40 – Time master state machine	82
Figure 41 – Time receiver state machine	83
Figure 42 – Clock synchronization	84
Figure A.1 – Structuring of the protocol machines	86
Figure A.2 – Structure of the SRU Machine	142
Figure B.1 – Example of FCS generation for Type 3 (synchronous)	160
Figure B.2 – Example of FCS syndrome checking on reception for Type 3 (synchronous)	160
Figure C.1 – Derivation of the token holding time (T_{TH})	163
Figure C.2 – No usage of token holding time (T_{TH})	164
Figure C.3 – Usage of token holding time (T_{TH}) for message transfer (equivalence between T_{TH} of each Master station)	165
Figure C.4 – Usage of token holding time (T_{TH}) in different working load situations	167
Table 1 – FCS length, polynomials and constants by Type 3 synchronous	23
Table 2 – Characteristic features of the fieldbus data-link protocol	25
Table 3 – Transmission function code	59
Table 4 – FCB, FCV in responder	60
Table 5 – Operating parameters	73
Table A.1 – Assignment of state machines	87
Table A.2 – Data resource	88
Table A.3 – Primitives issued by DL-User to FLC	91
Table A.4 – Primitives issued by FLC to DL-User	92
Table A.5 – Primitives issued by DL-User to DLM	94
Table A.6 – Primitives issued by DLM to DL-User	94

Table A.7 – Parameters used with primitives exchanged between DL-User and FLC.....	95
Table A.8 – Parameters used with primitives exchanged between DL-User and DLM	95
Table A.9 – FLC/DLM state table	96
Table A.10 – FLC / DLM function table.....	108
Table A.11 – Primitives issued by DLM to MAC.....	115
Table A.12 – Primitives issued by MAC to DLM.....	115
Table A.13 – Parameters used with primitives exchanged between DLM and MAC	115
Table A.14 – Local MAC variables	116
Table A.15 – MAC state table	117
Table A.16 – MAC function table.....	137
Table A.17 – Primitives issued by DLM to SRC.....	144
Table A.18 – Primitives issued by SRC to DLM.....	144
Table A.19 – Primitives issued by MAC to SRC.....	144
Table A.20 – Primitives issued by SRC to MAC.....	145
Table A.21 – Parameters used with primitives exchanged between MAC and SRC	145
Table A.22 – FC structure	145
Table A.23 – Local variables of SRC.....	146
Table A.24 – SRC state table.....	147
Table A.25 – SRC functions	159

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

SIST EN 61158-4-3:2015
<https://standards.iteh.ai/catalog/standards/sist/dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 4-3: Data-link layer protocol specification –
Type 3 elements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
<https://standards.iec.ch/ctg/standardPreview?standard=SISTEN61158-4-3:2014&language=EN&id=1ca68589c178/sist-en-61158-4-3-2015>
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-4-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

The changes with respect to the previous edition are listed below:

- Corrections in Table A.15 and Table A.16;
- Expired patent removed and added new patents.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/762/FDIS	65C/772/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 61158-4-3:2015

<https://standards.iteh.ai/catalog/standards/sist/dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015>

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual property rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in its profile parts. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning Type 3 elements and possibly other types given in the normative elements of this standard.

The following patent rights for Type 3 have been announced by [SI]:

Publication	Title
EP 1253494	Control device with fieldbus

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured IEC that he/she is willing to negotiate licenses either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

[SI]: Siemens AG
CT IP M&A
Otto-Hahn-Ring 6
D-81739 Munich
Germany

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line databases of patents relevant to their standards. Users are encouraged to consult the databases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-3: Data-link layer protocol specification – Type 3 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to a pre-selected “master” subset of data-link entities in a cyclic asynchronous manner, sequentially to each of those data-link entities. Other data-link entities communicate only as permitted and delegated by those master data-link entities.

For a given master, its communications with other data-link entities can be cyclic, or acyclic with prioritized access, or a combination of the two.

iTeh STANDARD PREVIEW

This protocol provides a means of sharing the available communication resources in a fair manner. There are provisions for time synchronization and for isochronous operation.

1.2 Specifications

SIST EN 61158-4-3:2015

<https://standards.iteh.ai/catalog/standards/sist/dac531a6-c37b-4b77-bb22-1ca68589c178/sist-en-61158-4-3-2015>

This standard specifies

1ca68589c178/sist-en-61158-4-3-2015

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.