

SLOVENSKI STANDARD

SIST EN 61158-6-22:2015

01-marec-2015

Nadomešča:

SIST EN 61158-6-22:2012

Industrijska komunikacijska omrežja - Specifikacije za procesna vodila - 6-22. del: Specifikacija protokola na aplikacijski ravni - Elementi tipa 22 (IEC 61158-6-22:2014)

Industrial communication networks - Fieldbus specifications - Part 6-22: Application layer protocol specification - Type 22 elements (IEC 61158-6-22:2014)

iTeh STANDARD PREVIEW

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-22: Protokollspezifikation des Application Layer (Anwendungsschicht) - Typ 22-Elemente (IEC 61158-6-22:2014)

[SIST EN 61158-6-22:2015](#)

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 6-22: Spécification du protocole de la couche application - Éléments de type 22 (CEI 61158-6-22:2014)

Ta slovenski standard je istoveten z: EN 61158-6-22:2014

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.70	Uporabniški sloj	Application layer
35.110	Omreževanje	Networking

SIST EN 61158-6-22:2015

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015>

EUROPEAN STANDARD

EN 61158-6-22

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2014

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN 61158-6-22:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 6-22: Application layer protocol specification - Type 22
elements
(IEC 61158-6-22:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 6-22: Spécification du protocole de la
couche application - Éléments de type 22
(CEI 61158-6-22:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-22:
Protokollspezifikation des Application Layer
(Anwendungsschicht) - Typ 22-Elemente
(IEC 61158-6-22:2014)

This European Standard was approved by CENELEC on 2014-09-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

[https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/764/FDIS, future edition 2 of IEC 61158-6-22, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-6-22:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-23

This document supersedes EN 61158-6-22:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a511111111/sist-en-61158-6-22-2015)
<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a511111111/sist-en-61158-6-22-2015>

Endorsement notice

The text of the International Standard IEC 61158-6-22:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-1	NOTE	Harmonized as EN 61158-1.
IEC 61784-1	NOTE	Harmonized as EN 61784-1.
IEC 61784-2	NOTE	Harmonized as EN 61784-2.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-3-22	-	Industrial communication networks - Fieldbus specifications - Part 3-22: Data-link layer service definition - Type 22 elements	EN 61158-3-22	-
IEC 61158-4-22	-	Industrial communication networks - Fieldbus specifications - Part 4-22: Data-link layer protocol specification - Type 22 elements	EN 61158-4-22	-
IEC 61158-5-22	-	Industrial communication networks - Fieldbus specifications - Part 5-22: Application layer service definition - Type 22 elements	EN 61158-5-22	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 8802-3	-	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO/IEC 8822	-	Information technology - Open Systems Interconnection - Presentation service definition	-	-
ISO/IEC 8824-1	-	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO/IEC/IEEE 60559	-	Information technology - Microprocessor Systems - Floating-Point arithmetic	-	-

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015>



IEC 61158-6-22

Edition 2.0 2014-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Industrial communication networks – Fieldbus specifications –
Part 6-22: Application layer protocol specification – Type 22 elements
(standards.iteh.ai)

Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 6-22: Spécification du protocole de la couche application – Éléments
de type 22
a5a52e8b6bc7/sist-en-61158-6-22-2015

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XD

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-1767-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications.....	10
1.3 Conformance.....	10
2 Normative references.....	10
3 Terms, definitions, abbreviations, symbols and conventions.....	11
3.1 Terms and definitions from other ISO/IEC standards.....	11
3.2 Fieldbus application-layer specific definitions.....	11
3.3 Abbreviations and symbols.....	15
3.4 Conventions.....	17
4 Application layer protocol specification.....	18
4.1 Operating principle.....	18
4.2 Device reference models.....	19
4.3 Application layer structure.....	21
5 FAL syntax description.....	21
5.1 Introduction and coding principles.....	21
5.2 Data type encoding.....	21
5.3 CeS encoding.....	25
5.4 ISO/IEC 8802-3 DLPDU communication inside Type 22 RTFL.....	71
5.5 Management encoding.....	71
6 FAL protocol state machines.....	72
6.1 Overview.....	72
6.2 Fieldbus service protocol machine (FSPM).....	74
6.3 Application relationship protocol machine (ARPM).....	74
6.4 DLL mapping protocol machine.....	74
7 AP-context state machine.....	74
8 FAL service protocol machine (FSPM).....	74
9 Application layer state machine (ALSM).....	75
9.1 Description.....	75
9.2 States.....	77
9.3 Primitive definitions.....	77
9.4 State table.....	78
9.5 AL-service forwarding depending on AL-state.....	79
10 DLL mapping protocol machine (DMPM).....	80
10.1 Overview.....	80
10.2 Primitives exchanged between ALSM and DMPM.....	80
10.3 Primitives exchanged between DLL and DMPM.....	84
10.4 ALSM to DLL mapping.....	86
Bibliography.....	87
Figure 1 – RTFL device reference model.....	20
Figure 2 – RTFN device reference model.....	21
Figure 3 – Encoding of TimeOfDay value.....	22

Figure 4 – Encoding of TimeDifference value	23
Figure 5 – Object dictionary addressing schema	26
Figure 6 – Relationships among protocol machines and adjacent layers	73
Figure 7 – ALSM protocol machine	74
Figure 8 – ALSM diagram	76
Table 1 – PDU element definition	18
Table 2 – Object definition	18
Table 3 – Transfer syntax for bit sequences	22
Table 4 – Transfer syntax for Integer data type	24
Table 5 – Transfer syntax for Unsigned data type	24
Table 6 – Object dictionary structure	25
Table 7 – Object dictionary object type definitions	26
Table 8 – Basic data type definitions	26
Table 9 – Complex data type definition	27
Table 10 – Communication section	28
Table 11 – Device type	30
Table 12 – Error register encoding	30
Table 13 – Error register	31
Table 14 – Object definition template	31
Table 15 – Encoding of event log entries	32
Table 16 – Event log	32
Table 17 – Manufacturer device name	33
Table 18 – Manufacturer HW version	33
Table 19 – Manufacturer SW version	33
Table 20 – CL configuration	34
Table 21 – Time sync IRQ configuration encoding	36
Table 22 – Time sync IRQ configuration	36
Table 23 – Time sync IRQ state	36
Table 24 – Store parameters read information	37
Table 25 – Store parameters	37
Table 26 – Restore parameters read information	39
Table 27 – Restore default parameters	39
Table 28 – Diagnostic information	40
Table 29 – Diagnostic threshold	43
Table 30 – IP address EMCY	45
Table 31 – Inhibit time EMCY	45
Table 32 – Encoding of consumer heartbeat entries	45
Table 33 – Consumer heartbeat list	46
Table 34 – Producer heartbeat parameter	47
Table 35 – Identity object	49
Table 36 – SDO protocol timeout	50
Table 37 – Enable client SDO parameter	50

Table 38 – Enable EMCY	51
Table 39 – PDO timeout tolerance	51
Table 40 – Store EDS	52
Table 41 – Storage format	52
Table 42 – OS command	52
Table 43 – OS command mode	53
Table 44 – OS debugger interface	54
Table 45 – OS prompt	55
Table 46 – Module list	56
Table 47 – Emergency subscriber encoding	57
Table 48 – Emergency subscriber	57
Table 49 – Client SDO parameter encoding	57
Table 50 – Client SDO parameter	58
Table 51 – Receive PDO communication parameter	58
Table 52 – Transmit PDO communication parameter	60
Table 53 – Mapping format	63
Table 54 – Receive PDO mapping parameter	63
Table 55 – Transmit PDO mapping parameter	64
Table 56 – Initiate SDO expedited download request	64
Table 57 – Initiate SDO expedited download response	65
Table 58 – Initiate SDO normal download request	65
Table 59 – Initiate SDO normal download response	65
Table 60 – SDO download request	65
Table 61 – SDO download response	66
Table 62 – Initiate SDO expedited upload request	66
Table 63 – Initiate SDO expedited upload response	66
Table 64 – Initiate SDO normal upload response	67
Table 65 – SDO upload request	67
Table 66 – SDO upload response	67
Table 67 – SDO abort request	67
Table 68 – SDO abort codes	68
Table 69 – Process data write request via MSC	69
Table 70 – Process data write request via CDC	69
Table 71 – Emergency request	69
Table 72 – Emergency error codes	69
Table 73 – Heartbeat request via MSC	70
Table 74 – Heartbeat request via CDC	71
Table 75 – Send frame request	71
Table 76 – Application layer management request	72
Table 77 – State transitions and management services	76
Table 78 – Primitives issued by ALSM to DLL	78
Table 79 – Primitives issued by DLL to ALSM	78
Table 80 – Primitives issued by FSPM to ALSM	78

Table 81 – Primitives issued by ALSM to FSPM	78
Table 82 – ALSM state table	79
Table 83 – Application layer states and communication services	79
Table 84 – Primitives issued by ALSM to DMPM	80
Table 85 – Primitives issued by DMPM to ALSM	82
Table 86 – Primitives issued by DMPM to DLL	84
Table 87 – Primitives issued by DLL to DMPM	85
Table 88 – ALSM to DLL mapping	86

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
 FIELDBUS SPECIFICATIONS –**
**Part 6-22: Application layer protocol specification –
 Type 22 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-6-22 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following technical changes with respect to the previous edition.

- Adopted revisions dates of cited standards.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/764/FDIS	65C/774/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015>

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[SIST EN 61158-6-22:2015](https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015)

<https://standards.iteh.ai/catalog/standards/sist/4e343eba-b80b-4e78-97fd-a5a52e8b6bc7/sist-en-61158-6-22-2015>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-22: Application layer protocol specification – Type 22 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 22 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible behavior provided by the different Types of the fieldbus Application Layer in terms of:

- a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities;
- b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities;
- c) the application context state machine defining the application service behavior visible between communicating application entities; and
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this standard is to define the protocol provided to:

- a) define the wire-representation of the service primitives defined in IEC 61158-5-22; and
- b) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can