



**SLOVENSKI STANDARD**  
**kSIST-TP FprCEN ISO/TR 52019-2:2017**  
**01-januar-2017**

---

**Energetska učinkovitost stavb - Higrotermalno obnašanje sestavnih delov stavb in elementov stavb - 2. del: Obrazložitev in utemeljitev (ISO/DTR 52019-2:2016)**

Energy performance of buildings - Hygrothermal performance of building components and building elements - Part 2: Explanation and justification (ISO/DTR 52019-2:2016)

Performance énergétique des bâtiments - Performances hygrothermiques des composants et parois de bâtiments - Partie 2: Explication et justification (ISO/DTR 52019-2:2016)

**Ta slovenski standard je istoveten z: FprCEN ISO/TR 52019-2**

---

**ICS:**

27.015	Energijska učinkovitost. Ohranjanje energije na splošno	Energy efficiency. Energy conservation in general
91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings

**kSIST-TP FprCEN ISO/TR 52019-2:2017 en**



TECHNICAL  
REPORT

ISO/TR  
52019-2

First edition

---

---

**Energy performance of buildings —  
Hygrothermal performance of  
building components and building  
elements —**

Part 2:  
**Explanation and justification**

*Performance énergétique des bâtiments — Performances  
hygrothermiques des composants et parois de bâtiments —  
Partie 2: Explication et justification*

**PROOF / ÉPREUVE**

---

---



Reference number  
ISO/TR 52019-2:2016(E)

© ISO 2016



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
copyright@iso.org  
www.iso.org

# Contents

Page

Foreword.....	iv
Introduction.....	v
<b>1 Scope.....</b>	<b>1</b>
<b>2 Normative references.....</b>	<b>1</b>
<b>3 Terms and definitions.....</b>	<b>1</b>
<b>4 Symbols and subscripts.....</b>	<b>1</b>
<b>5 Description of the methods.....</b>	<b>1</b>
5.1 Outputs.....	1
5.2 General description.....	2
<b>6 ISO 6946.....</b>	<b>3</b>
<b>7 ISO 10211.....</b>	<b>4</b>
<b>8 ISO 13370.....</b>	<b>4</b>
8.1 General.....	4
8.2 Thermal properties of the ground.....	4
8.3 The influence of flowing ground water.....	4
8.4 Application to dynamic simulation programmes.....	4
8.5 Embedded heating or cooling systems.....	4
8.6 Cold stores.....	4
<b>9 ISO 13786.....</b>	<b>4</b>
<b>10 ISO 13789.....</b>	<b>5</b>
<b>11 ISO 14683.....</b>	<b>5</b>
<b>Annex A (informative) ISO 13370: Thermal properties of the ground.....</b>	<b>6</b>
<b>Annex B (informative) ISO 13370: The influence of flowing ground water.....</b>	<b>8</b>
<b>Annex C (informative) ISO 13370: Application to dynamic simulation programmes.....</b>	<b>9</b>
<b>Annex D (informative) ISO 13370: Slab-on-ground floor with an embedded heating or cooling system.....</b>	<b>17</b>
<b>Annex E (informative) ISO 13370: Cold stores.....</b>	<b>18</b>
<b>Annex F (informative) ISO 13370: Worked examples.....</b>	<b>19</b>
<b>Annex G (informative) ISO 13786: Principle of the method and examples of applications.....</b>	<b>27</b>
<b>Annex H (informative) ISO 13786: Information for computer programming.....</b>	<b>31</b>
<b>Annex I (informative) ISO 13786: Examples.....</b>	<b>33</b>
<b>Annex J (informative) ISO 13789: Information on type of dimensions.....</b>	<b>36</b>
<b>Annex K (informative) ISO 13789: Ventilation airflow rates.....</b>	<b>38</b>
<b>Annex L (informative) ISO 14683: Example of the use of default values of linear thermal transmittance in calculating the heat transfer coefficient.....</b>	<b>42</b>
<b>Annex M (informative) Detailed worked examples for ISO 6946, ISO 13370 and ISO 13789.....</b>	<b>46</b>
<b>Bibliography.....</b>	<b>56</b>

## ISO/TR 52019-2:2016(E)

### Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

The committee responsible for this document is ISO /TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 2, *Calculation methods*.

A list of all parts in the ISO 52019 series, published under the general title *Energy performance of buildings (EPB) — Hygrothermal performance of building components and building elements*, can be found on the ISO website.

## Introduction

One of the main purposes of the revision of the EPB standards has been to enable that laws and regulations directly refer to the EPB standards and make compliance with them compulsory. This requires that the set of EPB standards consists of a systematic, clear, comprehensive and unambiguous set of energy performance procedures. The number of options provided is kept as low as possible, taking into account national and regional differences in climate, culture and building tradition, policy and legal frameworks (subsidiarity principle). For each option, an informative default option is provided (Annex B).

### Rationale behind the EPB technical reports

There is a risk that the purpose and limitations of the EPB standards will be misunderstood, unless the background and context to their contents – and the thinking behind them – is explained in some detail to readers of the standards. Consequently, various types of informative contents are recorded and made available for users to properly understand, apply and nationally or regionally implement the EPB standards.

If this explanation would have been attempted in the standards themselves, the result is likely to be confusing and cumbersome, especially if the standards are implemented or referenced in national or regional building codes.

Therefore each EPB standard is accompanied by an informative technical report, like this one, where all informative content is collected, to ensure a clear separation between normative and informative contents (see CEN/TS 16629<sup>[15]</sup>):

- to avoid flooding and confusing the actual normative part with informative content,
- to reduce the page count of the actual standard, and
- to facilitate understanding of the set of EPB standards.

This was also one of the main recommendations from the European CENSE project <sup>[[16]][[17]]</sup> that laid the foundation for the preparation of the set of EPB standards.

### This technical report

This technical report accompanies the suite of EPB standards on thermal transmission properties of building elements. It relates to ISO 6946<sup>1)</sup>[1], ISO 10211<sup>1)</sup>[3], ISO 13370<sup>1)</sup>[8], ISO 13786<sup>1)</sup>[9], ISO 13789<sup>1)</sup>[10] and ISO 14683<sup>1)</sup>[11], which form part of a set of standards related to the evaluation of the energy performance of buildings (EPB).

The role and the positioning of the accompanied standards in the set of EPB standards is defined in the introductions to ISO 6946, ISO 10211, ISO 13370, ISO 13786 and ISO 14683.

### Accompanying spreadsheet(s)

Concerning ISO 6946, ISO 10211, ISO 13370, ISO 13786 and ISO 14683, spreadsheets were produced for:

- ISO 6946;
- ISO 13370;
- ISO 13789.

In this document, examples of each of these calculation sheets are included in [Annex M](#).

---

1) To be published.

**ISO/TR 52019-2:2016(E)**

No accompanying calculation spreadsheets were prepared on:

- ISO 10211: this document does not provide a calculation procedure; it provides test cases and performance criteria for calculation procedures.
- ISO 13786: this document provides complex matrix calculation procedures. Instead of a spreadsheet, [Annex I](#) contains examples of calculation results obtained by a computer program.
- ISO 14683: this document does not provide a calculation procedure; it provides choices between procedures provided elsewhere and default tabulated values. Instead, [Annex L](#) contains examples of the use of default values.

The first series of standards on thermal and hygrothermal properties of building components and elements were prepared by ISO Technical Committee TC 163 in the 1980s, as a result of growing global concern on future fuel shortages and inadequate health and comfort levels in buildings. During the following decades these first standards were revised and new standards were added, to cope with new developments and additional needs. From the 1990s on, these standards were developed in close collaboration with CEN.



# Energy performance of buildings — Hygrothermal performance of building components and building elements —

## Part 2: Explanation and justification

### 1 Scope

This document contains information to support the correct understanding and use of ISO 6946, ISO 10211, ISO 13370, ISO 13786, ISO 13789 and ISO 14683.

This document does not contain any normative provision.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

There are no normative references in this document.

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 7345, ISO 6946, ISO 10211, ISO 13370, ISO 13786, ISO 13789 and ISO 14683 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

### 4 Symbols and subscripts

For the purposes of this document, the symbols and subscripts given in ISO 7345, ISO 6946, ISO 10211, ISO 13370, ISO 13786, ISO 13789 and ISO 14683 apply.

### 5 Description of the methods

#### 5.1 Outputs

The main outputs of ISO 7345, ISO 6946, ISO 10211, ISO 13370, ISO 13786, ISO 13789 and ISO 14683 are:

- thermal transmission properties of building elements (thermal resistance, thermal transmittance or dynamic thermal characteristics of a wall, floor or roof);
- heat transfer coefficient for the whole building (or part of a building).

## ISO/TR 52019-2:2016(E)

### 5.2 General description

Together with ISO 10456, ISO 10077-1<sup>2)</sup>, ISO 10077-2<sup>2)</sup> and ISO 12631<sup>2)</sup>, these documents (ISO 7345, ISO 6946, ISO 10211, ISO 13370, ISO 13786, ISO 13789 and ISO 14683) provide the methodology to obtain heat transfer coefficients for a building starting from the properties of materials used for its construction and the size and geometry of the building.

The results provide input for calculation of energy needs for heating and cooling by ISO 52016-1<sup>26)</sup> when one of the simplified (monthly or hourly) calculation methods is being used in ISO 52016-1<sup>26)</sup>. In the case of detailed dynamic simulations, the component (or subcomponent) properties are used directly as inputs for the building simulation.

In applications where individual component properties are needed, these documents provide:

- in the case of minimum component requirements, the *U*-value or *R*-value of the construction;
- for multi-zone calculations with assumed thermal interaction between the zones, the thermal transmission properties of the separating construction;

[Figure 1](#) illustrates the linkages between these documents.

---

2) To be published.




Figure 1 — Linkage between documents

## 6 ISO 6946

ISO 6946 provides a calculation method that is valid for most building components (walls and roofs). It is based on calculating the upper limit of thermal resistance of the component (which would apply if the heat flow were unidirectional from warm side to cold side) and the lower limit (in which the plane separating each layer is isothermal). Except for components consisting entirely of homogeneous layers (for which the upper and lower limits are equal) the true thermal resistance of a component is between these two limits. ISO 6946 specifies use of the arithmetic mean of the two limits provided that their ratio does not exceed 1,5.

## ISO/TR 52019-2:2016(E)

### 7 ISO 10211

ISO 10211 specifies the method for detailed calculation of thermal bridges. It can be applied to a whole building or part of it, and also to the calculation of linear and point thermal transmittances which are used in ISO 13789.

### 8 ISO 13370

#### 8.1 General

ISO 13370 is used for calculation of heat transfer via the ground, taking account of its contribution to the total thermal resistance in the case of U-value calculations and of its thermal inertia in the case of time-dependent calculations.

The following sub-clauses provide information in addition to that given in ISO 13370.

More background information can be found in references [18]–[25].

#### 8.2 Thermal properties of the ground

ISO 13370 specifies thermal properties for three representative types of ground. Particular values can be provided in ISO 13370:—, Annex A.

[Annex A](#) provides background information on the properties of the ground.

#### 8.3 The influence of flowing ground water

In most cases it is not necessary to take account of ground water since its flow rate is usually sufficiently small that it has a negligible effect on heat transfer rates. Further information and a method of allowing for the effect of ground water when its flow rate is known are given in [Annex B](#).

#### 8.4 Application to dynamic simulation programmes

ISO 13370:—, Annex F contains a procedure for the application to dynamic simulation programmes.

[Annex C](#) provides background information and validation of this procedure.

#### 8.5 Embedded heating or cooling systems

[Annex D](#) describes a modification of the methodology in ISO 13370 for floors with an embedded heating or cooling system.

#### 8.6 Cold stores

[Annex E](#) provides a method to calculate the heat gain to a cold store from heating elements in the ground (included to avoid frost heave).

### 9 ISO 13786

ISO 13786 defines a method of calculation of the dynamic thermal characteristics of a building component. [Annex G](#) gives background to the matrix method given in ISO 13786.

[Annex H](#) provides information on computer programming for complex numbers and [Annex I](#) gives the results of some sample calculations.

## 10 ISO 13789

ISO 13789 defines the calculation of the transmission heat transfer coefficient of a building, using the heat transmission properties of the building elements and thermal bridge used in its construction. A decision is needed on the system of dimensions to be used – internal, overall internal or external. [Annex J](#) illustrates the three systems and the effect of the systems on the linear thermal transmittance of junctions between elements. [Annex J](#) is relevant also to ISO 10211 and ISO 14683.

For the ventilation heat transfer coefficient the air flow rate through conditioned spaces is needed. [Annex K](#) provides a possible method, with associated data.

## 11 ISO 14683

ISO 14683 defines the methodology for determination of linear thermal transmittances and provides default values for when specific information is not available. [Annex L](#) provides examples of the influence of thermal bridges on the transmission heat loss coefficient.