



# SLOVENSKI STANDARD

## SIST ISO 50002:2017

01-april-2017

---

### Energetske presoje - Zahteve z navodili za uporabo

Energy audits - Requirements with guidance for use

Audits énergétiques - Exigences et recommandations de mise en oeuvre

Ta slovenski standard je istoveten z: **ISO 50002:2014**

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>

#### **ICS:**

03.100.70	Sistemi vodenja	Management systems
27.015	Energijska učinkovitost. Ohranjanje energije na splošno	Energy efficiency. Energy conservation in general

**SIST ISO 50002:2017**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>

INTERNATIONAL  
STANDARD

ISO  
50002

First edition  
2014-07-01

---

---

**Energy audits — Requirements with  
guidance for use**

*Audits énergétiques — Exigences et recommandations de mise en  
oeuvre*

**iTeh STANDARD PREVIEW  
(standards.iteh.ai)**

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

[https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-  
2f784597acc4/sist-iso-50002-2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)



Reference number  
ISO 50002:2014(E)

© ISO 2014

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Principles</b> .....	<b>3</b>
4.1 General.....	3
4.2 Energy auditor.....	3
4.3 Energy audit.....	4
4.4 Communication.....	5
4.5 Roles, responsibilities and authority.....	5
<b>5 Performing an energy audit</b> .....	<b>5</b>
5.1 General.....	5
5.2 Energy audit planning.....	6
5.3 Opening meeting.....	7
5.4 Data collection.....	8
5.5 Measurement plan.....	8
5.6 Conducting the site visit.....	9
5.7 Analysis.....	10
5.8 Energy audit reporting.....	12
5.9 Closing meeting.....	13
<b>Annex A (informative) Guidance on the use of this International Standard</b> .....	<b>14</b>
<b>Bibliography</b> .....	<b>22</b>

SIST ISO 50002:2017  
<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>

**ISO 50002:2014(E)****Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is Technical Committee ISO/TC 242, *Energy management*.

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>

## Introduction

The purpose of this International Standard is to define the minimum set of requirements leading to the identification of opportunities for the improvement of energy performance.

An energy audit comprises a detailed analysis of the energy performance of an organization, equipment, system(s) or process(es). It is based on appropriate measurement and observation of energy use, energy efficiency and consumption. Energy audits are planned and conducted as part of the identification and prioritization of opportunities to improve energy performance, reduce energy waste and obtain related environmental benefits. Audit outputs include information on current use and performance and they provide ranked recommendations for improvement in terms of energy performance and financial benefits.

An energy audit can support an energy review and can facilitate monitoring, measurement and analysis as described in ISO 50001, or it can be used independently.

This International Standard allows for differences in approach and in terms of scope, boundary and audit objective and seeks to harmonize common aspects of energy auditing in order to enhance clarity and transparency.

The energy audit process is presented as a simple chronological sequence, but this does not preclude repeated iterations of certain steps.

The main body of this International Standard covers the general requirements and framework common to all energy audits that can be supplemented by equivalent national audit standards. For auditing of specific types of facilities, processes or equipment, refer to the relevant international, national and local standards and guidelines, some of which are referenced in the Bibliography.

In this International Standard, the following verbal forms are used:

- “shall” indicates a requirement;
- “should” indicates a recommendation;
- “may” indicates a permission;
- “can” indicates a possibility or a capacity.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 50002:2017](#)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>



# Energy audits — Requirements with guidance for use

## 1 Scope

This International Standard specifies the process requirements for carrying out an energy audit in relation to energy performance. It is applicable to all types of establishments and organizations, and all forms of energy and energy use.

This International Standard specifies the principles of carrying out energy audits, requirements for the common processes during energy audits, and deliverables for energy audits.

This International Standard does not address the requirements for selection and evaluation of the competence of bodies providing energy audit services, and it does not cover the auditing of an organization's energy management system, as these are described in ISO 50003.

This International Standard also provides informative guidance on its use (see [Annex A](#)).

## 2 Normative references

There are no normative references.

iTeh STANDARD PREVIEW

## 3 Terms and definitions (standards.iteh.ai)

For the purposes of this document, the following terms and definitions apply.

**3.1 audit objective** <https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>  
purpose of an *energy audit* (3.3) agreed between the *organization* (3.13) and the *energy auditor* (3.5)

**3.2 boundary**  
physical or site limits and/or organizational limits as defined by the *organization* (3.13)

Note 1 to entry: The boundary of an energy management system can be different from the boundary of an *energy audit* (3.3).

Note 2 to entry: The energy audit can include one or more boundaries.

EXAMPLE The whole site and all energy using systems; the boiler plant; the vehicle fleet.

**3.3 energy audit**  
systematic analysis of *energy use* (3.12) and *energy consumption* (3.7) within a defined *energy audit scope* (3.4), in order to identify, quantify and report on the opportunities for improved *energy performance* (3.10)

Note 1 to entry: "Energy audit" is the normal expression in English. There are other expressions for the same concept, e.g. "diagnosi" in Italian and "diagnostic" in French.

**3.4 energy audit scope**  
extent of *energy uses* (3.12) and related activities to be included in the *energy audit* (3.3), as defined by the *organization* (3.13) in consultation with the *energy auditor* (3.5), which can include several boundaries

EXAMPLE Organization, facility/facilities, equipment, system(s) and process(es).

**ISO 50002:2014(E)**

Note 1 to entry: The energy audit scope can include energy related to transport.

**3.5****energy auditor**

individual, or team of people, conducting an *energy audit* (3.3)

Note 1 to entry: Energy audits can be conducted by the *organization* (3.13) using internal resources or external resources, such as energy consultants and energy service companies.

Note 2 to entry: An energy auditor, whether internal or external, needs to work with internal personnel relevant to the defined *energy audit scope* (3.4).

[SOURCE: EN 16247-1:2012, 3.2, modified — The expression “group of people or body” has been deleted and substituted by “or team of people”.]

**3.6****energy balance**

accounting of inputs and/or generation of energy supply versus energy outputs based on *energy consumption* (3.7) by *energy use* (3.12)

Note 1 to entry: Energy storage is considered within energy supply or energy use. If included in the *energy audit scope* (3.4), an energy balance needs to include energy storage and feedstock variation, as well as wasted energy, or energy content in material flows.

Note 2 to entry: An energy balance reconciles all energy, goods and products that enter the system *boundary* (3.2) against the energy, goods and products leaving the system boundary.

**3.7****energy consumption**

quantity of energy applied

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

[SOURCE: ISO 50001:2011, 3.7]

[SIST ISO 50002:2017](https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017)

<https://standards.iteh.ai/catalog/standards/sist/0501a9ab-14bd-465c-aa4d-2f784597acc4/sist-iso-50002-2017>

**3.8****energy efficiency**

ratio or other quantitative relationship between an output of performance, service, goods or energy, and an input of energy

EXAMPLE Conversion efficiency; energy required/energy used; output/input; theoretical energy used to operate/energy used to operate.

Note 1 to entry: Both input and output need to be clearly specified in quantity and quality, and be measurable.

[SOURCE: ISO 50001:2011, 3.8]

**3.9****energy flow**

description or mapping of processes for transfer of energy or conversion of energy within the defined *energy audit scope* (3.4)

**3.10****energy performance**

measurable results related to *energy efficiency* (3.8), *energy use* (3.12) and *energy consumption* (3.7)

[SOURCE: ISO 50001:2011, 3.12, modified — Notes 1 and 2 have been deleted as they are specific to energy management.]

**3.11****energy performance indicator****EnPI**

quantitative value or measure of *energy performance* (3.10), as defined by the *organization* (3.13)

Note 1 to entry: EnPIs could be expressed as a simple metric, ratio or a more complex model.

[SOURCE: ISO 50001:2011, 3.13]

### 3.12

#### **energy use**

manner or kind of application of energy

EXAMPLE Ventilation; lighting; heating; cooling; transportation; processes; production lines.

[SOURCE: ISO 50001:2011, 3.18]

### 3.13

#### **organization**

company, corporation, firm, enterprise, authority or institution, or part or combination thereof, whether incorporated or not, public or private, that has its own functions and administration and that has the authority to control its *energy use* (3.12) and consumption

Note 1 to entry: An organization can be a person or a group of people.

[SOURCE: ISO 50001:2011, 3.22]

### 3.14

#### **relevant variable**

quantifiable parameter impacting *energy consumption* (3.7)

EXAMPLE Ambient weather indicators; operating parameters (indoor temperature, light level); working hours; production throughput.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

## 4 Principles

### 4.1 General

SIST ISO 50002:2017

An energy audit is characterized by reliance on a number of principles. These principles help to make the energy audit an effective and reliable tool in support of management decisions and controls, by providing information on which an organization can act in order to improve its energy performance.

Adherence to these principles provides a consistent approach to an effective energy audit that would enable energy auditors, working independently from one another, to reach similar conclusions in similar circumstances.

It is essential that energy auditor(s) are familiar with applicable health and safety requirements throughout the audit process.

The organization selects the energy auditor(s) based on the expected energy audit scope, boundaries, audit objectives and their competencies.

### 4.2 Energy auditor

#### 4.2.1 Competency

Application of the following principles by the energy auditor is fundamental to the success of the energy audit.

The energy auditor shall have the knowledge and skills necessary to complete the defined energy audit scope. Competence can be shown by:

- a) appropriate education, skills, experience and/or training considering local or national guidelines and recommendations;
- b) relevant technical skills specific to the energy uses, scope, boundaries and audit objective;

**ISO 50002:2014(E)**

- c) knowledge of appropriate legal and other requirements;
- d) familiarity with the energy uses being audited;
- e) knowledge of the requirements of this International Standard, national and local energy auditing standards;
- f) (for a team member designated as lead energy auditor) having the skills to manage and provide leadership to the energy audit team: a lead auditor should have managerial, professional and leadership skills in order to manage a team.

NOTE 1 Where there is a single auditor, he/she is considered to be the lead auditor.

NOTE 2 Where a national or local energy auditor certification scheme, or equivalent, is available, certified energy auditors can be considered. Some schemes can be technology specific.

NOTE 3 The energy auditor is encouraged to demonstrate continual professional development to maintain and improve auditing knowledge, technical skills and personal attributes. Continual professional development could be achieved through means such as attendance at meetings, seminars, conferences, technical training, work experience, self- study, coaching, or other relevant activities.

**4.2.2 Confidentiality**

The confidentiality of the audit deliverables shall be agreed upon by the organization and the auditor prior to the start of the energy audit. Energy audit information shall not be used inappropriately for personal gain by the energy auditor, or in a manner detrimental to the legitimate interest of the organization.

NOTE This concept includes the proper handling of sensitive or confidential information.

**4.2.3 Objectivity**

The energy auditor shall act independently and in an impartial manner. Conflicts of interest (personal, financial or other) shall be identified and disclosed to the organization in a timely manner.

If the organization intends to carry out an energy audit using internal personnel, every effort should be made to remove bias and encourage objectivity.

**4.2.4 Access to equipment, resources and information**

For completion of the energy audit based on the defined energy audit scope and boundaries, access is required to:

- a) the organization, facility/facilities, equipment, system(s) and process(es);
- b) personnel (engineering, operations, maintenance, etc.), their equipment vendors, contractors and others to collect information pertinent and useful to the energy audit and analysis of data;
- c) other information sources, such as drawings, manuals, test reports, historical utility bill information, monitoring and control data, electrical equipment panels and calibration records.

**4.3 Energy audit**

The energy audit shall be conducted according to the following principles:

- a) the audit is consistent with the agreed energy audit scope, boundary and audit objective(s);
- b) the measurements and observations are appropriate to the energy uses and consumption;
- c) the collected energy performance data are representative of the activities, processes, equipment and systems;