



SLOVENSKI STANDARD
SIST EN 997:2012+A1:2015
01-september-2015

Straniščne školjke in straniščna oprema z integriranim sifonom

WC pans and WC suites with integral trap

WC-Becken und WC-Anlagen mit angeformtem Geruchverschluss

Cuvettes de WC et cuvettes à réservoir attenant à siphon intégré

Ta slovenski standard je istoveten z: EN 997:2012+A1:2015

[SIST EN 997:2012+A1:2015](https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015)

<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

ICS:

91.140.70 Sanitarne naprave Sanitary installations

SIST EN 997:2012+A1:2015 **en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 997:2012+A1:2015](https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015)
<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

EUROPEAN STANDARD

EN 997:2012+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2015

ICS 91.140.70

Supersedes EN 997:2012

English Version

WC pans and WC suites with integral trapCuvettes de WC et cuvettes à réservoir attenant à siphon
intégréWC-Becken und WC-Anlagen mit angeformtem
Geruchverschluss

This European Standard was approved by CEN on 9 December 2011 and includes Corrigendum 1 issued by CEN on 18 July 2012 and Amendment 1 approved by CEN on 6 April 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

[SIST EN 997:2012+A1:2015](https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015)

<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels



Contents

Page

Foreword.....	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Classification.....	10
5 Functional requirements and test methods for class 1 products	10
5.1 Depth of water seal	10
5.2 Flushing requirements	11
5.2.1 General.....	11
5.2.2 Wash of bowl.....	11
5.2.3 Flushing of toilet paper	11
5.2.4 Flushing of fifty small plastic balls	11
5.2.5 Oversplashing	11
5.2.6 After-flush volume	11
5.3 Water absorption	11
5.4 Static load.....	12
5.5 Additional requirements of flushing cisterns for close-coupled suites and one-piece WCs	12
5.5.1 General.....	12
5.5.2 Inlet valve of the flushing cistern	12
5.5.3 Supply piping	12
5.5.4 Flush volume(s) of the flushing cistern	12
5.5.5 Leaktightness between flushing cistern and bowl	12
5.5.6 Outlet valve leaktightness	12
5.5.7 Outlet valve reliability.....	12
5.5.8 Overflow.....	12
5.5.9 Safety margin – dimension “c”	13
5.5.10 Safety margin – dimension “a”	14
5.6 Durability	14
5.7 Test methods.....	14
5.7.1 Depth of water seal	14
5.7.2 Flushing tests.....	14
5.7.3 Determination of water absorption	17
5.7.4 Load test	18
5.7.5 Tests for flushing cisterns of close-coupled suites and one-piece WCs	18
5.8 Types of independent WC pans, close-coupled suites and one-piece WCs	21
5.8.1 Nominal flush volume	21
5.8.2 Flushing devices.....	22
5.8.3 Verification of types	22
6 Functional requirements and test methods for class 2 products	22
6.1 Inlet valve.....	22
6.2 Backflow prevention.....	23
6.3 Marking of flushing cistern	23
6.4 Warning pipe and overflow provision.....	23
6.5 Flush volume.....	23
6.5.1 Full flush	23
6.5.2 Reduced flush	23
6.6 Flush rate.....	23
6.7 Physical endurance and leakage of flushing device.....	23

6.8	Chemical endurance of flushing device.....	23
6.9	Solids discharge and after-flush volume for maximum flush	24
6.10	Paper discharge for reduced-flush volume	24
6.11	Liquid contaminant dye retention.....	24
6.12	Wash of bowl	24
6.13	Depth of water seal.....	24
6.14	Static load of class 2 products	24
6.15	Water absorption	24
6.16	Durability of class 2 products	24
6.17	Test methods	24
6.17.1	Inlet valve tests.....	24
6.17.2	Warning pipe and overflow provisions	25
6.17.3	Flush volume and water trap seal tests	25
6.17.4	Flush rate test	26
6.17.5	Physical endurance and leakage test of flushing device.....	27
6.17.6	Chemical endurance test of flushing device	28
6.17.7	Solids discharge and after-flush volume for maximum flush volume test	28
6.17.8	Paper discharge for reduced-flush volume test.....	30
6.17.9	Liquid contaminant dye retention test	30
6.17.10	Wash of bowl	31
6.17.11	Summary of requirements for compatibility testing of class 2 products	31
7	Dangerous substances	32
8	Marking.....	32
9	Assessment and verification of constancy of performance – AVCP	35
9.1	General	35
9.2	Type testing	35
9.2.1	General	35
9.2.2	Test samples, testing and compliance criteria	36
9.3	Factory production control (FPC) EN 997:2012+A1:2015	37
9.3.1	General	37
9.3.2	Equipment	38
9.3.3	Raw materials and components	38
9.3.4	Product testing and assessment	38
9.3.5	Non-complying products	38
9.3.6	Corrective action	38
Annex A	(normative) Valve-type test flushing cistern	39
A.1	Valve-type test flushing cistern (Figures A.1 to A.3)	39
A.2	Calibration of the valve-type test flushing cistern	41
A.3	Procedure to test the flush rate of the test flushing cistern	41
A.4	Procedure to test the flushing requirements of the WC.....	42
A.5	Procedure to measure the impact force of the test flushing cistern	42
A.5.1	General	42
A.5.2	Test device	42
A.5.3	Procedure for calibrating the load cell unit and the measurement amplifier.....	44
A.5.4	Measurement procedure.....	44
A.5.5	Calculation procedure for fixed time frame 0,35 s to 0,5 s	45
A.5.6	Calculation procedure for maximum impact force	45
Annex B	(normative) Test rig for test pressure flush valve	46
B.1	Test rig (Figure B.1).....	46
B.2	Procedure to measure the impact force.....	47
Annex C	(normative) Test rig for after-flush volume test	49
C.1	Test rig for after-flush volume test for independent WC pans (Figures C.1 and C.2)	49
C.2	Test rig for after-flush volume test for one-piece WC pans, close-coupled suites and WC suites (Figure C.3)	50
Annex D	(normative) Basket method	51

EN 997:2012+A1:2015 (E)

Annex E (normative) Preparation of test specimens.....	52
Annex F (informative) Examples of flush pipes and outlet valves for test flushing cisterns.....	54
Annex ZA (informative)  Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation .....	58
Bibliography	67

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 997:2012+A1:2015
<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

Foreword

This document (EN 997:2012+A1:2015) has been prepared by Technical Committee CEN/TC 163 “Sanitary appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2015, and conflicting national standards shall be withdrawn at the latest by March 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document includes Corrigendum 1 issued by CEN on 18 July 2012 and Amendment 1 approved by CEN on 4 April 2015.

This document supersedes A1 EN 997:2012 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 and A1.

The modifications of the related CEN Corrigendum have been implemented at the appropriate places in the text and are indicated by the tags AC AC.

A1 This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the EU Construction Products Regulation.

For relationship with EU Construction Products Regulation, see informative Annex ZA, which is an integral part of this document. A1

This standard is one of a series of standards for sanitary appliances. Supporting standards are those for flushing devices and connecting dimensions.

A1 The main changes introduced in EN 997:2012 with respect to the prior edition of this standard were the following: A1

- a) by reason of the actual market development, testing the flushing requirements has been specified. In this connection, requirements for test flushing cistern and its calibration have been adjusted to these conditions (introduction of the new parameter impact force);
- b) requirements and test methods for close-coupled suites and one-piece WCs have been extended and adjusted to those for flushing cisterns in accordance with EN 14055.

NOTE Noise level has not been considered in the present amendment. Noise level will be considered as soon as a European test method is available. ¹⁾

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1) Presently, a test method is under elaboration by CEN/TC 126 “Acoustic properties of building products and of buildings”.

EN 997:2012+A1:2015 (E)**1 Scope**

This European Standard specifies constructional and performance requirements together with test methods for close-coupled suites, one-piece and independent WC pans with integral trap used for personal hygiene manufactured from glazed ceramics or stainless steel.

This European Standard does not apply to squatting toilets, WC pans without integral trap or flushing cisterns as separate appliances.

In the case of independent WC pans, the associated flushing cisterns and pressure valves are covered by other standards and the reference to cisterns in this standard is related only to the definition and requirements of flushing volume.

In the case of close-coupled suites and one-piece WCs, this standard also specifies design, performance requirements and the test methods for designated flushing cisterns with flushing mechanisms, inlet valves and overflows. For these products, this standard covers flushing cisterns designed to be connected to drinking water installations inside buildings.

Before installation of WCs, EN 12056-2 and national requirements need to be taken into consideration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1717, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow*

EN 12056-2, *Gravity drainage systems inside buildings — Part 2: Sanitary pipework, layout and calculation*

EN 13618, *Flexible hose assemblies in drinking water installations — Functional requirements and test methods*

EN 14124, *Inlet valves for flushing cisterns with internal overflow*

AS 1172-1, *Water closets of 6/3 l capacity — pans*

BS 1212-2:1990, *Float operated valves. Specification for diaphragm type float operated valves (copper alloy body) (excluding floats)*

BS 1212-3:1990, *Float operated valves. Specification for diaphragm type float operated valves (plastics bodied) for cold water services only (excluding floats)*

BS 1212-4:1991, *Float operated valves. Specification for compact type float operated valves for WC flushing cisterns (including floats)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Drawings are diagrammatic only.

3.1**glazed ceramic**

ceramic material for sanitary appliances with all visible surfaces glazed when installed

3.2**WC pan**

bowl-shaped appliance for reception and flushing away of human solid and liquid excrement

3.3**pedestal WC pan**

floor-mounted WC pan that has an integral foot

**3.4****wall-hung WC pan**

WC pan cantilevered clear of the floor

**3.5****back-to-wall WC pan**

pedestal WC pan whose back is in contact with the wall

3.6**wash-out WC pan**

WC pan in which excrement falls first into a shallow water filled bowl, before being removed by the flushing water

**3.7****wash-down WC pan**

WC pan in which excrement falls directly into the trap before being removed by the flushing water

**3.8****siphonic WC pan**

WC pan in which excrement is removed by siphonage induced by the flushing water

**3.9****close-coupled suite**

combination of a WC pan and flushing cistern directly coupled into a functional unit

**3.10****one-piece WC pan**

WC pan manufactured with an integral flushing cistern

**3.11****independent WC pan**

WC pan suitable for the connection with a flushing cistern or a pressure flush valve

**3.12****WC suite**

WC pan combined with either a flushing cistern with integral warning pipe connection – or a device deemed to be a no less effective device – and inlet/outlet devices, or a pressure flush valve, with WC and flushing device installed as a functioning unit

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 997:2012+A1:2015

<https://standards.iteh.ai/catalog/standards/sist/a13c3f5-9a7a-42f0-b954-11a0c602abed/sist-en-997-2012a1-2015>

EN 997:2012+A1:2015 (E)**3.13****children WC pan**

WC pan with a front edge between 300 mm and 380 mm high

3.14**baby WC pan**

WC pan with a front edge below 260 mm high


3.15**flushing device**

device fitted to a cistern to provide controlled measured volume(s) of water to a WC pan or suite for flushing


Note 1 to entry: A flushing device can be a siphon, drop valve, flap valve or pressurised cistern etc. For the purposes of this specification, the flushing device includes the activator (e.g. handle, button, linkages etc.) and all seals, pistons, or other integral components.

3.16**valve-type flushing cistern**

cistern with integral valve outlet device for the storage and discharge of a defined volume(s) of flushing water for the removal of excrement from a WC pan

**3.17****pressure flush valve**

valve directly connected to the water supply which delivers a pre-determined volume of flushing water for the removal of excrement from a WC pan

**3.18****water trap**

water seal that prevents backflow of foul odour from a drain

3.19**inlet valve**

valve that controls and shuts off the flow of water into a flushing cistern, usually by an arm connected to a float

3.20**outlet valve**

mechanism for opening and closing the outlet orifice of the flushing cistern

3.21**flush pipe**

connecting pipe between a flushing cistern's outlet and a WC's inlet

3.22**overflow**

device enabling release of excess water from a flushing cistern when water reaches a pre-determined level

3.23**overflow level**

water level corresponding to the upper edge of the overflow or to the lower edge of the overflow notch

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 997:2012+A1:2015

<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

3.24**flush volume**

volume of water discharged from the flushing device during a flush cycle

3.25**after-flush volume**

volume of flush water remaining after the last test specimen has left the outlet of the bowl

3.26**warning level**

level of spill over of a vertically mounted warning pipe connection or the invert of a horizontally mounted warning pipe connection, or the level at which an equally effective (warning) device would operate

3.27**meniscus level**

level resulting from surface tension of water during overflowing

3.28**nominal water level**

water level when a cistern is filled to the nominal flush volume, e.g. 4 l, 5 l, 6 l, 7 l or 9 l

3.29**nominal flush volume**

volume of water indicated, when a flushing cistern is filled to the nominal water level

3.30**maximum water level**

highest water level reached after flow stabilisation, in the event of continuous supply, as a result of malfunction of the inlet valve

3.31**critical water level**

highest water level in any part of the appliance, 2 s after the supply is cut-off

3.32**residual water level**

water level, after a full flush is completed

3.33**adjustable residual water level**

residual water level in a cistern, after (uninterrupted) flushing, which can be altered by adjusting the outlet mechanism

3.34**short-term leak test**

leak test consisting of a 15 min wait after flushing then positioning paper designed to change colour when wet, under the flushing device for 10 min

Note 1 to entry: A leak is defined as being visible discharge of water amounting to more than three separate drops.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 997:2012+A1:2015](https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015)

<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

EN 997:2012+A1:2015 (E)**3.35****long-term leak test**

leak test consisting of a 2 h wait after flushing then positioning paper designed to change colour when wet, under the outlet for 15 min

Note 1 to entry: A leak is defined as being visible discharge of water amounting to more than three separate drops.

3.36**safety margin – safety margin c**

distance between the nominal water level determined by the manufacturer, and the overflow level

3.37**impact force**

force of the flushing water at the outlet of the flush pipe

3.38**test height**

distance between the seat of the flushing device and the horizontal axis of the flush pipe

3.39**flush rate**

volume of water flowing out of a flushing cistern as a function of time



iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.40**product type**

construction product with a set of representative performance levels or classes in relation to its essential characteristics, produced using a given combination of raw materials or other elements in a specific production process

SIST EN 997:2012+A1:2015
<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>



4 Classification

WC pans and suites are classified as described below:

- Class 1:** WC pans and suites designed for use with and tested using a nominal full flush volume of either 4 l, 5 l, 6 l, 7 l or 9 l and in case of a reduced flush not less than those in accordance with Table 2 and Table 3. The requirements of class 1 are given in Clause 5.
- Class 2:** WC suites designed for use with a pressure flushing valve or a flushing cistern incorporating some other flushing device, and tested as described in Clause 6, using a maximum flushing volume of 6 l, or a dual-flush combining a maximum flush of 6 l and a reduced flush no greater than two-thirds of the maximum flush volume. The requirements of class 2 are given in Clause 6.

5 Functional requirements and test methods for class 1 products**5.1 Depth of water seal**

When tested in accordance with 5.7.1, the depth of the water seal shall be not less than 50 mm.

5.2 Flushing requirements

5.2.1 General

Table 1 correlates the flushing requirements to the WC pan type and flushing volume.

Table 1 — Flushing requirements

Type of WC pan in accordance with Table 2 and Table 3	Wash of bowl (5.2.2)	Flushing of toilet paper (5.2.3)	Flushing of 50 plastic balls (5.2.4)	Oversplashing (5.2.5)	After-flush volume (5.2.6)
9	X	X	X	X	
7	X	X	X	X	
6	X	X		X	X
5	X	X		X	X
4	X	X	X	X	

The efficiency of flushing is demonstrated by the following requirements.

5.2.2 Wash of bowl

When tested in accordance with 5.7.2.3, the arithmetic average of any unflushed area below the rim and above the surface of the water in the trap shall not be more than 50 cm² after five flushing operations.

In case of rimless WCs, the surface to be tested is the area between the water surface and a horizontal line 85 mm below the top edge of the bowl.

5.2.3 Flushing of toilet paper

When tested in accordance with 5.7.2.4, 12 sheets of toilet paper shall be flushed out of the WC pan a minimum of 4 times out of five tests.

For baby WC pans, 6 sheets of toilet paper shall be flushed out of the WC pan a minimum of 4 times out of five tests.

5.2.4 Flushing of fifty small plastic balls

When tested in accordance with 5.7.2.5 after five tests, each with 50 balls, a minimum of 85 % of the balls shall be flushed out of the WC pan.

5.2.5 Oversplashing

When tested in accordance with 5.7.2.6, flushing water shall not splash beyond the rim of the bowl and wet the floor. Only a few small drops are permissible.

5.2.6 After-flush volume

When tested in accordance with 5.7.2.7, an after-flush volume of 2,5 l or 2,8 l as appropriate is required.

5.3 Water absorption

When tested in accordance with 5.7.3, the arithmetic average for water absorption of glazed ceramic WC pans shall not exceed 0,5 % by mass.

EN 997:2012+A1:2015 (E)**5.4 Static load**

When tested in accordance with 5.7.4, wall-hung and non-ceramic WC pans and WC suites shall withstand a force of $(4,00 \pm 0,05)$ kN without showing any evidence of cracking or permanent deformation.

Experience has shown that pedestal ceramic WC pans and WC suites comply with this requirement.

5.5 Additional requirements of flushing cisterns for close-coupled suites and one-piece WCs**5.5.1 General**

If close-coupled suites and one-piece WCs comprising a flushing cistern and a WC pan supplied or specified by the manufacturer as a unit, the following requirements shall be fulfilled.

5.5.2 Inlet valve of the flushing cistern

Flushing cisterns shall have an inlet valve complying with EN 14124.

5.5.3 Supply piping

All materials of the supply piping which could be in contact with drinking water shall not be danger to health. They shall not change the taste, aroma or visual appearance of the drinking water.

The use of elastomeric flexible supply hoses complying with EN 13618 is permissible inside the assembly.

5.5.4 Flush volume(s) of the flushing cistern

The flush volume(s) for one-piece and close-coupled flushing cisterns supplied with a WC pan shall conform to the value(s) specified by the manufacturer according to Table 3 when measured as described in 5.7.5.1.

Flushing cisterns or their components shall be marked to allow the correct volume(s) of flush to be achieved.

5.5.5 Leaktightness between flushing cistern and bowl

When tested in accordance with 5.7.5.2, there shall be no leakage between the WC pan and the flushing cistern.

5.5.6 Outlet valve leaktightness

When tested in accordance with 5.7.5.3, the outlet shall not show any leakage greater than three drops within 15 min.

5.5.7 Outlet valve reliability

When tested in accordance with 5.7.5.4, the outlet mechanism functions shall be ensured.

The flushing device shall not show any failure or permanent distortion of any component including linkages that prevents normal operation of the mechanism.


The outlet of the flushing device shall not show leakage greater than three drops within 15 min.

5.5.8 Overflow

When tested as described in 5.7.5.5, the overflow shall meet the requirements specified below (see Figure 1):

- a) The distance between the maximum water level and the overflow level shall be ≤ 20 mm.
- b) The distance between the critical water level and the overflow level shall be ≤ 10 mm.
- c) The distance between the meniscus level and the overflow level shall be ≤ 5 mm.

Dimensions in millimetres



iTeh STANDARD PREVIEW
(standards.iteh.ai)

Key

- 1 overflow pipe
- 2 overflow level
- 3 maximum water level
- 4 critical water level
- 5 meniscus level

SIST EN 997:2012+A1:2015
<https://standards.iteh.ai/catalog/standards/sist/af13c3f5-9a7a-42f0-b954-11a0cb02abed/sist-en-997-2012a1-2015>

Figure 1 — Maximum, critical and overflow level

5.5.9 Safety margin – dimension “c”

When tested as described in 5.7.5.6, dimension “c” (see Figure 2) corresponding to the distance between the overflowing level and the maximum nominal water level indicated by the manufacturer shall be ≥ 20 mm.