

SLOVENSKI STANDARD SIST EN 55016-2-3:2017

01-julij-2017

Nadomešča:

SIST EN 55016-2-3:2010

SIST EN 55016-2-3:2010/A1:2010 SIST EN 55016-2-3:2010/A2:2014 SIST EN 55016-2-3:2010/AC:2013

Specifikacija merilnih naprav in metod za merjenje radijskih motenj in odpornosti - 2-3. del: Metode za merjenje radijskih motenj in odpornosti - Merjenje sevanih motenj

iTeh STANDARD PREVIEW

Specification for radio disturbance and immunity measuring apparatus and methods - Part 2-3: Methods of measurement of disturbances and immunity - Radiated disturbance measurements

SIST EN 55016-2-3:2017

https://standards.iteh.ai/catalog/standards/sist/782d03a8-3ff7-408f-8bd3-

Anforderungen an Geräte und Einrichtungen Sowie Festlegung der Verfahren zur Messung der hochfrequenten Störaussendung (Funkstörungen) und Störfestigkeit - Teil 2-3: Verfahren zur Messung der hochfrequenten Störaussendung (Funkstörungen) und Störfestigkeit - Messung der gestrahlten Störaussendung

Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques - Partie 2-3: Méthodes de mesure des perturbations et de l'immunité - Mesures des perturbations rayonnées

Ta slovenski standard je istoveten z: EN 55016-2-3:2017

ICS:

17.240 Merjenje sevanja Radiation measurements

33.100.20 Imunost Immunity

SIST EN 55016-2-3:2017 en

2003-01. Slovenski inštitut za standardizacijo. Razmnoževanje celote ali delov tega standarda ni dovoljeno.

SIST EN 55016-2-3:2017

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 55016-2-3:2017</u> https://standards.iteh.ai/catalog/standards/sist/782d03a8-3ff7-408f-8bd3-082047a21ea3/sist-en-55016-2-3-2017 **EUROPEAN STANDARD**

EN 55016-2-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2017

ICS 33.100.10; 33.100.20

Supersedes EN 55016-2-3:2010

English Version

Specification for radio disturbance and immunity measuring apparatus and methods - Part 2-3: Methods of measurement of disturbances and immunity - Radiated disturbance measurements

(CISPR 16-2-3:2016)

Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques - Partie 2-3: Méthodes de mesure des perturbations et de l'immunité - Mesures des perturbations rayonnées (CISPR 16-2-3:2016) Anforderungen an Geräte und Einrichtungen sowie Festlegung der Verfahren zur Messung der hochfrequenten Störaussendung (Funkstörungen) und Störfestigkeit - Teil 2-3: Verfahren zur Messung der hochfrequenten Störaussendung (Funkstörungen) und Störfestigkeit -Messung der gestrahlten Störaussendung (CISPR 16-2-3:2016)

iTeh STANDARD PREVIEW

This European Standard was approved by CENELEC on 2016-10-20; CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

Management Centre or to any CENELEC member.

Mines //standards fieh.avcatalog/standards/sist/782d03a8-3ff7-408f-8bd3-

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

EN 55016-2-3:2017

European foreword

The text of document CISPR/A/1176A/FDIS, future edition 4 of CISPR 16-2-3, prepared by CISPR SC A "Radio-Interference measurements and statistical methods" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 55016-2-3:2017.

The following dates are fixed:

| • | latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2017-10-28 |
|---|--|-------|------------|
| • | latest date by which the national standards conflicting with the document have to be withdrawn | (dow) | 2020-04-28 |

This document supersedes EN 55016-2-3:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard CISPR 16-2-3:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

| CISPR 11:2015 | <u> </u> | Harmonized as EN 55011:2016. |
|----------------------|----------|--|
| CISPR 16-1-6:2014 | | log/standards/sist/782d03a8-3ff7-408f-8bd. e.Harmonized as EN 55016†176:2015. |
| CISPR 22:2008 | NOTE | Harmonized as EN 55022:2010. |
| IEC 61140:2016 | NOTE | Harmonized as EN 61140:2016. |
| ISO/IEC Guide 2:2004 | NOTE | Harmonized as EN 45020:2006. |
| ISO/IEC 17000:2004 | NOTE | Harmonized as EN ISO/IEC 17000:2004. |
| IEC 61000-4-21 | NOTE | Harmonized as EN 61000-4-21. |

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here:

| www.cenelec.eu | | T'U. | EN/UD | \/ |
|------------------------------|-------------|--|-------------------------|-------------|
| Publication IEC 60050-161 | <u>Year</u> | <u>Title</u> International Electrotechnical Vocabulary | EN/HD | <u>Year</u> |
| IEC 00030-101 | - | (IEV) Chapter 161: Electromagnetic | - | - |
| | | compatibility | | |
| IEC 61000-4-3 | 2006 | Electromagnetic compatibility (EMC) Pa | rtEN 61000-4-3 | 2006 |
| | | 4-3: Testing and measurement techniques | | |
| | | - Radiated, radio-frequency, | | |
| | | electromagnetic field immunity test | | |
| + A1 | 2007 | | + A1 | 2008 |
| + A2 | 2010 | | + A2 | 2010 |
| IEC 61000-4-20 | - | Electromagnetic compatibility (EMC) Pa | rtEN 61000-4-20 | |
| | | 4-20: Testing and measurement | | |
| | | techniques - Emission and immunity testing in transverse electromagnetic | | |
| | iT | (TEM) waveguides | EW | |
| CISPR 14-1 | 2016 | Electromagnetic compatibility - | FprEN 55014-1 | 2016 |
| | | Requirements for household appliances, | | |
| | | electric tools and similar apparatus - Part | | |
| 01000 40 4 4 | | 1: Emissio <u>RIST EN 55016-2-3:2017</u> | | |
| CISPR 16-1-1 | https://st | | 4 0 8f-8bd3- | - |
| | | immunity measuring apparatus and 017 methods - Part 1-1: Radio disturbance and | 1 | |
| | | immunity measuring apparatus - | 4 | |
| | | Measuring appartus | | |
| CISPR 16-1-2 | 2014 | Specification for radio disturbance and | EN 55016-1-2 | 2014 |
| | | immunity measuring apparatus and | | |
| | | methods - Part 1-2: Radio disturbance and | t | |
| | | immunity measuring apparatus - Coupling | | |
| | | devices for conducted disturbance | | |
| 01000 40 4 4 | 0040 | measurements | EN 55040 4 4 | 0040 |
| CISPR 16-1-4 | 2010 | Specification for radio disturbance and | EN 55016-1-4 | 2010 |
| | | immunity measuring apparatus and methods Part 1-4: Radio disturbance an | d | |
| | | immunity measuring apparatus - Antennas | | |
| | | and test sites for radiated disturbance | , | |
| | | measurements | | |
| + A1 | 2012 | | + A1 | 2012 |
| CISPR 16-2-1 | 2014 | Specification for radio disturbance and | EN 55016-2-1 | 2014 |
| | | immunity measuring apparatus and | | |
| | | methods - Part 2-1: Methods of | | |
| | | measurement of disturbances and | | |
| | | immunity - Conducted disturbance | | |
| CISPR 16-4-2 | | measurements Specification for radio disturbance and | EN 55016-4-2 | |
| CISEN 10-4-2 | - | immunity measuring apparatus and | EN 55010-4-2 | |
| | | methods Part 4-2: Uncertainties, | | |
| | | statistics and limit modelling - | | |
| | | Measurement instrumentation uncertainty | | |
| | | , | | |

SIST EN 55016-2-3:2017

EN 55016-2-3:2017

CISPR TR 16-4-1 - Specification for radio disturbance and -

immunity measuring apparatus and

methods - Part 4-1: Uncertainties, statistics

and limit modelling - Uncertainties in

standardized EMC tests

CISPR TR 16-4-5 - Specification for radio disturbance and

immunity measuring apparatus and

methods - Part 4-5: Uncertainties, statistics and limit modelling - Conditions for the use

of alternative test methods

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 55016-2-3:2017</u> https://standards.iteh.ai/catalog/standards/sist/782d03a8-3ff7-408f-8bd3-082047a21ea3/sist-en-55016-2-3-2017



CISPR 16-2-3

Edition 4.0 2016-09

INTERNATIONAL STANDARD

NORME INTERNATIONALE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

BASIC EMC PUBLICATION
PUBLICATION FONDAMENTALE EN CEM

iTeh STANDARD PREVIEW

(standards.iteh.ai)

Specification for radio disturbance and immunity measuring apparatus and methods – SIST EN 55016-2-3:2017

Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements

Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques – Partie 2-3: Méthodes de mesure des perturbations et de l'immunité – Mesurages des perturbations rayonnées

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 33.100.10; 33.100.20 ISBN 978-2-8322-3590-4

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

| FC | REWO | RD | 7 |
|----|----------------|--|----|
| 1 | Scop | e | 9 |
| 2 | Norm | native references | 9 |
| 3 | Term | s, definitions and abbreviations | 10 |
| | 3.1 | Terms and definitions | 10 |
| | 3.2 | Abbreviated terms | 15 |
| 4 | Туре | s of disturbance to be measured | 16 |
| | 4.1 | General | 16 |
| | 4.2 | Types of disturbance | 16 |
| | 4.3 | Detector functions | 16 |
| 5 | Conn | ection of measuring equipment | 16 |
| 6 | Gene | eral measurement requirements and conditions | 17 |
| | 6.1 | General | 17 |
| | 6.2 | Disturbance not produced by the equipment under test | 17 |
| | 6.2.1 | General | 17 |
| | 6.2.2 | Compliance (conformity assessment) testing | 17 |
| | 6.3 | Measurement of continuous disturbance | 17 |
| | 6.3.1 | Narrowband continuous disturbanceBroadband continuous disturbance | 17 |
| | 6.3.2 | Broadband continuous disturbance | 17 |
| | 6.3.3 | (200011000100001) | |
| | 6.4 | EUT arrangement and measurement conditions | |
| | 6.4.1 | General arrangement of the E016-2-3:2017 | 18 |
| | 6.4.2 | 082047a21ea3/sist_en_55016-2-3-2017 | 20 |
| | 6.4.3 | | |
| | 6.4.4 | 5 | |
| | 6.4.5 | 11,7 | |
| | 6.4.6 | ' | |
| | 6.4.7 | -1 | |
| | 6.4.8 6.4.9 | 3 () | |
| | 6.5 | Interpretation of measuring results | |
| | 6.5.1 | Continuous disturbance | |
| | 6.5.2 | | |
| | 6.5.3 | | |
| | 6.6 | Measurement times and scan rates for continuous disturbance | |
| | 6.6.1 | General | |
| | 6.6.2 | Minimum measurement times | 23 |
| | 6.6.3 | Scan rates for scanning receivers and spectrum analyzers | 23 |
| | 6.6.4 | Scan times for stepping receivers | 24 |
| | 6.6.5 | Strategies for obtaining a spectrum overview using the peak detector | 25 |
| | 6.6.6 | Timing considerations using FFT-based instruments | 29 |
| 7 | Meas | surement of radiated disturbances | 32 |
| | 7.1 | Introductory remarks | 32 |
| | 7.2 | Loop-antenna system measurements (9 kHz to 30 MHz) | 33 |
| | 7.2.1 | General | |
| | 7.2.2 | General measurement method | 33 |

| 7.2.3 | l est environment | 34 |
|-------|---|----|
| 7.2.4 | Configuration of the equipment under test | 35 |
| 7.2.5 | Measurement uncertainty for LAS | 35 |
| 7.3 | Open-area test site or semi-anechoic chamber measurements (30 MHz to 1 GHz) | 35 |
| 7.3.1 | Measurand | 35 |
| 7.3.2 | Test site requirements | 38 |
| 7.3.3 | General measurement method | 38 |
| 7.3.4 | Measurement distance | 39 |
| 7.3.5 | Antenna height variation | 40 |
| 7.3.6 | Product specification details | 40 |
| 7.3.7 | Measurement instrumentation | 42 |
| 7.3.8 | Field-strength measurements on other outdoor sites | 42 |
| 7.3.9 | • | |
| 7.4 | Fully-anechoic room measurements (30 MHz to 1 GHz) | |
| 7.4.1 | | |
| 7.4.2 | | |
| 7.4.3 | Cable layout and termination | 46 |
| 7.4.4 | | |
| 7.5 | Radiated emission measurement method (30 MHz to 1 GHz) and radiated immunity test method (80 MHz to 1 GHz) with common test set-up in semi-anechoic chamber | |
| 7.5.1 | Applicability(standards.iteh.ai) | 47 |
| 7.5.2 | | 47 |
| 7.5.3 | Uniform test volume SIST EN 55016-2-3:2017 | 48 |
| 7.5.4 | Specifications for EUT is et up in common emissions / immunity test set- up | 49 |
| 7.5.5 | Measurement uncertainty for common emission/immunity set-up and method | 55 |
| 7.6 | Fully-anechoic room and absorber-lined OATS/SAC measurements (1 GHz to 18 GHz) | 55 |
| 7.6.1 | , | |
| 7.6.2 | | 55 |
| 7.6.3 | Set-up and operating conditions of the equipment under test (EUT) | 56 |
| 7.6.4 | Measurement site | 56 |
| 7.6.5 | Measurement instrumentation | 56 |
| 7.6.6 | Measurement procedure | 57 |
| 7.6.7 | · | |
| 7.7 | In situ measurements (9 kHz to 18 GHz) | |
| 7.7.1 | | |
| 7.7.2 | Field-strength measurements <i>in situ</i> in the frequency range 9 kHz to 30 MHz | 65 |
| 7.7.3 | Field-strength measurements <i>in situ</i> in the frequency range above 30 MHz | 65 |
| 7.7.4 | In situ measurement of the disturbance effective radiated power using the substitution method | 66 |
| 7.7.5 | Documentation of the measurement results | 70 |
| 7.7.6 | Measurement uncertainty for <i>in situ</i> method | 70 |
| 7.8 | Substitution measurements (30 MHz to 18 GHz) | |
| 7.8.1 | | |
| 7.8.2 | | |

- 4 - CISPR 16-2-3:2016 © IEC 2016

| | 7.8.3 | | |
|----|---------|--|----|
| | 7.8.4 | EUT configuration | 72 |
| | 7.8.5 | · | |
| | 7.8.6 | Measurement uncertainty for substitution method | 72 |
| | 7.9 | Reverberation chamber measurements (80 MHz to 18 GHz) | 72 |
| | 7.10 | TEM waveguide measurements (30 MHz to 18 GHz) | 72 |
| 8 | Autor | mated measurement of emissions | 72 |
| | 8.1 | Introduction – Precautions for automated measurements | 72 |
| | 8.2 | Generic measurement procedure | |
| | 8.3 | Pre-scan measurements | |
| | 8.3.1 | General | 73 |
| | 8.3.2 | Determination of the required measurement time | 74 |
| | 8.3.3 | · | |
| | 8.4 | Data reduction | |
| | 8.5 | Emission maximization and final measurement | |
| | 8.6 | Post-processing and reporting | |
| | 8.7 | Emission measurement strategies with FFT-based measuring instruments | |
| Ar | nex A (| informative) Measurement of disturbances in the presence of ambient | |
| | | , | 78 |
| | A.1 | General | 78 |
| | A.2 | Terms and definitionSTANDARD PREVIEW | 78 |
| | A.3 | | |
| | A.4 | Problem description (standards.iteh.ai) Proposed solution | 78 |
| | A.4.1 | | |
| | A.4.2 | OverviewSISTEN 55016-2-3:2017 Pre-testing the EUT in a shielded room 2d03:48-3ff7-408f-8bd3 | 81 |
| | A.4.3 | | |
| | A.4.4 | Method of measurement of EUT disturbance in the presence of broadband ambient emissions | 85 |
| | A.5 | Determination of the EUT disturbance in case of superposition | 87 |
| Ar | nex B (| informative) Use of spectrum analyzers and scanning receivers | 92 |
| | B.1 | General | 92 |
| | B.2 | Overload | |
| | B.3 | Linearity test | |
| | B.4 | Selectivity | |
| | B.5 | Normal response to pulses | |
| | B.6 | Peak detection | |
| | B.7 | Frequency scan rate | |
| | B.8 | Signal interception | |
| | B.9 | Average detection | |
| | B.10 | Sensitivity | |
| | B.11 | Amplitude accuracy | |
| Ar | | informative) Scan rates and measurement times for use with the average | |
| | | , | 95 |
| | C.1 | Purpose | 95 |
| | C.2 | Suppression of disturbances | 95 |
| | C.2.1 | Suppression of impulsive disturbance | 95 |
| | C.2.2 | | |
| | C.2.3 | | |
| | | | |

| C.3 | Measurement of slowly intermittent, unsteady or drifting narrowband disturbances | 96 |
|-------------|--|-----|
| C.4 | Recommended procedure for automated or semi-automated measurements | 98 |
| | informative) Explanation of the APD measurement method applying to the | 99 |
| | normative) Determination of suitability of spectrum analyzers for compliance | 101 |
| Bibliograp | hy | 102 |
| | - Measurement of a combination of a CW signal (NB) and an impulsive signal g multiple sweeps with maximum hold | 26 |
| Figure 2 - | - Example of a timing analysis | 27 |
| Figure 3 - | - A broadband spectrum measured with a stepped receiver | 28 |
| | - Intermittent narrowband disturbances measured using fast short repetitive ith maximum hold function to obtain an overview of the emission spectrum | 29 |
| Figure 5 - | - FFT scan in segments | 31 |
| Figure 6 - | - Frequency resolution enhanced by FFT-based measuring instrument | 32 |
| | - Concept of magnetic field induced current measurements made with the | 34 |
| Figure 8 - | - Measurement distance | 36 |
| Figure 9 - | - Separation distance relative to the phase centre of an LPDA antenna | 38 |
| test site (| - Concept of electric field strength measurements made on an open-area OATS) or semi-anechoic chamber (SAC) showing the direct and reflecteding at the receiving antenna | 39 |
| Figure 11 | - Position of CMAD for table top equipment on OATS for tin SAC | 42 |
| Figure 12 | – Typical FAR site geometry, where a, b, c, e depend upon the room | 43 |
| Figure 13 | - Typical test set-up for table-top equipment within the test volume of a FAR | 44 |
| | - Typical test set-up for floor-standing equipment within the test volume of a | 45 |
| Figure 15 | - Positions of reference planes for uniform field calibration (top-view) | 48 |
| Figure 16 | - Test set-up for table-top equipment | 52 |
| Figure 17 | - Test set-up for table-top equipment - Top view | 53 |
| _ | - Test set-up for floor-standing equipment | |
| • | - Test set-up for floor-standing equipment - Top view | |
| Figure 20 | – Measurement method above 1 GHz, receive antenna in vertical | |
| • | - Illustration of height scan requirements for two different categories of | 59 |
| Figure 22 | - Determination of the transition distance | 69 |
| | - Substitution method set-up geometries for: a) measurement, b) calibration | |
| | - Process to give reduction of measurement time | |
| | 1 – Flow diagram for the selection of bandwidths and detectors and the measurement errors due to that selection | 80 |
| | 2 – Relative difference in adjacent emission amplitudes during preliminary | 82 |
| Figure A 3 | 3 – Disturbance by an unmodulated signal (dotted line) | 83 |

| Figure A.4 – Disturbance by an amplitude-modulated signal (dotted line) | 83 |
|---|-----|
| Figure A.5 – Indication of an amplitude-modulated signal as a function of modulation frequency with the QP detector in CISPR bands B, C and D | 84 |
| Figure A.6 – Indication of a pulse-modulated signal (pulse width 50 μ s) as a function of pulse repetition frequency with peak, QP and average detectors | 85 |
| Figure A.7 – Disturbance by a broadband signal (dotted line) | 85 |
| Figure A.8 – Unmodulated EUT disturbance (dotted line) | 86 |
| Figure A.9 – Amplitude-modulated EUT disturbance (dotted line) | 87 |
| Figure A.10 – Increase of peak value with superposition of two unmodulated signals | 88 |
| Figure A.11 – Determination of the amplitude of the disturbance signal by means of the amplitude ratio d and the factor i (see Equation (A.3) and Equation (A.6)) | 89 |
| Figure A.12 – Increase of average indication measured with a real receiver and calculated from Equation (A.8) | 90 |
| Figure C.1 – Weighting function of a 10 ms pulse for peak (PK) and average detections with (CISPR AV) and without (AV) peak reading: meter time constant 160 ms | 97 |
| Figure C.2 – Weighting functions of a 10 ms pulse for peak (PK) and average detections with (CISPR AV) and without (AV) peak reading: meter time constant 100 ms | 97 |
| Figure C.3 – Example of weighting functions (of a 1 Hz pulse) for peak (PK) and average detections as a function of pulse width: meter time constant 160 ms | 98 |
| Figure C.4 – Example of weighting functions (of a 1 Hz pulse) for peak (PK) and average detections as a function of pulse width; meter time constant 100 ms | 98 |
| Figure D.1 – Example of APD measurement Method 1 for fluctuating disturbances | 99 |
| Figure D.2 – Example of APD measurement Method 2 for fluctuating disturbances | 100 |
| https://standards.iteh.ai/catalog/standards/sist/782d03a8-3ff7-408f-8bd3- | |
| Table 1 – Minimum measurement times for the four CISPR bands | 23 |
| Table 2 – Minimum scan times for the three CISPR bands with peak and quasi-peak detectors | 23 |
| Table 3 – Applicable frequency ranges and document references for CISPR radiated emission test sites and test methods | 33 |
| Table 4 – Minimum dimension of w (w_{min}) | 58 |
| Table 5 – Example values of w for three antenna types | 59 |
| Table 6 – Horizontal polarization correction factors as a function of frequency | 69 |
| Table 7 – Recommended antenna heights to guarantee signal interception (for prescan) in the frequency range 30 MHz to 1 000 MHz | 75 |
| Table A.1 – Combinations of EUT disturbance and ambient emissions | 79 |
| Table A.2 – Measurement error depending on the detector type and on the combination of ambient and disturbing signal spectra | 91 |
| Table C.1 – Pulse suppression factors and scan rates for a 100 Hz video bandwidth | 96 |
| Table C.2 – Meter time constants and the corresponding video bandwidths and minimum scan times | 96 |
| Table E.1 – Maximum amplitude difference between peak and quasi-peak detected | 101 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY MEASURING APPARATUS AND METHODS –

Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user is itch air catalog/standards/sist/782d03a8-3ff7-408f-8bd3-
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard CISPR 16-2-3 has been prepared by CISPR subcommittee A: Radio-interference measurements and statistical methods.

This fourth edition edition cancels and replaces the third edition published in 2010, its Amendment 1:2010 and its Amendment 2:2014. This edition constitutes a technical revision.

This edition includes the following significant technical change with respect to the previous edition: addition of content on correction of the electric field strength to account for phase centre of log-periodic dipole array antennas.

CISPR 16-2-3:2016 © IEC 2016

It has the status of a basic EMC publication in accordance with IEC Guide 107, Electromagnetic compatibility – Guide to the drafting of electromagnetic compatibility publications.

The text of this standard is based on the following documents:

| FDIS | Report on voting |
|--------------------|------------------|
| CISPR/A/1176A/FDIS | CISPR/A/1182/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the CISPR 16 series, published under the general title *Specification for radio disturbance and immunity measuring apparatus and methods,* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- iTeh STANDARD PREVIEW
- · withdrawn,
- replaced by a revised edition standards.iteh.ai)
- amended.

SIST EN 55016-2-3:2017

https://standards.iteh.ai/catalog/standards/sist/782d03a8-3ff7-408f-8bd3-

082047a21ea3/sist-en-55016-2-3-2017

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

- 8 -

SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY MEASURING APPARATUS AND METHODS –

Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements

1 Scope

This part of CISPR 16 specifies the methods of measurement of radiated disturbance phenomena in the frequency range of 9 kHz to 18 GHz. The aspects of measurement uncertainty are specified in CISPR 16-4-1 and CISPR 16-4-2.

NOTE In accordance with IEC Guide 107 [13]¹, CISPR 16-2-3 is a basic EMC publication for use by product committees of the IEC. As stated in Guide 107, product committees are responsible for determining the applicability of the EMC standard. CISPR and its subcommittees are prepared to co-operate with product committees in the evaluation of the value of particular EMC tests for specific products.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 14-1:2016, Electromagnetic <u>compatibility 2-3 Requirements</u> for household appliances, electric tools and similar apparatus at Rarty 1:a Emission 82 d03a8-3ff7-408f-8bd3-

082047a21ea3/sist-en-55016-2-3-2017

CISPR 16-1-1, Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus

CISPR 16-1-2:2014, Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Coupling devices for conducted disturbance measurements

CISPR 16-1-4:2010, Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-4: Radio disturbance and immunity measuring apparatus – Antennas and test sites for radiated disturbance measurements
CISPR 16-1-4:2010/AMD1:2012

CISPR 16-2-1:2014, Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements

CISPR TR 16-4-1, Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-1: Uncertainties, statistics and limit modelling – Uncertainties in standardized EMC tests

CISPR 16-4-2, Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-2: Uncertainties, statistics and limit modelling – Measurement instrumentation uncertainty

¹ Numbers in square brackets refer to the Bibliography.